

Final Proposed New BAL Reliability Standards Definitions

Final Proposed – Blackline

November 23, 2011

New BAL Reliability Standards Definitions

“reportable disturbance” means any loss of supply that causes an area control error change greater than or equal to eighty per cent (80%) of the ISO’s most severe single contingency

”reserve sharing group” means a group whose members consist of two (2) or more balancing authorities that collectively maintain, allocate and supply operating reserves required for each balancing authority’s use in recovering from contingencies within the group.