

Final Proposed New BAL Reliability Standards Definitions

Final Proposed – Clean

November 23, 2011

New BAL Reliability Standards Definitions

“**reportable disturbance**” means any loss of supply that causes an **area control error** change greater than or equal to eighty per cent (80%) of the **ISO’s** most severe single **contingency**

“**reserve sharing group**” means a group whose members consist of two (2) or more **balancing authorities** that collectively maintain, allocate and supply **operating reserves** required for each **balancing authority’s** use in recovering from **contingencies** within the group.