



AESO Reliability Standards Monthly Report

April 2010

EOP-001-1 – Emergency Operations Planning

Purpose:

Florida Municipal Power Pool request for interpretation.

Standard:

EOP-001-1 was NERC BOT approved October 17, 2008.

Request:

The request for interpretation deals specifically with EOP-001-1 R2.4.

Question 1

Are the plans for system restoration referred to in Requirement R2.4 related to the Balancing Authority's responsibility for maintaining load-generation-interchange balance at all times including during a system restoration?

Question 2

What does "a set of plans for system restoration" mean for a Balancing Authority?

NERC Interpretation:

Response 1

Yes.

Response 2

In addition to the Balancing Authority's stated responsibilities of maintaining the load-generation-interchange balance at all times, the Balancing Authority's "plans for system restoration" must, at a minimum, incorporate provisions to comply with the applicable Balancing Authority requirements of EOP-005-1.

Applicability:

Transmission Operators, Balancing Authorities

Current Status:

The interpretation was posted for pre-ballot review until April 5. Balloting is on hold while NERC goes through the approval process of their revised Standards Development Process.

NERC Link:

[Emergency Operations Planning RFI](#)