



# AESO Reliability Standards Monthly Report

March 2010

## EOP-001-1 – Emergency Operations Planning

### **Purpose:**

Florida Municipal Power Pool request for interpretation.

### **Standard:**

EOP-001-1 was NERC BOT approved October 17, 2008.

### **Request:**

The request for interpretation deals specifically with EOP-001-1 R2.4.

#### Question 1

Are the plans for system restoration referred to in Requirement R2.4 related to the Balancing Authority's responsibility for maintaining load-generation-interchange balance at all times including during a system restoration?

#### Question 2

What does "a set of plans for system restoration" mean for a Balancing Authority?

### **NERC Interpretation:**

#### Response 1

Yes.

#### Response 2

In addition to the Balancing Authority's stated responsibilities of maintaining the loadgeneration-interchange balance at all times, the Balancing Authority's "plans for system restoration" must, at a minimum, incorporate provisions to comply with the applicable Balancing Authority requirements of EOP-005-1.

### **Applicability:**

Transmission Operators, Balancing Authorities

### **Current Status:**

The interpretation is posted for pre-ballot review until April 5.

### **NERC Link:**

[Emergency Operations Planning RFI](#)