



# AESO Reliability Standards Monthly Report

August 2009

## WECC-0065 - Underfrequency Load Shedding Criterion

**Purpose:**

WECC Standards/Regional Criteria Request

**Current Practice:**

Currently the WECC meets NERC PRC-006-0, R1 through the WSCC Coordinated Off-Nominal Frequency Load Shedding and Restoration Plan.

**Proposed Criterion:**

NERC PRC-006-0, R1.4 requires that assessment of the Load Shedding and Restoration Plan shall be conducted periodically but no less than every five years or as required by changes in system condition. The Plan is currently in need of review.

**Applicability:**

Regional Reliability Organization

**Current Status:**

Posted for a 2 week comment period ending on September 02, 2009.

**WECC Link:**

[Underfrequency Load Shedding](#)