



AESO Reliability Standards Monthly Report

September 2010

WECC-0065 Under Frequency Load Shedding

Purpose:

Draft WECC UFLS Plan, posted for comment.

Current Criterion:

There is a new criterion.

Proposed Criterion:

WECC is required to develop, coordinate, and document an Under Frequency Load Shedding program that must include a number of specified features. Currently, WECC meets this Requirement through the WSCC Coordinated Off-Nominal Frequency Load Shedding and Restoration Plan (Plan). NERC PRC-006-0, R1.4 requires that assessment of the Plan shall be conducted periodically but no less than every five years or as required by changes in system condition. The Plan is currently in need of review. Fulfillment of this Request would meet the NERC PRC-006-0 "fill-in-the-blank" requirements.

Applicability:

Balancing Authority

Current Status:

A questionnaire for comments is posted until October 21.

WECC Link:

[UFLS](#)