
Attachment F

Transient Simulation Results

Section: F-3


Figure 1



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1002L (Dome Empress Jenner) near Dome Empress
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1002L (Dome Empress Jenner)
- T = 1.1010 s: Fault is cleared


Figure 2



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1002L (Dome Empress Jenner) near Dome Empress
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1002L (Dome Empress Jenner)
- T = 1.1010 s: Fault is cleared


Figure 3



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1002L (Dome Empress Jenner) near Dome Empress
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1002L (Dome Empress Jenner)
- T = 1.1010 s: Fault is cleared


Figure 4



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1002L (Dome Empress Jenner) near Dome Empress
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1002L (Dome Empress Jenner)
- T = 1.1010 s: Fault is cleared


Figure 5



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1002L (Dome Empress Jenner) near Dome Empress
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1002L (Dome Empress Jenner)
- T = 1.1010 s: Fault is cleared


Figure 6



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1002L (Dome Empress Jenner) near Dome Empress
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1002L (Dome Empress Jenner)
- T = 1.1010 s: Fault is cleared


Figure 7



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1002L (Dome Empress Jenner) near Dome Empress
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1002L (Dome Empress Jenner)
- T = 1.1010 s: Fault is cleared


Figure 8



Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1002L (Dome Empress Jenner) near Dome Empress
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1002L (Dome Empress Jenner)
- T = 1.1010 s: Fault is cleared


Figure 9



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Cassils Bowmanton) near Bowmanton
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Cassils Bowmanton)
- T = 1.1010 s: Fault is cleared


Figure 10



Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Cassils Bowmanton) near Bowmanton
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Cassils Bowmanton)
- T = 1.1010 s: Fault is cleared


Figure 11



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Cassils Bowmanton) near Bowmanton
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Cassils Bowmanton)
- T = 1.1010 s: Fault is cleared


Figure 12



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Cassils Bowmanton) near Bowmanton
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Cassils Bowmanton)
- T = 1.1010 s: Fault is cleared


Figure 13



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Cassils Bowmanton) near Bowmanton
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Cassils Bowmanton)
- T = 1.1010 s: Fault is cleared


Figure 14



Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Cassils Bowmanton) near Bowmanton
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Cassils Bowmanton)
- T = 1.1010 s: Fault is cleared


Figure 15



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Cassils Bowmanton) near Bowmanton
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Cassils Bowmanton)
- T = 1.1010 s: Fault is cleared


Figure 16



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Cassils Bowmanton) near Bowmanton
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Cassils Bowmanton)
- T = 1.1010 s: Fault is cleared


Figure 17



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Bowmanton Cassils) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Bowmanton Cassils)
- T = 1.1010 s: Fault is cleared


Figure 18



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Bowmanton Cassils) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Bowmanton Cassils)
- T = 1.1010 s: Fault is cleared


Figure 19



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Bowmanton Cassils) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Bowmanton Cassils)
- T = 1.1010 s: Fault is cleared


Figure 20



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Bowmanton Cassils) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Bowmanton Cassils)
- T = 1.1010 s: Fault is cleared


Figure 21



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Bowmanton Cassils) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Bowmanton Cassils)
- T = 1.1010 s: Fault is cleared


Figure 22



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Bowmanton Cassils) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Bowmanton Cassils)
- T = 1.1010 s: Fault is cleared


Figure 23



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Bowmanton Cassils) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Bowmanton Cassils)
- T = 1.1010 s: Fault is cleared


Figure 24



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 1034L (Bowmanton Cassils) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 1034L (Bowmanton Cassils)
- T = 1.1010 s: Fault is cleared


Figure 25



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Benalto Red Deer) near Red Deer
- T = 1.0920 s: Tripped 900L (Benalto Red Deer)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 26



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Benalto Red Deer) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 900L (Benalto Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 27



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Benalto Red Deer) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 900L (Benalto Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 28



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Benalto Red Deer) near Red Deer
- T = 1.0920 s: Tripped 900L (Benalto Red Deer)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 29



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Benalto Red Deer) near Red Deer
- T = 1.0920 s: Tripped 900L (Benalto Red Deer)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 30



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Benalto Red Deer) near Red Deer
- T = 1.0920 s: Tripped 900L (Benalto Red Deer)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 31



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Benalto Red Deer) near Red Deer
- T = 1.0920 s: Tripped 900L (Benalto Red Deer)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 32



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Benalto Red Deer) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 900L (Benalto Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 33



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Red Deer Benalto) near Benalto
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 900L (Red Deer Benalto)
- T = 1.0920 s: Fault is cleared


Figure 34



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Red Deer Benalto) near Benalto
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 900L (Red Deer Benalto)
- T = 1.0920 s: Fault is cleared


Figure 35



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Red Deer Benalto) near Benalto
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 900L (Red Deer Benalto)
- T = 1.0920 s: Fault is cleared


Figure 36



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Red Deer Benalto) near Benalto
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 900L (Red Deer Benalto)
- T = 1.0920 s: Fault is cleared


Figure 37



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Red Deer Benalto) near Benalto
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 900L (Red Deer Benalto)
- T = 1.0920 s: Fault is cleared


Figure 38



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Red Deer Benalto) near Benalto
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 900L (Red Deer Benalto)
- T = 1.0920 s: Fault is cleared


Figure 39



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Red Deer Benalto) near Benalto
- T = 1.0920 s: Tripped 900L (Red Deer Benalto)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 40



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 900L (Red Deer Benalto) near Benalto
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 900L (Red Deer Benalto)
- T = 1.0920 s: Fault is cleared

Figure 41




- Study case: 2023 H3; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Saunders Lake

Figure 42




- Study case: 2023 H8; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Saunders Lake

Figure 43




- Study case: 2023 H2; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Saunders Lake

Figure 44




Study case: 2023 H4; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Saunders Lake

Figure 45




- Study case: 2023 H1; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Saunders Lake

Figure 46




- Study case: 2023 H6; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Saunders Lake

Figure 47




- Study case: 2023 H7; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Saunders Lake

Figure 48




- Study case: 2023 H5; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Saunders Lake


Figure 49



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Saunders Lake Wolf Creek) near Saunders Lake
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Saunders Lake Wolf Creek)
- T = 1.1010 s: Fault is cleared


Figure 50



Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Saunders Lake Wolf Creek) near Saunders Lake
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Saunders Lake Wolf Creek)
- T = 1.1010 s: Fault is cleared


Figure 51



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Saunders Lake Wolf Creek) near Saunders Lake
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Saunders Lake Wolf Creek)
- T = 1.1010 s: Fault is cleared


Figure 52



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Saunders Lake Wolf Creek) near Saunders Lake
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Saunders Lake Wolf Creek)
- T = 1.1010 s: Fault is cleared


Figure 53



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Saunders Lake Wolf Creek) near Saunders Lake
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Saunders Lake Wolf Creek)
- T = 1.1010 s: Fault is cleared


Figure 54



Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Saunders Lake Wolf Creek) near Saunders Lake
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Saunders Lake Wolf Creek)
- T = 1.1010 s: Fault is cleared


Figure 55



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Saunders Lake Wolf Creek) near Saunders Lake
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Saunders Lake Wolf Creek)
- T = 1.1010 s: Fault is cleared


Figure 56



Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Saunders Lake Wolf Creek) near Saunders Lake
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Saunders Lake Wolf Creek)
- T = 1.1010 s: Fault is cleared


Figure 57



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Wolf Creek Saunders Lake) near Wolf Creek
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Wolf Creek Saunders Lake)
- T = 1.1010 s: Fault is cleared


Figure 58



Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Wolf Creek Saunders Lake) near Wolf Creek
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Wolf Creek Saunders Lake)
- T = 1.1010 s: Fault is cleared


Figure 59



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Wolf Creek Saunders Lake) near Wolf Creek
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Wolf Creek Saunders Lake)
- T = 1.1010 s: Fault is cleared


Figure 60



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Wolf Creek Saunders Lake) near Wolf Creek
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Wolf Creek Saunders Lake)
- T = 1.1010 s: Fault is cleared


Figure 61



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Wolf Creek Saunders Lake) near Wolf Creek
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Wolf Creek Saunders Lake)
- T = 1.1010 s: Fault is cleared


Figure 62



Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Wolf Creek Saunders Lake) near Wolf Creek
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Wolf Creek Saunders Lake)
- T = 1.1010 s: Fault is cleared


Figure 63



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Wolf Creek Saunders Lake) near Wolf Creek
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Wolf Creek Saunders Lake)
- T = 1.1010 s: Fault is cleared


Figure 64



Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 910L (Wolf Creek Saunders Lake) near Wolf Creek
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 910L (Wolf Creek Saunders Lake)
- T = 1.1010 s: Fault is cleared


Figure 65



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Nevis Red Deer) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 912L (Nevis Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 66



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Nevis Red Deer) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 912L (Nevis Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 67



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Nevis Red Deer) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 912L (Nevis Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 68



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Nevis Red Deer) near Red Deer
- T = 1.0920 s: Tripped 912L (Nevis Red Deer)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 69



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Nevis Red Deer) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 912L (Nevis Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 70



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Nevis Red Deer) near Red Deer
- T = 1.0920 s: Tripped 912L (Nevis Red Deer)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 71



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Nevis Red Deer) near Red Deer
- T = 1.0920 s: Tripped 912L (Nevis Red Deer)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 72



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Nevis Red Deer) near Red Deer
- T = 1.0920 s: Tripped 912L (Nevis Red Deer)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 73



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Red Deer Nevis) near Nevis
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 912L (Red Deer Nevis)
- T = 1.0920 s: Fault is cleared


Figure 74



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Red Deer Nevis) near Nevis
- T = 1.0920 s: Tripped 912L (Red Deer Nevis)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 75



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Red Deer Nevis) near Nevis
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 912L (Red Deer Nevis)
- T = 1.0920 s: Fault is cleared


Figure 76



- Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Red Deer Nevis) near Nevis
- T = 1.0920 s: Tripped 912L (Red Deer Nevis)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 77



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Red Deer Nevis) near Nevis
- T = 1.0920 s: Tripped 912L (Red Deer Nevis)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 78



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Red Deer Nevis) near Nevis
- T = 1.0920 s: Tripped 912L (Red Deer Nevis)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 79



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Red Deer Nevis) near Nevis
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 912L (Red Deer Nevis)
- T = 1.0920 s: Fault is cleared


Figure 80



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 912L (Red Deer Nevis) near Nevis
- T = 1.0920 s: Tripped 912L (Red Deer Nevis)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 81



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Bigstone Gaetz) near Bigstone
- T = 1.0920 s: Tripped 914L (Bigstone Gaetz)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 82



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Bigstone Gaetz) near Bigstone
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Bigstone Gaetz)
- T = 1.0920 s: Fault is cleared


Figure 83



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Bigstone Gaetz) near Bigstone
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Bigstone Gaetz)
- T = 1.0920 s: Fault is cleared


Figure 84



- Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Bigstone Gaetz) near Bigstone
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Bigstone Gaetz)
- T = 1.0920 s: Fault is cleared


Figure 85



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Bigstone Gaetz) near Bigstone
- T = 1.0920 s: Tripped 914L (Bigstone Gaetz)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 86



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Bigstone Gaetz) near Bigstone
- T = 1.0920 s: Tripped 914L (Bigstone Gaetz)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 87



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Bigstone Gaetz) near Bigstone
- -- T = 1.0920 s: Tripped 914L (Bigstone Gaetz)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 88



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Bigstone Gaetz) near Bigstone
- -- T = 1.0920 s: Tripped 914L (Bigstone Gaetz)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 89



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Bigstone) near Gaetz
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Gaetz Bigstone)
- T = 1.0920 s: Fault is cleared


Figure 90



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Bigstone) near Gaetz
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Gaetz Bigstone)
- T = 1.0920 s: Fault is cleared


Figure 91



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Bigstone) near Gaetz
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Gaetz Bigstone)
- T = 1.0920 s: Fault is cleared


Figure 92



- Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Bigstone) near Gaetz
- T = 1.0920 s: Tripped 914L (Gaetz Bigstone)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 93



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Bigstone) near Gaetz
- T = 1.0920 s: Tripped 914L (Gaetz Bigstone)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 94



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Bigstone) near Gaetz
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Gaetz Bigstone)
- T = 1.0920 s: Fault is cleared


Figure 95



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Bigstone) near Gaetz
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Gaetz Bigstone)
- T = 1.0920 s: Fault is cleared


Figure 96



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Bigstone) near Gaetz
- T = 1.0920 s: Tripped 914L (Gaetz Bigstone)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 97



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Red Deer Gaetz) near Gaetz
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Red Deer Gaetz)
- T = 1.0920 s: Fault is cleared


Figure 98



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Red Deer Gaetz) near Gaetz
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Red Deer Gaetz)
- T = 1.0920 s: Fault is cleared


Figure 99



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Red Deer Gaetz) near Gaetz
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Red Deer Gaetz)
- T = 1.0920 s: Fault is cleared

Figure 100




Case Description

- Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Red Deer Gaetz) near Gaetz
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Red Deer Gaetz)
- T = 1.0920 s: Fault is cleared


Figure 101



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Red Deer Gaetz) near Gaetz
- T = 1.0920 s: Tripped 914L (Red Deer Gaetz)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers

Figure 102




Case Description

- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Red Deer Gaetz) near Gaetz
- T = 1.0920 s: Tripped 914L (Red Deer Gaetz)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 103



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Red Deer Gaetz) near Gaetz
- T = 1.0920 s: Tripped 914L (Red Deer Gaetz)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 104



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Red Deer Gaetz) near Gaetz
- T = 1.0920 s: Tripped 914L (Red Deer Gaetz)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 105



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Red Deer) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Gaetz Red Deer)
- T = 1.0920 s: Fault is cleared

Figure 106




Case Description

- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Red Deer) near Red Deer
- T = 1.0920 s: Tripped 914L (Gaetz Red Deer)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 107



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Red Deer) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Gaetz Red Deer)
- T = 1.0920 s: Fault is cleared

Figure 108




Case Description

Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Red Deer) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Gaetz Red Deer)
- T = 1.0920 s: Fault is cleared

Figure 109




Case Description

- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Red Deer) near Red Deer
- T = 1.0920 s: Tripped 914L (Gaetz Red Deer)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 110



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Red Deer) near Red Deer
- T = 1.0920 s: Tripped 914L (Gaetz Red Deer)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 111



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Red Deer) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Gaetz Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 112



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 914L (Gaetz Red Deer) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 914L (Gaetz Red Deer)
- T = 1.0920 s: Fault is cleared

Figure 113




Study case: 2023 H3; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

T = 1.1010 s: Tripped 923L
T = 1.1010 s: Tripped 935L
T = 1.1010 s: Fault is cleared

Figure 114




Study case: 2023 H8; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

T = 1.1010 s: Tripped 923L
T = 1.1010 s: Tripped 935L
T = 1.1010 s: Fault is cleared

Figure 115




Study case: 2023 H2; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

T = 1.1010 s: Tripped 923L
T = 1.1010 s: Tripped 935L
T = 1.1010 s: Fault is cleared

Figure 116




Study case: 2023 H4; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

- T = 1.1010 s: EATL runback to 500 MW activated

Figure 117




Study case: 2023 H1; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

T = 1.1010 s: Tripped 923L
T = 1.1010 s: Tripped 935L
T = 1.1010 s: Fault is cleared

Figure 118




- Study case: 2023 H6; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

T = 1.1010 s: Tripped 923L
T = 1.1010 s: Tripped 935L
T = 1.1010 s: Fault is cleared

Figure 119




Study case: 2023 H7; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

T = 1.1010 s: Tripped 923L
T = 1.1010 s: Tripped 935L
T = 1.1010 s: Fault is cleared

Figure 120




- Study case: 2023 H5; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

- T = 1.1010 s: EATL runback to 500 MW activated

Figure 121




Study case: 2023 H3; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

Figure 122




Study case: 2023 H8; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

Figure 123




Study case: 2023 H2; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

Figure 124




Study case: 2023 H4; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

Figure 125




Study case: 2023 H1; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

Figure 126




- Study case: 2023 H6; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

Figure 127




Study case: 2023 H7; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

Figure 128




Study case: 2023 H5; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Milo

Figure 129




- Study case: 2023 H3; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Janet

Figure 130




- Study case: 2023 H8; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Janet

Figure 131




Study case: 2023 H2; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Janet

Figure 132




Study case: 2023 H4; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Janet

Figure 133




Study case: 2023 H1; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Janet

Figure 134




Study case: 2023 H6; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Janet

Figure 135




Study case: 2023 H7; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Janet

Figure 136




- Study case: 2023 H5; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Janet


Figure 137



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Red Deer Janet) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Red Deer Janet)
- T = 1.0920 s: Fault is cleared


Figure 138



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Red Deer Janet) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Red Deer Janet)
- T = 1.0920 s: Fault is cleared


Figure 139



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Red Deer Janet) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Red Deer Janet)
- T = 1.0920 s: Fault is cleared


Figure 140



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Red Deer Janet) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Red Deer Janet)
- T = 1.0920 s: Fault is cleared


Figure 141



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Red Deer Janet) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Red Deer Janet)
- T = 1.0920 s: Fault is cleared


Figure 142



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Red Deer Janet) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Red Deer Janet)
- T = 1.0920 s: Fault is cleared


Figure 143



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Red Deer Janet) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Red Deer Janet)
- T = 1.0920 s: Fault is cleared


Figure 144



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Red Deer Janet) near Red Deer
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Red Deer Janet)
- T = 1.0920 s: Fault is cleared


Figure 145



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Janet Red Deer) near Janet
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Janet Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 146



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Janet Red Deer) near Janet
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Janet Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 147



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Janet Red Deer) near Janet
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Janet Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 148



- Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Janet Red Deer) near Janet
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Janet Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 149



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Janet Red Deer) near Janet
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Janet Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 150



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Janet Red Deer) near Janet
- T = 1.0920 s: Tripped 925L (Janet Red Deer)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 151



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Janet Red Deer) near Janet
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Janet Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 152



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 925L (Janet Red Deer) near Janet
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 925L (Janet Red Deer)
- T = 1.0920 s: Fault is cleared


Figure 153



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Langdon Milo) near Langdon
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Langdon Milo)
- T = 1.1010 s: Fault is cleared


Figure 154



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Langdon Milo) near Langdon
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Langdon Milo)
- T = 1.1010 s: Fault is cleared


Figure 155



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Langdon Milo) near Langdon
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Langdon Milo)
- T = 1.1010 s: Fault is cleared


Figure 156



- Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Langdon Milo) near Langdon
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Langdon Milo)
- T = 1.1010 s: Fault is cleared


Figure 157



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Langdon Milo) near Langdon
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Langdon Milo)
- T = 1.1010 s: Fault is cleared


Figure 158



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Langdon Milo) near Langdon
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Langdon Milo)
- T = 1.1010 s: Fault is cleared


Figure 159



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Langdon Milo) near Langdon
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Langdon Milo)
- T = 1.1010 s: Fault is cleared

Figure 160




Case Description

- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Langdon Milo) near Langdon
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Langdon Milo)
- T = 1.1010 s: Fault is cleared


Figure 161



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Milo Langdon) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Milo Langdon)
- T = 1.1010 s: Fault is cleared


Figure 162



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Milo Langdon) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Milo Langdon)
- T = 1.1010 s: Fault is cleared


Figure 163



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Milo Langdon) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Milo Langdon)
- T = 1.1010 s: Fault is cleared


Figure 164



- Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Milo Langdon) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Milo Langdon)
- T = 1.1010 s: Fault is cleared


Figure 165



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Milo Langdon) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Milo Langdon)
- T = 1.1010 s: Fault is cleared


Figure 166



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Milo Langdon) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Milo Langdon)
- T = 1.1010 s: Fault is cleared


Figure 167



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Milo Langdon) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Milo Langdon)
- T = 1.1010 s: Fault is cleared


Figure 168



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 927L (Milo Langdon) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 927L (Milo Langdon)
- T = 1.1010 s: Fault is cleared


Figure 169



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Janet Hazelwood) near Janet
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 929L (Janet Hazelwood)
- T = 1.0920 s: Fault is cleared


Figure 170



Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Janet Hazelwood) near Janet
- T = 1.0920 s: Tripped 929L (Janet Hazelwood)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 171



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Janet Hazelwood) near Janet
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 929L (Janet Hazelwood)
- T = 1.0920 s: Fault is cleared


Figure 172



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Janet Hazelwood) near Janet
- T = 1.0920 s: Tripped 929L (Janet Hazelwood)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 173



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Janet Hazelwood) near Janet
- T = 1.0920 s: Tripped 929L (Janet Hazelwood)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 174



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Janet Hazelwood) near Janet
- T = 1.0920 s: Tripped 929L (Janet Hazelwood)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 175



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Janet Hazelwood) near Janet
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 929L (Janet Hazelwood)
- T = 1.0920 s: Fault is cleared


Figure 176



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Janet Hazelwood) near Janet
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 929L (Janet Hazelwood)
- T = 1.0920 s: Fault is cleared


Figure 177



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Hazelwood Janet) near Hazelwood
- T = 1.0920 s: Tripped 929L (Hazelwood Janet)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 178



Study case: 2023 H8; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 929L (Hazelwood Janet) near Hazelwood
- T = 1.0920 s: Tripped 929L (Hazelwood Janet)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers

Figure 179



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Hazelwood Janet) near Hazelwood
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 929L (Hazelwood Janet)
- T = 1.0920 s: Fault is cleared




Case Description

Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Hazelwood Janet) near Hazelwood
- T = 1.0920 s: Tripped 929L (Hazelwood Janet)
- T = 1.0920 s: Fault is cleared
- T = 1.0920 s: Opened both breakers


Figure 181



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Hazelwood Janet) near Hazelwood
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 929L (Hazelwood Janet)
- T = 1.0920 s: Fault is cleared


Figure 182



Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Hazelwood Janet) near Hazelwood
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 929L (Hazelwood Janet)
- T = 1.0920 s: Fault is cleared


Figure 183



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Hazelwood Janet) near Hazelwood
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 929L (Hazelwood Janet)
- T = 1.0920 s: Fault is cleared


Figure 184



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 929L (Hazelwood Janet) near Hazelwood
- T = 1.0920 s: Opened both breakers
- T = 1.0920 s: Tripped 929L (Hazelwood Janet)
- T = 1.0920 s: Fault is cleared


Figure 185



- Study case: 2023 H3; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at West Brooks




Case Description

- Study case: 2023 H8; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at West Brooks


Figure 187



- Study case: 2023 H2; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at West Brooks




Case Description

- Study case: 2023 H4; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at West Brooks




Case Description

- Study case: 2023 H1; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at West Brooks




Case Description

- Study case: 2023 H6; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at West Brooks

Figure 191




- Study case: 2023 H7; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at West Brooks

Figure 192




- Study case: 2023 H5; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at West Brooks

Figure 193




- Study case: 2023 H3; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Anderson

Figure 194




- Study case: 2023 H8; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Anderson


Figure 195



- Study case: 2023 H2; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Anderson




Case Description

- Study case: 2023 H4; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Anderson

Figure 197




- Study case: 2023 H1; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Anderson


Figure 198



- Study case: 2023 H6; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Anderson




Case Description

- Study case: 2023 H7; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Anderson




Case Description

- Study case: 2023 H5; Pre Project (No CRPC)

Event Description


— T = 1.0020 s: Applied 3-ph fault at Anderson



Case Description

- Study case: 2023 H3; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 935L (Cassils Milo) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Cassils Milo)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H8; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 935L (Cassils Milo) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Cassils Milo)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H2; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 935L (Cassils Milo) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Cassils Milo)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H4; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 935L (Cassils Milo) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Cassils Milo)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H1; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 935L (Cassils Milo) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Cassils Milo)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H6; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 935L (Cassils Milo) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Cassils Milo)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H7; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 935L (Cassils Milo) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Cassils Milo)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 935L (Cassils Milo) near Cassils
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Cassils Milo)
- T = 1.1010 s: Fault is cleared




Case Description

- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 935L (Milo Cassils) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Milo Cassils)
- T = 1.1010 s: Fault is cleared


Figure 210



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 935L (Milo Cassils) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Milo Cassils)
- T = 1.1010 s: Fault is cleared


Figure 211



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 935L (Milo Cassils) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Milo Cassils)
- T = 1.1010 s: Fault is cleared


Figure 212



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 935L (Milo Cassils) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Milo Cassils)
- T = 1.1010 s: Fault is cleared


Figure 213



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 935L (Milo Cassils) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Milo Cassils)
- T = 1.1010 s: Fault is cleared


Figure 214



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 935L (Milo Cassils) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Milo Cassils)
- T = 1.1010 s: Fault is cleared


Figure 215



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 935L (Milo Cassils) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Milo Cassils)
- T = 1.1010 s: Fault is cleared


Figure 216



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 935L (Milo Cassils) near Milo
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 935L (Milo Cassils)
- T = 1.1010 s: Fault is cleared


Figure 217



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Ware Jct. Jenner) near Ware Jct.
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Ware Jct. Jenner)
- T = 1.1220 s: Fault is cleared


Figure 218



Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Ware Jct. Jenner) near Ware Jct.
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Ware Jct. Jenner)
- T = 1.1220 s: Fault is cleared


Figure 219



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Ware Jct. Jenner) near Ware Jct.
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Ware Jct. Jenner)
- T = 1.1220 s: Fault is cleared

Figure 220




Case Description

Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Ware Jct. Jenner) near Ware Jct.
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Ware Jct. Jenner)
- T = 1.1220 s: Fault is cleared


Figure 221



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Ware Jct. Jenner) near Ware Jct.
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Ware Jct. Jenner)
- T = 1.1220 s: Fault is cleared


Figure 222



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Ware Jct. Jenner) near Ware Jct.
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Ware Jct. Jenner)
- T = 1.1220 s: Fault is cleared


Figure 223



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Ware Jct. Jenner) near Ware Jct.
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Ware Jct. Jenner)
- T = 1.1220 s: Fault is cleared


Figure 224



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Ware Jct. Jenner) near Ware Jct.
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Ware Jct. Jenner)
- T = 1.1220 s: Fault is cleared


Figure 225



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Jenner Ware Jct.) near Jenner
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Jenner Ware Jct.)
- T = 1.1220 s: Fault is cleared


Figure 226



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Jenner Ware Jct.) near Jenner
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Jenner Ware Jct.)
- T = 1.1220 s: Fault is cleared


Figure 227



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Jenner Ware Jct.) near Jenner
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Jenner Ware Jct.)
- T = 1.1220 s: Fault is cleared


Figure 228



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Jenner Ware Jct.) near Jenner
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Jenner Ware Jct.)
- T = 1.1220 s: Fault is cleared


Figure 229



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Jenner Ware Jct.) near Jenner
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Jenner Ware Jct.)
- T = 1.1220 s: Fault is cleared


Figure 230



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Jenner Ware Jct.) near Jenner
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Jenner Ware Jct.)
- T = 1.1220 s: Fault is cleared


Figure 231



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Jenner Ware Jct.) near Jenner
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Jenner Ware Jct.)
- T = 1.1220 s: Fault is cleared


Figure 232



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 944L (Jenner Ware Jct.) near Jenner
- T = 1.1070 s: Opened near end breaker
- T = 1.1220 s: Tripped 944L (Jenner Ware Jct.)
- T = 1.1220 s: Fault is cleared


Figure 233



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Tinchebray Cordel) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Tinchebray Cordel)
- T = 1.1010 s: Fault is cleared


Figure 234



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Tinchebray Cordel) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Tinchebray Cordel)
- T = 1.1010 s: Fault is cleared


Figure 235



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Tinchebray Cordel) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Tinchebray Cordel)
- T = 1.1010 s: Fault is cleared


Figure 236



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Tinchebray Cordel) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Tinchebray Cordel)
- T = 1.1010 s: Fault is cleared


Figure 237



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Tinchebray Cordel) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Tinchebray Cordel)
- T = 1.1010 s: Fault is cleared


Figure 238



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Tinchebray Cordel) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Tinchebray Cordel)
- T = 1.1010 s: Fault is cleared


Figure 239



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Tinchebray Cordel) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Tinchebray Cordel)
- T = 1.1010 s: Fault is cleared


Figure 240



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Tinchebray Cordel) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Tinchebray Cordel)
- T = 1.1010 s: Fault is cleared


Figure 241



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Cordel Tinchebray) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Cordel Tinchebray)
- T = 1.1010 s: Fault is cleared


Figure 242



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Cordel Tinchebray) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Cordel Tinchebray)
- T = 1.1010 s: Fault is cleared


Figure 243



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Cordel Tinchebray) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Cordel Tinchebray)
- T = 1.1010 s: Fault is cleared


Figure 244



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Cordel Tinchebray) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Cordel Tinchebray)
- T = 1.1010 s: Fault is cleared


Figure 245



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Cordel Tinchebray) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Cordel Tinchebray)
- T = 1.1010 s: Fault is cleared


Figure 246



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Cordel Tinchebray) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Cordel Tinchebray)
- T = 1.1010 s: Fault is cleared


Figure 247



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Cordel Tinchebray) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Cordel Tinchebray)
- T = 1.1010 s: Fault is cleared


Figure 248



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L16 (Cordel Tinchebray) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L16 (Cordel Tinchebray)
- T = 1.1010 s: Fault is cleared


Figure 249



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L20 (Nevis Cordel) near Nevis
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Nevis Cordel)
- T = 1.1010 s: Fault is cleared

Figure 250




Case Description

- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L20 (Nevis Cordel) near Nevis
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Nevis Cordel)
- T = 1.1010 s: Fault is cleared


Figure 251



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L20 (Nevis Cordel) near Nevis
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Nevis Cordel)
- T = 1.1010 s: Fault is cleared


Figure 252



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L20 (Nevis Cordel) near Nevis
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Nevis Cordel)
- T = 1.1010 s: Fault is cleared


Figure 253



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L20 (Nevis Cordel) near Nevis
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Nevis Cordel)
- T = 1.1010 s: Fault is cleared


Figure 254



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L20 (Nevis Cordel) near Nevis
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Nevis Cordel)
- T = 1.1010 s: Fault is cleared


Figure 255



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L20 (Nevis Cordel) near Nevis
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Nevis Cordel)
- T = 1.1010 s: Fault is cleared


Figure 256



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L20 (Nevis Cordel) near Nevis
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Nevis Cordel)
- T = 1.1010 s: Fault is cleared


Figure 257



- Study case: 2023 H3; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L20 (Cordel Nevis) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Cordel Nevis)
- T = 1.1010 s: Fault is cleared

Figure 258



- Study case: 2023 H8; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L20 (Cordel Nevis) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Cordel Nevis)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L20 (Cordel Nevis) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Cordel Nevis)
- T = 1.1010 s: Fault is cleared




Case Description

Study case: 2023 H4; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L20 (Cordel Nevis) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Cordel Nevis)
- T = 1.1010 s: Fault is cleared

Figure 261



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L20 (Cordel Nevis) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Cordel Nevis)
- T = 1.1010 s: Fault is cleared




Case Description

- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L20 (Cordel Nevis) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Cordel Nevis)
- T = 1.1010 s: Fault is cleared


Figure 263



- Study case: 2023 H7; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L20 (Cordel Nevis) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Cordel Nevis)
- T = 1.1010 s: Fault is cleared

Figure 264



- Study case: 2023 H5; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L20 (Cordel Nevis) near Cordel
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L20 (Cordel Nevis)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L46 (New Brigden Lanfine) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (New Brigden Lanfine)
- T = 1.1010 s: Fault is cleared




Case Description

- Study case: 2023 H8; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L46 (New Brigden Lanfine) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (New Brigden Lanfine)
- T = 1.1010 s: Fault is cleared

Figure 267



- Study case: 2023 H2; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L46 (New Brigden Lanfine) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (New Brigden Lanfine)
- T = 1.1010 s: Fault is cleared



Case Description

Study case: 2023 H4; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L46 (New Brigden Lanfine) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (New Brigden Lanfine)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L46 (New Brigden Lanfine) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (New Brigden Lanfine)
- T = 1.1010 s: Fault is cleared




Case Description

- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L46 (New Brigden Lanfine) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (New Brigden Lanfine)
- T = 1.1010 s: Fault is cleared


Figure 271



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L46 (New Brigden Lanfine) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (New Brigden Lanfine)
- T = 1.1010 s: Fault is cleared


Figure 272



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L46 (New Brigden Lanfine) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (New Brigden Lanfine)
- T = 1.1010 s: Fault is cleared


Figure 273



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L46 (Lanfine New Bridgen) near Lanfine
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (Lanfine New Bridgen)
- T = 1.1010 s: Fault is cleared


Figure 274



- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L46 (Lanfine New Bridgen) near Lanfine
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (Lanfine New Bridgen)
- T = 1.1010 s: Fault is cleared


Figure 275



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L46 (Lanfine New Bridgen) near Lanfine
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (Lanfine New Bridgen)
- T = 1.1010 s: Fault is cleared


Figure 276



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L46 (Lanfine New Bridgen) near Lanfine
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (Lanfine New Bridgen)
- T = 1.1010 s: Fault is cleared


Figure 277



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L46 (Lanfine New Bridgen) near Lanfine
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (Lanfine New Bridgen)
- T = 1.1010 s: Fault is cleared


Figure 278



- Study case: 2023 H6; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L46 (Lanfine New Bridgen) near Lanfine
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (Lanfine New Bridgen)
- T = 1.1010 s: Fault is cleared

Figure 279



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L46 (Lanfine New Bridgen) near Lanfine
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (Lanfine New Bridgen)
- T = 1.1010 s: Fault is cleared




Case Description

- Study case: 2023 H5; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L46 (Lanfine New Bridgen) near Lanfine
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L46 (Lanfine New Bridgen)
- T = 1.1010 s: Fault is cleared

Figure 281



- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L51 (New Brigden Pemukan) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (New Brigden Pemukan)
- T = 1.1010 s: Fault is cleared




Case Description

- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L51 (New Brigden Pemukan) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (New Brigden Pemukan)
- T = 1.1010 s: Fault is cleared


Figure 283



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L51 (New Brigden Pemukan) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (New Brigden Pemukan)
- T = 1.1010 s: Fault is cleared


Figure 284



Study case: 2023 H4; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L51 (New Brigden Pemukan) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (New Brigden Pemukan)
- T = 1.1010 s: Fault is cleared

Figure 285



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L51 (New Brigden Pemukan) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (New Brigden Pemukan)
- T = 1.1010 s: Fault is cleared




Case Description

- Study case: 2023 H6; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L51 (New Brigden Pemukan) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (New Brigden Pemukan)
- T = 1.1010 s: Fault is cleared

Figure 287



- Study case: 2023 H7; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L51 (New Brigden Pemukan) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (New Brigden Pemukan)
- T = 1.1010 s: Fault is cleared



Case Description

Study case: 2023 H5; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L51 (New Brigden Pemukan) near New Brigden
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (New Brigden Pemukan)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L51 (Pemukan New Bridgen) near Pemukan
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (Pemukan New Bridgen)
- T = 1.1010 s: Fault is cleared




Case Description

- Study case: 2023 H8; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L51 (Pemukan New Bridgen) near Pemukan
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (Pemukan New Bridgen)
- T = 1.1010 s: Fault is cleared


Figure 291



- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L51 (Pemukan New Bridgen) near Pemukan
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (Pemukan New Bridgen)
- T = 1.1010 s: Fault is cleared


Figure 292



Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L51 (Pemukan New Bridgen) near Pemukan
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (Pemukan New Bridgen)
- T = 1.1010 s: Fault is cleared


Figure 293



- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L51 (Pemukan New Bridgen) near Pemukan
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (Pemukan New Bridgen)
- T = 1.1010 s: Fault is cleared


Figure 294



- Study case: 2023 H6; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L51 (Pemukan New Bridgen) near Pemukan
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (Pemukan New Bridgen)
- T = 1.1010 s: Fault is cleared

Figure 295



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L51 (Pemukan New Bridgen) near Pemukan
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (Pemukan New Bridgen)
- T = 1.1010 s: Fault is cleared




Case Description

- Study case: 2023 H5; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L51 (Pemukan New Bridgen) near Pemukan
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L51 (Pemukan New Bridgen)
- T = 1.1010 s: Fault is cleared

Figure 297



- Study case: 2023 H3; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L59 (Tinchebray Anderson) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Tinchebray Anderson)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H8; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L59 (Tinchebray Anderson) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Tinchebray Anderson)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H2; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L59 (Tinchebray Anderson) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Tinchebray Anderson)
- T = 1.1010 s: Fault is cleared




Case Description

Study case: 2023 H4; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L59 (Tinchebray Anderson) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Tinchebray Anderson)
- T = 1.1010 s: Fault is cleared

Figure 301



- Study case: 2023 H1; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L59 (Tinchebray Anderson) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Tinchebray Anderson)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H6; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L59 (Tinchebray Anderson) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Tinchebray Anderson)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H7; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L59 (Tinchebray Anderson) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Tinchebray Anderson)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H5; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L59 (Tinchebray Anderson) near Tinchebray
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Tinchebray Anderson)
- T = 1.1010 s: Fault is cleared



Case Description

- Study case: 2023 H3; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L59 (Anderson Tinchebray) near Anderson
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Anderson Tinchebray)
- T = 1.1010 s: Fault is cleared




Case Description

- Study case: 2023 H8; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L59 (Anderson Tinchebray) near Anderson
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Anderson Tinchebray)
- T = 1.1010 s: Fault is cleared

Figure 307



- Study case: 2023 H2; Pre Project (No CRPC)


- T = 1.0020 s: Applied 3-ph fault on 9L59 (Anderson Tinchebray) near Anderson
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Anderson Tinchebray)
- T = 1.1010 s: Fault is cleared



Case Description

Study case: 2023 H4; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L59 (Anderson Tinchebray) near Anderson
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Anderson Tinchebray)
- T = 1.1010 s: Fault is cleared




Case Description

- Study case: 2023 H1; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L59 (Anderson Tinchebray) near Anderson
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Anderson Tinchebray)
- T = 1.1010 s: Fault is cleared


Figure 310



- Study case: 2023 H6; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L59 (Anderson Tinchebray) near Anderson
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Anderson Tinchebray)
- T = 1.1010 s: Fault is cleared


Figure 311



- Study case: 2023 H7; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L59 (Anderson Tinchebray) near Anderson
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Anderson Tinchebray)
- T = 1.1010 s: Fault is cleared


Figure 312



- Study case: 2023 H5; Pre Project (No CRPC)

- T = 1.0020 s: Applied 3-ph fault on 9L59 (Anderson Tinchebray) near Anderson
- T = 1.0860 s: Opened near end breaker
- T = 1.1010 s: Tripped 9L59 (Anderson Tinchebray)
- T = 1.1010 s: Fault is cleared

Figure 313




- Study case: 2023 H3; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Newell

Figure 314




- Study case: 2023 H8; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Newell

Figure 315




- Study case: 2023 H2; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Newell

Figure 316




Study case: 2023 H4; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Newell

Figure 317




- Study case: 2023 H1; Pre Project (No CRPC)

Event Description

- T = 1.0020 s: Applied 3-ph fault at Newell

Figure 318




- Study case: 2023 H6; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Newell

Figure 319




- Study case: 2023 H7; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Newell

Figure 320




- Study case: 2023 H5; Pre Project (No CRPC)

Event Description

- T = 1.0020 s: Applied 3-ph fault at Newell

Figure 321




- Study case: 2023 H3; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Crossings

Figure 322




- Study case: 2023 H8; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Crossings

Figure 323




- Study case: 2023 H2; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Crossings

Figure 324




Study case: 2023 H4; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Crossings

Figure 325




- Study case: 2023 H1; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Crossings

Figure 326




- Study case: 2023 H6; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Crossings

Figure 327




- Study case: 2023 H7; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Crossings

Figure 328



- Study case: 2023 H5; Pre Project (No CRPC)

Event Description

— T = 1.0020 s: Applied 3-ph fault at Crossings