

# ISO Rules

## Part 500 Facilities

### Division 502 Technical Requirements

#### Section 502.15 Reporting Facility Modelling Data



#### Applicability

- 1 Section 502.15 applies to:
- (a) the **legal owner** of a **transmission facility**;
  - (b) the **legal owner** of an **aggregated generating facility** directly connected to the **transmission system**;
  - (c) the **legal owner** of a **generating unit** directly connected to the **transmission system**;
  - (d) the **legal owner** of an industrial complex directly connected to the **transmission system**;
  - (e) the **legal owner** of an **electric distribution system**; and
  - (f) the **ISO**.

#### Requirements

##### Submission of Data Related to a New Facility, or a Planned Modification to, or Re-rating of, an Existing Facility

**2(1)** The **ISO** must post a list of electrical and physical parameters for the modelling data and records that are to be submitted to the **ISO** in accordance with this sSection 502.15 to the AESO website, which may be amended from time to time in accordance with subsection 8.

**(2)** Subject to subsection 3, a **legal owner** must submit to the **ISO** the modelling data and records related to new equipment, machinery or other facility components or a planned modification to, or re-rating of, any existing equipment, machinery or other facility components set out in the list of electrical and physical parameters provided to the **legal owner** by the **ISO** in accordance with subsection 2(1).

**(3)** The modelling data and records described in subsection 2(2) must be submitted to the **ISO** in writing, in the forms provided by the **ISO**, no later than thirty (30) **days** prior to the proposed date of energization of new equipment, machinery or other facility components or the modification of existing equipment, machinery or other facility components, or thirty (30) **days** prior to the application of new ratings to existing equipment, machinery or other facility components, unless otherwise specified by the **ISO**.

**(4)** The **ISO** may notify the **legal owner**, in writing, of any deficiencies the **ISO** identifies regarding the modelling data and records submitted pursuant to subsection 2(3).

**(5)** A **legal owner** that receives a written notice under subsection 2(4) must respond to the **ISO**, in writing, and, where necessary, resubmit the modelling data and records provided under subsection 2(3) no later than thirty (30) **days** after receipt of the written notice, ~~unless otherwise approved by the ISO.~~

##### Submission of Data Related to an Urgent and Unplanned Modification to, or Re-rating of, an Existing Facility

**3(1)** Where a **legal owner** specified in subsection 1 makes a modification to, or re-rating of, any existing equipment, machinery or other facility components set out in the list of electrical and physical parameters provided to the **legal owner** by the **ISO** in accordance with subsection 2(1) on an urgent and unplanned basis, including an unplanned transmission facility limit change described in Section 304.6 of the **ISO rules**, *Unplanned Transmission Facility Limit Changes*, and such modification or re-rating precludes the **legal owner** from complying with the submission timing requirements of subsection 2(3), then the **legal**

# ISO Rules

## Part 500 Facilities

### Division 502 Technical Requirements

#### Section 502.15 Reporting Facility Modelling Data



**owner** must, within three (3) **business days** after making the modification or re-rating, or within a shorter period of time as deemed necessary by the **ISO** in its sole discretion, submit the following information to the **ISO** in writing:

- (a) a description of the modification or re-rating made to each piece of equipment, machinery or other facility component;
- (b) the reason for the modification or re-rating;
- (c) the period of time the modification or re-rating will be in effect; and
- (d) the modelling data and records related to the modification or re-rating.

**(2)** The **legal owner** must, if it does not have the specific modelling data and records available to meet the three (3) **business days** requirement in subsection 3(1)(d), notify the **ISO** in writing within three (3) **business days** after making the modification or re-rating, and submit these records to the **ISO**, in writing, as they become available.

**(3)** Notwithstanding subsection 3(1), the **legal owner** is not required to submit modelling data and records for a mobile transformer if:

- (a) the **legal owner** is setting up a mobile transformer to address an urgent or unplanned situation; and
- (b) the mobile transformer is energized for less than fifteen (15) **days**.

#### Reporting of Errors by the Legal Owner

**4(1)** If a **legal owner** identified in subsection 1 identifies an error in any modelling data and records maintained by the **ISO** of the type described in subsection 2(2), the **legal owner** must provide the **ISO** with written notice of the error and corrections to the modelling data and records no later than thirty (30) **days** after the date the **legal owner** identifies the error, ~~unless otherwise approved by the ISO.~~

**(2)** The **ISO** must review a written notice submitted pursuant to subsection 4(1) and may notify the **legal owner** in writing of any additional information the **ISO** requires to correct the error.

**(3)** A **legal owner** must respond to a written notice received from the **ISO** under subsection 4(2) and submit to the **ISO**:

- (a) any additional requested information, or
- (b) a description of the reasons for which the **legal owner** cannot provide the additional requested information,

no later than thirty (30) **days** after receipt of the written notice, ~~unless otherwise approved by the ISO.~~

#### Reporting of Suspected Errors by the ISO

**5(1)** If the **ISO** identifies a suspected error within any modelling data and records maintained by the **ISO** of the type described in subsection 2(2), the **ISO** may provide the applicable **legal owner** with written notice of the suspected error, which notice must include a description of the reasons for which the **ISO** suspects an error.

**(2)** The **legal owner** must review the written notice received pursuant to subsection 5(1) and provide a written response to the **ISO** no later than thirty (30) **days** after the receipt of the written notice, ~~unless otherwise approved by the by the ISO,~~ which either:

# ISO Rules

## Part 500 Facilities

### Division 502 Technical Requirements

#### Section 502.15 Reporting Facility Modelling Data



- (a) confirms the error and provides the necessary corrections to the modelling data and records; or
- (b) provides a sufficient explanation of the reasons for which the **ISO's** determination of the suspected error was inaccurate or incorrect.

**(3)** If the **ISO** is not satisfied with a response provided by a **legal owner** pursuant to subsection 5(2) or 5(4), it may notify the **legal owner** in writing, which notice must specify the reasons for which the **ISO** is not satisfied with the response.

**(4)** A **legal owner** must, if it receives a notice from the **ISO** under subsection 5(3), submit an updated response no later than thirty (30) **days** after receipt of the notice, ~~unless otherwise approved by the ISO.~~

#### Provision of Modelling Data and Records by a Legal Owner

**6(1)** The **ISO** may make a written request of a **legal owner** identified in subsection 1 for modelling data and records.

**(2)** Notwithstanding subsections 2(1) and (2), the **ISO** may make a request under subsection 6(1) for modelling data and records that are not included on the **ISO's** list of electrical and physical parameters.

**(3)** A **legal owner** must respond to a request received from the **ISO** under subsection 6(1) and submit to the **ISO** in writing:

- (a) the requested modelling data and records, or
- (b) a description of the reasons for which the **legal owner** cannot provide the requested modelling data and records,

no later than thirty (30) **days** after receipt of the request, ~~unless otherwise approved by the ISO.~~

#### Waiver of Requirements

~~**7** The **ISO** may waive any requirements of subsections 2 and 3 of this section 502.15, by providing written notice to a **legal owner** identified in subsection 1, if the **ISO** determines that the modelling data and records the **legal owner** is required to provide are not necessary and their absence will not significantly impact the **ISO's** transmission system model.~~

#### Revision to the List of Electrical and Physical Parameters

**87** The **ISO** must, to amend the list of electrical and physical parameters posted to the AESO website in accordance with subsection 2(1):

- (a) notify and seek comments from the Transmission Data Committee, or its successor, regarding the amendments to the list of electrical and physical parameters;
- (b) notify **market participants** no less than thirty (30) **days** in advance of the amended list of electrical and physical parameters coming into effect; and
- (c) post the amended list of electrical and physical parameters to the AESO website on the effective date.

ISO Rules  
Part 500 Facilities  
Division 502 Technical Requirements  
Section 502.15 Reporting Facility Modelling Data



Revision History

Date	Description
<a href="#">2019-xx-xx</a>	<a href="#">Removed duplication with new Section 103.14, Waivers and Variances; standardized functional specifications language; capitalized references to "Section".</a>
2016-07-26	Initial release