

Date of Request for Comment: <u>November 25, 2016</u> Period of Comment: <u>November 25, 2016</u> through <u>January 6, 2017</u> Comments From: <u>Suncor Energy Inc.</u> Date [yyyy/mm/dd]: <u>2017/01/05</u>	Contact: <u>Georgina Newell</u> Phone: <u>+1 (403) 296-7701</u> Email: <u>gnewell@suncor.com</u>
---	--

Please place your comments/reasons for position (if any), in response to the questions set out below, in the following matrix.

Questions	Stakeholder Comments and/or Alternate Proposal
<p>The AESO is seeking comments from stakedholders with regard to the following matters:</p> <ol style="list-style-type: none"> 1. Do you agree or disagree that proposals 1 through 13 presented in the Section 502.11 Discussion Paper represent the minimum technical requirements for substations? If you disagree, please provide comments. 2. Are any of the proposals in the Section 502.11 Discussion Paper unclear? If yes, please indicate the proposal number and describe how the clarity of the proposal could be improved. 	<p><i>Comment # 1:</i></p> <p>Suncor is seeking clarity and applicability of proposal #3 that requires:</p> <ul style="list-style-type: none"> (a) -50°C grade equipment - availability of equipment rated at -50°C might be an issue (c) Equipment withsatand capability of up to 15°C per hour - is it too conservative?