External Consultation Final Draft April 7, 2017

Applicability

- 1 Section 304.9 applies to:
 - (a) the legal owner of a wind or solar aggregated generating facility connected to the interconnected electric system or an electric system within the service area of the City of Medicine Hat, including a wind or solar aggregated generating facility situated within an industrial complex that is directly connected to the interconnected electric system or to an electric system within the service area of the City of Medicine Hat and that has a gross real power capability equal to or greater than 5 MW; and
 - (b) the ISO.

Requirements

Functional Specification

- **2(1)** The **ISO** may issue a written functional specification containing details, work requirements and specifications for the design, construction and operation of an **aggregated generating facility** and associated **transmission facility** connection facilities.
- (2) The functional specification referred to in subsection 2(1) must be generally consistent with the provisions of this section 304.9, but may contain material variances approved of by the **ISO** based upon its discrete analysis of any one or more of the technical, economic, safety, operational and **reliability** requirements of the **interconnected electric system** related to the specific facility project.

Successor to Prior Requirements and Compliance Timeframe

- **3(1)** The provisions of this section 304.9 succeed all previous forecasting requirements for **aggregated generating facilities**, whether in an **ISO rule** or other document, and those requirements will no longer be in force and effect as of **[effective date of the rule]**.
- (2) The legal owner of an aggregated generating facility connected in accordance with any previous forecasting requirements must bring its aggregated generating facility into compliance with this section 304.9 by no later than twelve (12) months after [effective date the rule] unless otherwise agreed to in writing by the ISO, and until such time as the aggregated generating facility is brought into compliance with this section 304.9, the legal owner of the aggregated generating facility shall operate its aggregated generating facility in compliance with the previously effective forecasting requirements in accordance with which it was being operated prior to [effective date of the rule].

Meteorological Data Collection Equipment and Availability Requirements

- **4(1)** The **legal owner** of a wind or solar **aggregated generating facility** must ensure that the facility is equipped with <u>meteorological</u> data collection equipment and related devices that are installed and maintained in accordance with the provisions of subsections 4 and 5.
- (2) The legal owner of a wind aggregated generating facility must ensure that it is equipped with two (2) sets of instruments for each meteorological data collection equipment and related devices parameter in accordance with the following: requirements in Table 1.
 - (a) a first device that takes measurements at the wind turbine generator hub height; and
 - (b) a second device that takes measurements at a height of 35 meters.

- (3) The legal owner of a solar aggregated generating facility must ensure that the facility is equipped with meteorological data collection equipment and related devices in accordance with the following:
 - (a) one (1) set of <u>instruments for each</u> meteorological <u>data collection equipment and related</u> devices per 100 parameter in accordance with the requirements in Table 1 per 49 square kilometers of surface area within the facility;
 - (b) the meteorological data collection equipment and related devices each set of instruments, if required by subsection 4(3)(a), must not be less than 8 kilometers and not greater than 10 kilometers apart; and
 - (c) measurements must be taken at not less than 2 meters and not greater than 10 meters above ground.
- (4) The **legal owner** of a wind or solar **aggregated generating facility** must ensure that the meteorological data collection equipment and related devices described in subsections 4(2) and 4(3) take measurements of instantaneous values at interval of 15 **seconds** or less.
- (5) The legal owner of a wind or solar aggregated generating facility must measure, collect and submit to the ISO the meteorological data in Table 1.
- (6) The legal owner of a wind or solar aggregated generating facility must determine, at 30 minute intervals, and submit to the ISO, the gross real power capability with a precision to the nearest 2.0 MW.
- (7) The **legal owner** of a wind or solar **aggregated generating facility** must determine and submit to the **ISO**, the following data:
 - (a) any real power limits in megawatts (MW), with a precision for instantaneous measurements to the nearest 0.1 MW; and
 - (b) actual net to grid real power production in megawatts (MW), with a precision for instantaneous measurements to the nearest 0.1 MW.

Data Transfer Technical Specification

- **5(1)** The **legal owner** of a wind or solar **aggregated generating facility** must submit to the **ISO** the data specified in subsection 4(5) using one **minute** average data.
- (2) The legal owner of a wind or solar aggregated generating facility must submit to the ISO the data specified in subsection 4 in the method and format the ISO specifies.
- (3) The legal owner of a wind or solar aggregated generating facility must ensure that its meteorological data collection equipment and related devices including its data transfer equipment is designed and maintained with an availability of 98.0% for the ranges specified in accordance with Table 1 and a mean time to repair of forty-eight (48) hours or less.
- (4) The **legal owner** of a wind or solar **aggregated generating facilities** must keep seven (7) **days** of back up data for any data that has been submitted in accordance with this subsection 5 and must provide it to the **ISO** upon request within thirty (30) **days**.

Notification of Unavailability, Suspected Failure or Data Error

6(1) The **legal owner** of a wind or solar **aggregated generating facility** must, if any component in the meteorological data collection equipment and related devices including data transfer equipment becomes unavailable due to an unplanned event, is suspected to have failed, or to be providing

erroneous data, notify the **ISO** as soon as practicable, in writing, after identifying the unavailability, suspected failure or data error.

- (2) The **legal owner** of a wind or solar **aggregated generating facility** must provide the **ISO** as soon as practicable, in writing:
 - (a) a description of the cause of any unavailability, suspected failure or data error reported pursuant to subsection 6(1);
 - (b) in the event of an equipment failure, a plan acceptable to the **ISO** to repair the failed equipment, including testing; and
 - (c) in the event of an equipment failure, the expected date when the equipment will be repaired and the required measurements will be restored.
- (3) The **legal owner** of a wind or solar **aggregated generating facility** must, if an equipment failure described in subsection 6(2) is not repaired and required measurements are not restored by the expected date, notify the **ISO** as soon as practicable, in writing, of the revised date and the reason the component in the equipment was not repaired by the expected date.
- (4) The **legal owner** of a wind or solar **aggregated generating facility** must notify the **ISO** as soon as practicable in writing after an equipment failure described in subsection 6(2) is repaired and the required measurements are restored.

Exceptions

- 7 Notwithstanding subsections 4 and 5, the **legal owner** of a wind or solar **aggregated generating facility** is not required to comply with the requirements of this section 304.9 relating to meteorological data collection equipment and related devices including data transfer equipment when:
 - (a) such equipment is being repaired or replaced in accordance with a plan acceptable to the ISO under subsection 6; and
 - (b) the **legal owner** is using reasonable efforts to complete such repair or replacement in accordance with that plan.

Pre-Commissioning Facility Data and Records Requirements

- **8(1)** The **legal owner** of a wind or solar aggregated generating facility must provide to the **ISO** the pre-commissioning data and records referred to in this subsection 8 in a method and format the **ISO** specifies.
- (2) The legal owner of a solar aggregated generating facility must provide to the ISO, in a method and format the ISO specifies, either:
 - (a) the pre-commissioning data and records referred to in this subsection 8; or
 - (b) an industry standard model that is approved by the ISO.
- (23) Subject to the provisions of this subsection 8, the **legal owner** of a wind or solar **aggregated generating facility** must retain and provide within sixty (60) **days** of the **ISO**'s written request the following averaged meteorological data and records at ten (10) minute intervals or less, covering the two (2) calendar years prior to the **commissioning** of the wind or solar **aggregated generating facility**:
 - (a) details on the height of the measurements;
 - (b) wind speed;

- (c) wind direction;
- (d) temperature;
- (e) barometric pressure; and
- (f) for solar aggregated generating facilities only, global horizontal irradiance.

(34) The legal owner of a wind aggregated generating facility must, in response to a request by the ISO under subsection 8(23), provide the following facility data:

- (a) meteorological tower data collection height in meters (m), with a precision for instantaneous measurements to the nearest 1 m;
- (b) turbine model name;
- (c) turbine model capacity in megawatts (MW), with a precision to the nearest 0.1 MW;
- (d) turbine wind speed cut-in in meters per second (m/s), with a precision to the nearest 0.1 m/s;
- (e) turbine wind speed cut-out in meters per second (m/s), with a precision to the nearest 0.1 m/s;
- (f) turbine temperature cut-out lower in degrees Celsius (°C), with a precision for instantaneous measurements to the nearest 1 °C and an indicator is required to confirm that the numbers are ambient temperature within the rotor or air temperature;
- (g) turbine temperature cut-out upper in degrees Celsius (°C), with a precision for instantaneous measurements to the nearest 1 °C and an indicator is required to confirm that the numbers are ambient temperature within the rotor or air temperature;
- (h) site latitude and longitude in degrees; and
- (i) turbine power curves.

(45) The legal owner of a solar aggregated generating facility must in response to a request by the ISO under subsection 8(23), provide the following solar array data and records, including:

- (a) site latitude and longitude in degrees;
- (b) direct current (DC) real power rating;
- (c) alternating current (AC) real power rating;
- (d) inverter manufacturer and model;
- (e) mounting height from ground in meters (m);
- (f) tilt angle or range of tilt angles to horizontal plane in degrees;
- (g) azimuth angle in degrees;
- (h) alternating current (AC) real power capacity per solar array in megawatts (MW);
- (i) mounting type, tracking (fixed, single or dual axis); and
- (j) module type (crystalline, thin-film etc.).

Revision History

Date	Description
xxxx-xx-xx	Initial release.

Table 1
Wind and Solar Aggregated Generating Facility Meteorological Data Requirements

Wind Aggregated Generating Facility Meteorological Data Requirements								
Measurement Type	Units	Precision	Range	Accuracy	Required for Aggregated Generating FacilityHeight of Instrument			
					WindSet-1	SolarSet-2		
Wind Speed	Meters/Second (m/s)	0.1 m/s	0 to 50	±1m/s	Required <u>At Hub</u> <u>Height</u>	RequiredAt 35 Meters		
Wind Direction	Degrees from True North	1 degree	0 to 360	±5°	RequiredAt Hub Height	RequiredAt 35 Meters		
Barometric Pressure	HectoPascals (HPa)	1 hPa	800 to 1000	±-1.0 hPa at -20 to 50°C; and ±1.5 hPa at below - -20°C	RequiredAt Convenient location	RequiredAt Convenient location		
Ambient Temperature	Degree Celsius (°C)	0.1° C	-50 to +50	±0.2°C	RequiredAt Hub Height	Required At 35 Meters		
Dewpoint	Degrees Celsius (°C)	0.1° C	-50 to +50	±0.2°C	RequiredAt Convenient location	RequiredAt Convenient location		
Relative Humidity	Percentage (%)	1.00%	0 to 100 %	±2%	Required <u>At</u> Convenient location	RequiredAt Convenient location		
Ice-up Parameter Measured with an Icing Sensor	Scale 0.0 to1.0	0.1	0 to 1	n/a	RequiredAt Convenient location	Not Applicable At Convenient location		
Precipitation	Millimeters/minute (mm/min)	0.1	0 to11	2% up to 0.417 mm/mon _3% over 0.417 mm/min	RequiredAt Convenient location	RequiredAt Convenient location		
Solar Aggregated Generating Facility Meteorological Data Requirements								
<u>Measurement</u>	<u>Units</u>	<u>Precision</u>	Range	Accuracy		Height of Instrument		
<u>Type</u>					Set-1 per 49 km ²	Set-2 for each subsequent 49 km ²		
Wind Speed	Meters/Second (m/s)	<u>0.1 m/s</u>	<u>0 to 50</u>	<u>±1m/s</u>	Between 2-10 meters	Between 2-10 meters		
Wind Direction	Degrees from True North	1 degree	0 to 360	<u>±5°</u>	Between 2-10 meters	Between 2-10 meters		

Pressure				•			
Ambient Degree Celsius 0.1° C -50 to ±0.2° C Between 2-10 meters meters	<u>Barometric</u>	<u>HectoPascals</u>	<u>1 hPa</u>		<u>±1.0 hPa</u>	Between 2-10	Between 2-10
Ambient Degree Celsius 0.1° C -50 to ±0.2° C Between 2-10 meters met	<u>Pressure</u>	<u>(HPa)</u>		<u>1000</u>	at -20 to	<u>meters</u>	<u>meters</u>
Ambient Degree Celsius O.1° C -50 to ±0.2° C Between 2-10 meters meters					50°C; and		
Ambient Degree Celsius (°C) ±50 ±0.2°C Between 2-10 meters					<u>±1.5 hPa</u>		
Ambient Degree Celsius (°C) ±50 ±0.2°C Between 2-10 meters					at below -		
Temperature					20°C		
Temperature	Ambient	Degree Celsius	0.1° C	-50 to	±0.2°C	Between 2-10	Between 2-10
Dewpoint	Temperature	(°C)	·	+50		meters	meters
Relative		Degrees Celsius	0.1° C	-50 to	±0.2°C		
Humidity Precipitation Millimeters/minute (mm/min) 0.1 0 to 11 2% up to 0.417 meters Between 2-10 meters meters							
Humidity	Relative	Percentage (%)	1.00%	<u>0 to</u>	<u>±2%</u>	Between 2-10	Between 2-10
Comm/min	<u>Humidity</u>			<u>100 %</u>		<u>meters</u>	<u>meters</u>
BackpanelBack Degree Celsius O.1° C C C Danel Temperature Temperature Diffused Horizontal Irradiance Horizontal Irradiance Diffused Horizontal Irradiance Diffused Horizontal Irradiance Diffused Neter (W/m²) Irradiance Diffused Neter (W/m²) Diffused Irradiance Watts/Square O.1 O to ±3% Net ApplicableBetween 2-10 meters 2-10 m	Precipitation	Millimeters/minute	<u>0.1</u>	<u>0 to11</u>	2% up to	Between 2-10	Between 2-10
BackpanelBack		(mm/min)			0.417	<u>meters</u>	<u>meters</u>
BackpanelBack panel (°C) BackpanelBack panel (°C) Temperature Color (°C) Degree Celsius (°C) Degree Celsius (°C) Color (°C) Degree Celsius (°C) Degree Celsius (°C) Color (°C) Degree Celsius (°C) Degree Celsiu					mm/mon		
BackpanelBack panel Temperature Color					3% over		
Degree Celsius (°C)					0.417		
Temperature (°C) +50 at -27 to +50°C; and ± 0.2°C at below -27 °C Global Horizontal Irradiance Diffused Horizontal Irradiance Direct Normal Irradiance Direct Norm					mm/min		
Temperature Color Color Color	BackpanelBack	Degree Celsius	0.1° C	-50 to	±-0.4 <u>15</u> °C	Not	Required Between
Temperature Color Color Color Color	panel	(°C)		+50	at	Applicable Between	<u>2-10 meters</u>
Global Watts/Square Horizontal Irradiance Direct Normal Irradiance Direct Normal Irradiance Sunshine Volts And ± 0.2°C at below -27 °C Applicable Between 2-10 meters Applicable Bet	Temperature	, ,			- <u>-</u> 27 to		
Global Watts/Square Horizontal Irradiance Diffused Horizontal Irradiance Direct Normal Irradiance Direct Normal Irradiance Sunshine Volts O.2°C at below -27 °C O.1 O to ±3% ApplicableBetween 2-10 meters PrequiredBetween 2-10 meters ApplicableBetween 2-10 meters	`				+50°C;		
Global Watts/Square Horizontal Irradiance Diffused Horizontal Irradiance Direct Normal Irradiance I Watts/Square Meter (W/m²) Direct Normal Irradiance Direct Normal Irradiance Sunshine Volts Discript Normal Sunshine Sequired Details and solution of the sequired Between and solution of the sequired Betwe					and ±		
Global Watts/Square Horizontal Irradiance Diffused Horizontal Irradiance Direct Normal Irradiance Irradiance Direct Normal Irradiance Sunshine Volts O.1 O to ±3% Applicable Between 2-10 meters O.1 O to ±3% Not Required Between 2-10 meters Applicable Between 2-10 meters	1				0.2°C at		
Global Watts/Square Horizontal Irradiance Diffused Horizontal Irradiance Direct Normal Irradiance Irradiance Direct Normal Irradiance Watts/Square Meter (W/m²) Watts/Square Direct Normal Irradiance Direct Normal Irradiance Meter (W/m²) Moter (W/m²) Direct Normal Irradiance Meter (W/m²) Watts/Square Meter (W/m²) Direct Normal Irradiance Meter (W/m²) Direct Normal Irradiance Meter (W/m²) Direct Normal Meter (W/m²) Direct Nor							
Horizontal Irradiance Diffused Horizontal Irradiance Diffused Horizontal Irradiance Direct Normal Irradiance Meter (W/m²) Direct Normal Irradiance Direct Normal Irradiance Meter (W/m²) Meter (W/m²) Direct Normal Irradiance Meter (W/m²) Direct Normal Irradiance Meter (W/m²) Direct Normal Meter (W/m²) Meter (W/m²) Not Applicable Required Required Required Required Required							
Horizontal Irradiance Diffused Horizontal Irradiance Diffused Horizontal Irradiance Direct Normal Irradiance Meter (W/m²) Direct Normal Irradiance Direct Normal Irradiance Meter (W/m²) Meter (W/m²) Meter (W/m²) Direct Normal Irradiance Meter (W/m²) Meter (W/m²) Meter (W/m²) Direct Normal Irradiance Meter (W/m²) Meter (W/m²) Meter (W/m²) Direct Normal Irradiance Meter (W/m²) Met	Global	Watts/Square	0.1	0 to		Not	RequiredBetween
Irradiance Diffused Watts/Square Diffused Horizontal Irradiance Direct Normal Irradiance Direct Normal Irradiance Meter (W/m²) Direct Normal Meter (W/m²	Horizontal					Applicable Between	
Diffused Horizontal Irradiance Direct Normal Irradiance Meter (W/m²) Universe Direct Normal Irradiance Meter (W/m²) Uni	Irradiance						
Horizontal Irradiance	! 	Watts/Square	0.1	0 to	±3%		Required Between
Irradiance Direct Normal Watts/Square Direct Normal Irradiance Meter (W/m²) Direct Normal O.1 O to ±3% Not RequiredBetween 2-10 meters 2-10 meters						Applicable Between	
Direct Normal Irradiance ¹ Watts/Square Meter (W/m²) 0.1 0 to 2000 2000 2000 2000 2000 2000 2000	Irradiance						
Irradiance ¹ Meter (W/m²) 2000 Applicable Between 2-10 meters 2-10 meters Sunshine Volts 0.1 0 to 1 90.00% Not Applicable Required		Watts/Square	0.1	0 to	±3%		RequiredBetween
Sunshine Volts 0.1 0 to 1 90.00% Not Applicable Required	Irradiance ¹		-	2000		Applicable Between	
Sunshine Volts 0.1 0 to 1 90.00% Not Applicable Required							
	Sunshine	Volts	0.1	0 to 1	90.00%		Required
	Duration						'

¹ The requirement to provide this parameter will be determined by the AESO based on solar technology used in the project.