

## **APPENDIX A   CONNECTION ASSESSMENT**


# *Fortis Hughenden 213S Upgrade*

## Project Number: 1642

The attached engineering study report has been prepared by a third party as part of the AESOs connection process. The AESO has reviewed the report and the conclusions that it contains, and finds it acceptable for the purpose of assessing potential impacts of the proposed connection on the transmission system.

Information regarding the AESO's connection process can be found at:  
<http://www.aeso.ca/8602.html>.

Date: February 11, 2016

| Function                                              | Name                            | Company                                   | Signature                                                                            | Date          |
|-------------------------------------------------------|---------------------------------|-------------------------------------------|--------------------------------------------------------------------------------------|---------------|
| Senior Engineer                                       | Bipul Karki,<br>Ph. D., P. Eng. | Alberta<br>Electric<br>System<br>Operator |  | Feb 11, 2016  |
| Manager,<br>Projects &<br>System<br>Access<br>Studies | Mohamed Kamh,<br>Ph.D., P. Eng. | Alberta<br>Electric<br>System<br>Operator |  | Feb. 11, 2016 |

Public



# Engineering Study Report

## Fortis Hughenden Upgrade

**AESO Project Number: P1642**

Revision: 3

Revision Date: February 5, 2016

|                               | Name                              | Date          | Signature |
|-------------------------------|-----------------------------------|---------------|-----------|
| Prepared                      | Fatima Belmoufid, EIT. (AltaLink) | Feb 08, 2016  |           |
| Reviewed                      | Carl Wang, P. Eng. (AltaLink)     | Feb. 08, 2016 |           |
| Joby Varghese For<br>Approved | Ryan Cui, P. Eng. (AltaLink)      | Feb 08, 2016  |           |



**AltaLink APEGGA Permit Number P-7862**

**(Page intentionally blank)**

# Executive Summary

## Project Overview

FortisAlberta Inc. (FortisAlberta), the market participant, has applied to the Alberta Electric System Operator (AESO) requesting a 2.8MW load increase at the existing Hughenden 213S substation. The Hughenden 213S substation is located in Provost area (AESO Planning area 37) at 04-03-41-07-W4M.

AESO project 1642, hereafter the Project, seeks to address FortisAlberta's need. The requested in-service date (ISD) for the Project is December 1, 2016.

## Existing System

The Provost area is located in the Central East region of Alberta and consists primarily of 138 kV and 240 kV transmission systems. The primary source of supply in the area is the coal-fired plant at Battle River. The area is connected to the neighbouring planning areas of Battle River (AESO Planning area 36), Lloydminster (AESO Planning area 13), Hanna (AESO Planning area 42) and Wainwright (AESO Planning area 32).

## Connection Alternatives Considered for the Project

Two (2) connection alternatives were proposed for the Project:

- Alternative 1: Addition of one (1) new 138/25kV 25/33/42MVA LTC Transformer with the existing T-tap connection to 138 kV transmission line 703L;
- Alternative 2: Addition of one (1) new 138/25kV 25/33/42MVA LTC Transformer with in-and-out connection to 138 kV transmission line 703L.

FortisAlberta confirmed that of these two alternatives, only Alternative 2 meets their reliability criteria<sup>1</sup>. Thus, this report presents the results of the detailed studies for Alternative 2.

## Study Summary

This Engineering Study Report (ESR) presents the system performance studies undertaken to assess the impact of the Project on the performance of the Alberta Interconnected Electric System (AIES).

The Wainwright area, Battle River area, Lloydminster area, and Provost area were collectively considered as the Study Area. 2016 winter peak (2016 WP) and 2017 summer peak (2017 SP) scenarios were considered in the studies. Power flow and voltage stability analysis were performed for Category A and B contingencies. Short-circuit analysis was performed to calculate the short circuit levels for the major substations in the Study Area.

Study results show that there are one existing thermal loading above transmission line emergency rating and one voltage collapse under loss of Metiskow 648S Transformer T1. AESO has previously identified these violations through other projects and specified the solutions with the regional long term plan. Alternative 2 does not adversely impact the AIES and

---

<sup>1</sup> As per Section 4.2.1 of Fortis's Distribution Deficiency Report dated October 7, 2015

does not significantly alter the short circuit levels in the area. Voltage stability analysis confirms that voltage stability margins continue to satisfy the voltage stability criteria.

The power flow study results indicate the following:

A- Pre-connection scenarios:

1- 2016 WP

- Category A (N-0)
  - No voltage violations or transmission thermal violations were observed.
- Category B (Single Element Outage (N-1))
  - The contingency of the Metiskow 648S 138/25kV transformer T1, which trips the Metiskow 648S 138kV bus and all three 138kV lines connected to the bus, will cause voltage collapse. This violation is known to the AESO and is managed using real time operational practices.
  - A thermal violation was observed on the 138 kV transmission line 7L130 (Kitscoty 705S to Vermilion 710S) following the N-1 contingency of the 138 kV transmission line 749L (Metiskow 648S to Edgerton 899S). 749L contingency leaves 7L130 to radially feed the area load which causes thermal violation on this line.. This violation is known to the AESO and is managed using real time operational practices.

2- 2017 SP

- Category A(N-0)
  - No voltage violations or transmission thermal violations were observed.
- Category B (Single Element Outage (N-1))
  - The contingency of the Metiskow 648S 138/25kV transformer T1, which trips the Metiskow 648S 138kV bus and all three 138kV lines connected to the bus, will cause voltage collapse. This violation is known to the AESO and is managed using real time operational practices.

B- Post-connection scenarios:

3- 2016 WP

- Category A(N-0)
  - No voltage violations or transmission thermal violations were observed.
- Category B (Single Element Outage (N-1))
  - Similar to the pre-connection scenario, the contingency of the Metiskow 648S 138/25kV transformer T1, which trips the Metiskow

648S 138kV bus and all three 138kV lines connected to the bus, will cause voltage collapse in 2016WP Post-connection as well.

- Thermal overloading was observed on the 138 kV transmission line 7L130 (Kitscoty 705S to Vermilion 750S) under the N-1 contingency of the 138 kV transmission line 749L (Metiskow 648S to Edgerton 899S). The 749L contingency leaves 7L130 to radially feed the area load which causes thermal violation on this line. This violation is known to the AESO and is managed using real time operational practices.

#### 4- 2017 SP

- Category A(N-0)
  - No voltage violations or transmission thermal violations were observed
- Category B ( Single Element Outage (N-1))
  - Similar to the pre-connection scenario, the contingency of the Metiskow 648S 138/25kV transformer T1, which trips the Metiskow 648S 138kV bus and all three 138kV lines connected to the bus, will cause voltage collapse in 2017 SP Post-connection. This violation is known to the AESO and is managed using real time operational practices.

## Conclusions and Recommendation

The connection assessment performed for upgrade of Hughenden 213S indicates that the proposed connection will not adversely impact the performance of the AIES. It is recommended to connect the Project through Alternative 2.

# Contents

|                                                                                                                                                     |           |
|-----------------------------------------------------------------------------------------------------------------------------------------------------|-----------|
| <b>Executive Summary .....</b>                                                                                                                      | <b>3</b>  |
| <b>1. Introduction .....</b>                                                                                                                        | <b>5</b>  |
| 1.1. Project .....                                                                                                                                  | 5         |
| 1.1.1. Project Overview .....                                                                                                                       | 5         |
| 1.1.2. Load Component .....                                                                                                                         | 5         |
| 1.1.3. Generation Component .....                                                                                                                   | 5         |
| 1.2. Study Scope .....                                                                                                                              | 5         |
| 1.2.1. Study Objectives.....                                                                                                                        | 5         |
| 1.2.2. Study Area.....                                                                                                                              | 5         |
| 1.2.3. Studies Performed.....                                                                                                                       | 6         |
| 1.2.4. Report Overview.....                                                                                                                         | 7         |
| <b>2. Criteria, System Data, and Study Assumptions .....</b>                                                                                        | <b>8</b>  |
| 2.1. Criteria, Standards, and Requirements .....                                                                                                    | 8         |
| 2.1.1. AESO Transmission Reliability Criteria .....                                                                                                 | 8         |
| 2.1.2. AESO Information Document (ID) and Authoritative Documents (ADs) .....                                                                       | 9         |
| 2.1.3. Voltage Stability Criteria .....                                                                                                             | 9         |
| 2.2. Load and Generation Assumptions .....                                                                                                          | 9         |
| 2.2.1. Load Assumptions .....                                                                                                                       | 9         |
| 2.2.2. Generation and Inter-Tie Assumptions .....                                                                                                   | 10        |
| 2.2.3. HVDC Assumptions.....                                                                                                                        | 10        |
| 2.3. System Projects .....                                                                                                                          | 10        |
| 2.4. Customer Connection Projects.....                                                                                                              | 11        |
| 2.5. Facility Ratings and Shunt Elements.....                                                                                                       | 12        |
| 2.6. Voltage Profile Assumptions .....                                                                                                              | 14        |
| <b>3. Study Methodology.....</b>                                                                                                                    | <b>15</b> |
| 3.1. Study Objectives .....                                                                                                                         | 15        |
| 3.2. Study Scenarios .....                                                                                                                          | 15        |
| 3.3. Connection Studies Carried Out.....                                                                                                            | 16        |
| 3.4. Power Flow Analysis .....                                                                                                                      | 16        |
| 3.4.1. Contingencies Studied.....                                                                                                                   | 16        |
| 3.5. Voltage Stability (PV) Analysis .....                                                                                                          | 18        |
| 3.5.1. Contingencies Studied.....                                                                                                                   | 18        |
| 3.6. Short-Circuit Analysis .....                                                                                                                   | 19        |
| <b>4. Pre-Connection System Assessment .....</b>                                                                                                    | <b>20</b> |
| 4.1. Pre-Connection Power Flow Analysis .....                                                                                                       | 20        |
| 4.1.1. Scenario #1 – 2017 SP (Pre-connection) .....                                                                                                 | 20        |
| 4.1.2. Scenario #2 – 2016 WP (Pre-connection) .....                                                                                                 | 20        |
| <b>5. Connection Alternatives.....</b>                                                                                                              | <b>22</b> |
| 5.1. Overview .....                                                                                                                                 | 22        |
| 5.2. Connection Alternatives Evaluated .....                                                                                                        | 24        |
| 5.2.1. Connection Alternatives Selected for Further Studies .....                                                                                   | 24        |
| 5.2.2. Connection Alternatives Not Selected for Further Studies .....                                                                               | 24        |
| <b>6. Technical Analysis of the Connection Alternatives.....</b>                                                                                    | <b>25</b> |
| 6.1. Alternative 2 – Addition of one (1) new 138/25kV 25/33/42MVA LTC transformer with In-and-out connection to 138 kV transmission line 703L ..... | 25        |
| 6.1.1. Power Flow Analysis .....                                                                                                                    | 25        |
| 6.1.2. Voltage Stability Analysis (Alternative 2) .....                                                                                             | 27        |
| 6.2. Conclusions.....                                                                                                                               | 27        |

|                                                                                                                                                          |           |
|----------------------------------------------------------------------------------------------------------------------------------------------------------|-----------|
| <b>7. Short-Circuit Analysis .....</b>                                                                                                                   | <b>28</b> |
| 7.1. Pre-Connection .....                                                                                                                                | 28        |
| 7.2. Post-Connection.....                                                                                                                                | 28        |
| 7.2.1. Alternative 2: Addition of one (1) new 138/25kV 25/33/42MVA LTC transformer with In-and-out connection to the 138 kV transmission line 703L ..... | 29        |
| <b>8. Project Interdependencies .....</b>                                                                                                                | <b>30</b> |
| <b>9. Summary and Recommendations .....</b>                                                                                                              | <b>31</b> |

## Attachments

|              |                                                                                 |
|--------------|---------------------------------------------------------------------------------|
| Attachment A | Pre-Connection Power Flow Analysis Results (Scenarios 1 and 2)                  |
| Attachment B | Post-Connection Power Flow Analysis Results (Scenarios 3 and 4) - Alternative 2 |
| Attachment C | Post-Connection Voltage Stability Analysis Results (Scenario 4) - Alternative 2 |

## Figures

|                                                                                                                                              |    |
|----------------------------------------------------------------------------------------------------------------------------------------------|----|
| Figure 1: Pre-connection Area Transmission System in 2016 .....                                                                              | 6  |
| Figure 2: Provost Area (Existing) .....                                                                                                      | 22 |
| Figure 3: Alternative 2 – 138/25 kV 25/33/42 MVA LTC Transformer addition with In-and-out connection to 138 kV transmissions line 703L ..... | 23 |

## Tables

|                                                                                          |    |
|------------------------------------------------------------------------------------------|----|
| Table 2.1-1: Post Contingency Voltage Deviation Guidelines.....                          | 9  |
| Table 2-2: 2014LTO Region Forecast Load.....                                             | 9  |
| Table 2-3: Local Generators in the Study Scenarios .....                                 | 10 |
| Table 2-4: Summary of System Project CETD in the Study Cases .....                       | 10 |
| Table 2-5: Summary of relevant facility assumptions for connection studies .....         | 11 |
| Table 2-6: Summary of Key Transmission Line Ratings .....                                | 12 |
| Table 2-7: Summary of Key Transformer Ratings.....                                       | 13 |
| Table 2-8: Summary of Shunt Elements in the Study Area.....                              | 13 |
| Table 2-9: Summary of Voltage at Key Nodes in the Study Area .....                       | 15 |
| Table 3-1: Study Scenarios .....                                                         | 15 |
| Table 3-2: List of Special Category B Contingencies.....                                 | 16 |
| Table 4-1: Summary of System Performance – 2017 SP Pre-connection.....                   | 20 |
| Table 4-2: Summary of System Performance – Thermal Loading, 2016 WP Pre-connection.....  | 21 |
| Table 4-3: Summary of Voltage Violation and Deviation– 2016 WP Pre-connection .....      | 21 |
| Table 6-1: Summary of System Performance – 2017 SP Post-connection .....                 | 25 |
| Table 6-2: Summary of System Performance – Thermal Loading 2016 WP Post-connection ..... | 26 |
| Table 6-3: Summary of Voltage Violation and Deviation 2016 WP Post-connection .....      | 26 |
| Table 6-4: Summary of Voltage Stability Analysis .....                                   | 27 |
| Table 7-1: Summary of Short-Circuit Current Levels – Pre-Connection (2016 WP).....       | 28 |
| Table 7-2: Summary of Short-Circuit Current Levels – Post-Connection (2016 WP) .....     | 29 |
| Table 7-3: Summary of Short-Circuit Current Levels – Post-Connection (2025 WP) .....     | 29 |

# **1. Introduction**

This Customer Connection Engineering Study Report presents the results of the study conducted to analyze the impact of the Project on the AIES.

## **1.1. Project**

### **1.1.1. Project Overview**

FortisAlberta has submitted System Access Service Request (SASR) to the AESO requesting a 2.8MW DTS increase at the existing Hughenden 213S substation. The Hughenden 213S substation is located in Provost area (AESO Planning area 37) at 04-03-41-07-W4M.

### **1.1.2. Load Component**

- Existing DTS at Hughenden 213S substation: 16.1 MW.
- Power factor: 0.9 lagging
- Type of load: Residential, industrial, and commercial loads
- Requested DTS increase: 2.8MW
- FortisAlberta does not anticipate further upgrades at the Hughenden 213S substation for the next 10 years.

### **1.1.3. Generation Component**

There is no generation component related to this project.

## **1.2. Study Scope**

### **1.2.1. Study Objectives**

The objectives of the study were the following:

- To assess the performance of the system following the connection of the Project to the AIES
- To identify any pre- and post- connection system constraints and recommend mitigation measures to facilitate the Project connection, if required.


### **1.2.2. Study Area**

#### **1.2.2.1. Study Area Description**

The Provost area is located in the Central East sub-region of Alberta and consists primarily of 138 kV and 240 kV transmission systems. The primary source of supply in the area is the coal-fired plant at Battle River. The pre-connection area transmission system in 2016 is shown in Figure 1.

In this study, the Study Area consists of Wainwright (AESO Planning Area 32), Alliance (AESO Planning Area 36), Lloydminster (AESO Planning Area 13), Hanna (AESO Planning Area 42), and Provost (AESO Planning Area 37).

**Figure 1: Pre-connection Area Transmission System in 2016**



### 1.2.2.2. Existing Constraints

The existing constraints in the Central East sub-region are managed in accordance with Section 302.1 of the ISO rules, Real Time Transmission Constraint Management (TCM Rule).

### 1.2.3. Studies Performed

2016/2017 winter peak (2016 WP) and 2017 summer peak (2017 SP) scenarios were used to assess the impact of the Project for near term assessment. In addition, 2025 winter peak (2025 WP) scenario was used to evaluate the long-term short circuit level impact following the proposed developments.

Power flow, voltage stability, and short-circuit studies were performed for pre- and post-connection on the selected scenarios under N-0 (Category A) and N-1 (Category B) contingencies. Table 3-1 summarizes the study scenarios used for the connection studies.

#### **1.2.4. Report Overview**

The Executive Summary provides a high-level summary of the report and its conclusions. Section 1 provides an introduction of the Connection Project. Section 2 describes the Reliability Criteria, system data, and other study assumptions used in this study. Section 3 presents the study methodology used in this study. Section 4 discusses the pre-connection system assessment. Section 5 presents the connection alternative identified. Section 6 provides a technical analysis of the post-connection system assessment for the alternative selected for further study. Section 7 provides a short-circuit analysis for the pre- and post-connection. Section 8 discusses the connection project dependencies. Section 9 presents the summary and recommendations of this study.

## 2. Criteria, System Data, and Study Assumptions

### 2.1. Criteria, Standards, and Requirements

#### 2.1.1. AESO Transmission Reliability Criteria

The Transmission Planning (TPL) Standards, which are included in the Alberta Reliability Standards, and the AESO's *Transmission Planning Criteria – Basis and Assumptions* (Reliability Criteria)<sup>2</sup> were applied to evaluate system performance under Category A system conditions (i.e., all elements in-service) and following Category B contingencies (i.e., single element outage), prior to and following the studied alternatives. Below is a summary of Category A and Category B system conditions.

**Category A**, often referred to as the N-0 condition, represents a normal system with no contingencies and all facilities in service. Under this condition, the system must be able to supply all firm load and firm transfers to other areas. All equipment must operate within its applicable rating, voltages must be within their applicable range, and the system must be stable with no cascading outages.

**Category B** events, often referred to as an N-1 or N-G-1 with the most critical generator out of service, result in the loss of any single specified system element under specified fault conditions with normal clearing. These elements are a generator, a transmission circuit, a transformer, or a single pole of a DC transmission line. The acceptable impact on the system is the same as Category A. Planned or controlled interruptions of electric supply to radial customers or some local network customers, connected to or supplied by the faulted element or by the affected area, may occur in certain areas without impacting the overall reliability of the interconnected transmission systems. To prepare for the next contingency, system adjustments are permitted, including curtailments of contracted firm (non-recallable reserved) transmission service electric power transfers.

The Alberta Reliability Standards include the Transmission Planning (TPL) standards that specify the desired system performance under different contingency categories with respect to the Applicable Ratings. The transmission system performance under various system conditions is defined in Appendix 1 of the TPL standards. For the purpose of applying the TPL standards to this study, the Applicable Ratings shall mean:

- Seasonal continuous thermal rating of the line's loading limits.
- Highest specified loading limits for transformers.
- For Category A conditions: Voltage range under normal operating condition should follow the AESO Information Document ID# 2010-007RS. For the busses not listed in ID#2010-007RS, Table 2-1 in the Reliability Criteria applies.
- For Category B conditions: The extreme voltage range values per Table 2-1 in the Reliability Criteria.
- Desired post-contingency voltage change limits for three defined post event timeframes as provided in Table 2.1-1.

---

<sup>2</sup> Filed under a separate cover.

Table 2.1-1: Post Contingency Voltage Deviation Guidelines

| Parameter and reference point                                  | Time Period                      |                                        |                                          |
|----------------------------------------------------------------|----------------------------------|----------------------------------------|------------------------------------------|
|                                                                | Post Transient<br>(up to 30 sec) | Post Auto Control<br>(30 sec to 5 min) | Post Manual<br>Control (Steady<br>State) |
| Voltage deviation from steady state at<br>POD low voltage bus. | ±10%                             | ±7%                                    | ±5%                                      |

### 2.1.2. AESO Information Document (ID) and Authoritative Documents (ADs)

ISO Rules Section 304.4, *Maintaining Network Voltage*, and information document ID #2010-007RS, General Operating Practice – Voltage Control, were applied to establish pre-contingency voltage profile in the study area and its vicinity.

### 2.1.3. Voltage Stability Criteria

Voltage Stability Analysis was performed using PV analysis method to establish Voltage Stability margin.

The applicable voltage stability criteria are stated in AESO Transmission Planning Criteria – Basis and Assumptions and they were applied for Category A and Category B contingencies.

## 2.2. Load and Generation Assumptions

### 2.2.1. Load Assumptions

Table 2-2 presents the AESO's 2014 Long-term Outlook (2014 LTO) corporate forecast for the Central Region at the time of Central Region peak. The load at central region is maintained as per the table below for both pre- and post- connection.

Table 2-2: 2014LTO Region Forecast Load

| 2014LTO at Peak |        | Forecast (MW) |         |
|-----------------|--------|---------------|---------|
| Description     | Season |               |         |
|                 |        | 2016          | 2017    |
| Central Region  | Summer | 1542.6        | 1602.8  |
|                 | Winter | 1779.5        | 1847.1  |
| AIL w/o Losses  | Summer | 10833.6       | 11440.4 |
|                 | Winter | 12154.2       | 12796.1 |

### 2.2.2. Generation and Inter-Tie Assumptions

The local generators in the Study Area were manually updated based on Table 2-3. The Battle River plant unit #5 was taken off-line to simulate N-G (Category A) and N-G-1 (Category B) events.

**Table 2-3: Local Generators in the Study Scenarios**

| Substation Name    | Generator Id | Pmax (MW) | 2016 WP (MW) | 2017SP (MW) |
|--------------------|--------------|-----------|--------------|-------------|
| Battler River 757S | 3            | 162.6     | 149.0        | 149.0       |
| Battle River 757S  | 4            | 166.3     | 155.0        | 155.0       |
| Battle River 757S  | 5*           | 407.0     | OFF          | OFF         |
| Total              | -            | 735.9     | 304          | 304         |

\* Battle River 5 was chosen for N-G criteria.

The import through the BC intertie has minimal impact on this study and therefore intertie assumptions were consistent with that in the AESO base cases. The intertie to SK is considered at zero. The most stressed, no-wind scenario was assumed. All wind generators in the study area were switched off in the studies.

### 2.2.3. HVDC Assumptions

The Western Alberta Transmission HVDC Line (WATL) and the Eastern Alberta Transmission HVDC Line (EATL) were dispatched to minimize total system loss in all study scenarios.

## 2.3. System Projects

The status of the transmission system project CETD in the study scenarios is based on the projected facility in-service date shown Table 2-4. All these components, except those that are canceled, were modeled in the study cases.

**Table 2-4: Summary of System Project CETD in the Study Cases**

| Project | Subproject | Subproject Name                             | In-Service Date |
|---------|------------|---------------------------------------------|-----------------|
| 811     | 1          | Bourque 970S (Partial Stage 1)              | Complete        |
| 811     | 1          | Bourque 970S (Partial Stage 2)              | Complete        |
| 811     | 2          | Cold Lake Area Bonnyville 700S and 7L146    | Complete        |
| 811     | 3          | St. Paul Area Upgrades - Watt Lake          | Complete        |
| 811     | 4          | St. Paul Upgrades St. Paul 707S, 7L139/7L70 | August-2016     |

|     |    |                                                    |          |
|-----|----|----------------------------------------------------|----------|
| 811 | 5  | Vermillion 710S Substation Upgrade                 | Complete |
| 811 | 6  | Heisler Area Upgrades                              | Complete |
| 811 | 7  | EN-7 - Kitscoty 705S and lines 7L14/7L130          | Complete |
| 811 | 9  | 7L701 Line Clearance Mitigation                    | Complete |
| 811 | 10 | 7L157 Bourque 970S to Mahihkan 837S                | Complete |
| 811 | 11 | 7L574 Bourque 970S to Wolf Lake 822S               | Complete |
| 811 | 12 | Bourque 970S to Leming Lake 715S                   | Complete |
| 811 | 13 | 7L160 Bourque 970S to Mahihkan 837S                | Complete |
| 811 | 14 | EN-14 - St. Paul Area Upgrades - 7LA92             | Complete |
| 811 | 16 | EN-16 7L24 Termination at Bonnyville 700S          | Complete |
| 811 | 20 | EN-20 7L587 Marguerite Lake 826S to Wolf Lake 822S | Complete |
| 811 | 22 | 7L14 Line Clearance Mitigation                     | Canceled |
| 811 | 23 | 7L53/7L117 Line Clearance Mitigation               | Canceled |
| 811 | 24 | EN-24 - St. Paul Area Upgrades - Whitby Lake 819S  | Complete |
| 811 | 25 | EN-25 - Bonnyville 700S Transformer addition       | Oct-2016 |
| 811 | 26 | EN-26 Kitscoty 6L06 Decommission                   | Complete |

The developments identified in the 2015 AESO Long Term Transmission Plan (2015 LTP) were not modeled in the studies.

## 2.4. Customer Connection Projects

Table 2-5 lists the customer connection projects that passed AESO Gate 2 and were modeled in all the study scenarios.

**Table 2-5: Summary of relevant facility assumptions for connection studies**

| Proj No | Project Name                                     | Planning Area | Gen MW | Load MW | Type | Planned ISD |
|---------|--------------------------------------------------|---------------|--------|---------|------|-------------|
| 851     | TransCanada Keystone KXL Pump station #2-Eyre    | 37-Provost    | 0.0    | 25.0    | Load | July, 2016  |
| 863     | TransCanada Keystone KXL Pump station #3-Current | 42-Hanna      | 0.0    | 25.0    | Load | July, 2016  |
| 864     | TransCanada Keystone KXL Pump                    | 42-Hanna      | 0.0    | 25.0    | Load | July, 2016  |

|      |                                                            |            |     |     |                  |           |
|------|------------------------------------------------------------|------------|-----|-----|------------------|-----------|
|      | station #4-Armitage                                        |            |     |     |                  |           |
| 1495 | Fortis Hayter 277S 42MVA Transformer and 25KV Breaker Add. | 37-Provost | 0.0 | 0.0 | Equipment Change | Sep, 2015 |
| 1516 | Enbridge Sunken Lake 221S Transformer Change               | 37-Provost | 0.0 | 14  | Load             | Jan, 2017 |

## 2.5. Facility Ratings and Shunt Elements

Table 2-6 to Table 2-8 provide the ratings of the existing and future key transmission facilities in the Study Area.

**Table 2-6: Summary of Key Transmission Line Ratings**

| Nominal Voltage (kV) | Transmission Line | From Substation     | To Substation/TAP point | Summer Rate (MVA) | Winter Rate (MVA) | Emergency Summer Rate (MVA) | Emergency Winter Rate (MVA) |
|----------------------|-------------------|---------------------|-------------------------|-------------------|-------------------|-----------------------------|-----------------------------|
| 138                  | 703BL             | HRT Express 329S    | Express TAP             | 123               | 150               | 135                         | 165                         |
| 138                  | 703L              | Hardisty 377S       | Express TAP             | 83                | 83                | 83                          | 83                          |
| 138                  | 885L              | Metiskow 648S       | Hansman Lake 650S       | 287               | 287               | 287                         | 287                         |
| 138                  | 749L              | Metiskow 648S       | Killarney TAP           | 121               | 148               | 133                         | 164                         |
| 138                  | 703L              | Metiskow 648S       | 703AL TAP               | 122               | 143               | 134                         | 162                         |
| 138                  | 703L              | Hughenden 213S      | Express TAP             | 121               | 145               | 133                         | 160                         |
| 138                  | 703L              | Hughenden 213S      | 703AL TAP               | 122               | 147               | 134                         | 162                         |
| 138                  | 715L              | Provost 545S        | Hansman Lake 650S       | 98                | 132               | 108                         | 145                         |
| 240                  | 954L              | Metiskow 648S       | Hansman Lake 650S       | 333               | 333               | 499                         | 499                         |
| 138                  | 703AL             | Sunken Lake 221S    | 703AL TAP               | 85                | 90                | 94                          | 99                          |
| 138                  | 748L              | Killarney Lake 267S | Hayter 277S             | 119               | 146               | 131                         | 161                         |
| 138                  | 749AL             | Killarney Lake 267S | Edgerton 899S           | 121               | 148               | 133                         | 163                         |
| 138                  | 7L224             | Hansman Lake 650S   | Monitor 774S            | 109.25            | 138.99            | 123.63                      | 142.79                      |
| 240                  | 9L948/948L        | Hansman Lake 650S   | PaintEarth 863S         | 332               | 332               | 432                         | 432                         |
| 240                  | 1047L             | Hansman Lake 650S   | Nilrem 574S             | 499               | 499               | 680.0                       | 748                         |

|     |            |                   |                   |        |        |       |        |
|-----|------------|-------------------|-------------------|--------|--------|-------|--------|
| 240 | 9L966      | Hansman Lake 650S | Pemukan 932S      | 332    | 332    | 432   | 432    |
| 138 | 749L       | Killarney TAP     | Metiskow 648S     | 121    | 149    | 133   | 164    |
| 138 | 749L/7L749 | Edgerton 899S     | Briker TAP        | 88     | 127    | 97    | 140    |
| 138 | 7L749      | Briker TAP        | Lloydminster 716S | 109.25 | 138.99 | 123.6 | 142.79 |
| 138 | 7L42       | Lloydminster 716S | Hill 751S         | 94.88  | 94.88  | 94.88 | 94.88  |
| 138 | 7L14       | Hill 751S         | Kitscoty 705S     | 71.88  | 86.25  | 71.88 | 86.25  |
| 138 | 7L130      | Kitscoty 705S     | Vermilion 710S    | 71.88  | 86.25  | 71.88 | 86.25  |

**Table 2-7: Summary of Key Transformer Ratings**

| Substation Name and Number | Nominal Ratio | Id | Rate (MVA) |
|----------------------------|---------------|----|------------|
| Metiskow 648S              | 240/138       | T3 | 200        |
| Metiskow 648S              | 138/25        | T1 | 25         |
| Hughenden 213S             | 138/25        | T1 | 25         |
| Provost 545S               | 138/25        | T1 | 42         |
| Sunken Lake 221S           | 138/4.16      | T2 | 25         |
| Sunken Lake 221S           | 138/4.16      | T1 | 25         |
| Killarney Lake 267S        | 138/25        | T1 | 42         |
| Hayter 277S                | 138/25        | T1 | 47         |
| Edgerton 899S              | 138/25        | 3T | 25         |
| Hansman Lake 650S          | 240/138       | T1 | 200        |
| Hansman Lake 650S          | 240/34.5      | T2 | 200        |

**Table 2-8: Summary of Shunt Elements in the Study Area**

| Substation Name and Number | Nominal Bus Voltage (kV) | Capacitors                      |                                 |                 | Reactors                        |                                 |                 |
|----------------------------|--------------------------|---------------------------------|---------------------------------|-----------------|---------------------------------|---------------------------------|-----------------|
|                            |                          | Number of Switched Shunt Blocks | Total at Nominal Voltage (MVar) | Status in Study | Number of Switched Shunt Blocks | Total at Nominal Voltage (MVar) | Status in Study |
| Sunken Lake 221S           | 138                      | 18.1                            | 18.1                            | Off/On/TBD      | -                               | -                               | -               |
| Hill 751S                  | 138                      | 1x18.12 + 1x22.96               | 41.08                           | TBD             | -                               | -                               | -               |
| Killarney Lake             | 138                      | 1x9.1+2x10.9                    | 30.9                            | TBD             | -                               | -                               | -               |

|                     |      |         |               |            |        |      |   |
|---------------------|------|---------|---------------|------------|--------|------|---|
| 267S                |      |         |               |            |        |      |   |
| Lloydminster 716S   | 138  | 1x18.12 | 18.12         | TBD        | -      | -    | - |
| Metiskow 648S       | 138  | 1x27    | 27            | TBD        | -      | -    | - |
| Nilrem 574S         | 138  | 2x24.8  | 49.6          | TBD        | -      | -    | - |
| Tucuman 478S        | 138  | 1x27.17 | 27.17         | TBD        | -      | -    | - |
| Vermilion 710S      | 138  | 1x22.96 | 22.96         | TBD        | -      | -    | - |
| Lanfine 959S        | 34.5 | 1x200   | 200           | SVC        | 1x-100 | -100 | - |
| Monitor 774S        | 144  | 2       | 50 (20 & 30)  | On/off/TBD | -      | -    | - |
| Stettler 769S       | 144  | 1       | 15            | On/off/TBD | -      | -    | - |
| Lanfine 959S        | 144  | 2       | 60(2x30)      | On/off/TBD | -      | -    | - |
| Sullivan Lake 775S  | 72   | 1       | 10            | On/off/TBD | -      | -    | - |
| Three Hills 770S    | 25   | 1       | 4.95          | On/off/TBD | -      | -    | - |
|                     | 144  | 1       | 20            | On/off/TBD | -      | -    | - |
| Michichi Creek 802S | 144  | 1       | 10            | On/off/TBD | -      | -    | - |
| Youngstown 772S     | 25   | 1       | 2.4           | On/off/TBD | -      | -    | - |
|                     | 72   | 1       | 5             | On/off/TBD | -      | -    | - |
| Hanna 763S          | 25   | 1       | 4.95          | On/off/TBD | -      | -    | - |
| Pemukan 932S        | 138  | 2       | 55(2 x 27.55) | On/off/TBD | -      | -    | - |
| Hansman Lake 650S   | 34.5 | 1       | 200           | SCV        | 1      | -100 | - |

## 2.6. Voltage Profile Assumptions

The AESO ID #2010-007RS was used to establish normal system (i.e., pre-contingency) voltage profiles in the study area and its vicinity prior to commencing analysis. The voltage profile for the key nodes in the study area under normal operation condition is listed in Table 2-9.

For steady state analysis, the operating range of the SVC at Hansman Lake 650S was maintained in the range of -20 MVar to +20 MVar. The voltage set-point is 253 kV. The operating range of the SVC at Lanfine 959S was maintained in the range of -20 MVar to +20 MVar. The voltage set-point is 258 kV.

Table 2-9: Summary of Voltage at Key Nodes in the Study Area

| Substation          | Nominal Voltage (kV) | Minimum Operating Limit (kV) | Desired Range (kV) | Maximum Operating Limit (kV) | 2016 WP (kV) | 2017 SP (kV) |
|---------------------|----------------------|------------------------------|--------------------|------------------------------|--------------|--------------|
| Battle River 757S   | 144                  | 144                          | 146-150            | 155                          | 149.6        | 149.7        |
| Cordel 755S         | 240                  | 253                          | 254-257            | 260                          | 254.8        | 254.2        |
| Nevis 766S          | 240                  | 246                          | 248-255            | 265                          | 253.3        | 249.8        |
|                     | 144                  | 145                          | 149-152            | 155                          | 149.2        | 150.2        |
| Oyen 767S           | 144                  | 140                          | 143-146            | 155                          | 143.7        | 144.1        |
| Killarney Lake 267S | 138                  | 138                          | 138-144            | 145                          | 142.4        | 143.2        |
| Metiskow 648S       | 240                  | 250                          | 250-260            | 260                          | 254.4        | 254.4        |
| Hardisty 377S       | 138                  | 140                          | 140-144            | 145                          | 142.9        | 142.2        |
| Lloydminster 716S   | 144                  | 137                          | 142-149            | 151                          | 146.6        | 144.7        |

### 3. Study Methodology

#### 3.1. Study Objectives

The objectives of the study discussed in this report were the following:

- To assess the impact of the Project connection to the AIES.
- To identify Pre- and Post-connection system constraints and recommend mitigation measures to facilitate the connection, if required.

#### 3.2. Study Scenarios

Table 3-1 summarizes the study scenarios used for the connection studies.

Table 3-1: Study Scenarios

| Scenario # | Scenario            | Power Flow | Voltage Stability | Short Circuit* | Generation level                         |
|------------|---------------------|------------|-------------------|----------------|------------------------------------------|
| 01         | 2017SP Pre Project  | X          | -                 | -              | Low generation, Critical generation off  |
| 02         | 2016WP Pre Project  | X          | -                 | x              | Low generation, Critical generation off* |
| 03         | 2017SP Post Project | X          | -                 | -              | Low generation, Critical generation off  |
| 04         | 2016WP Post Project | X          | X                 | X              | Low generation, Critical generation off* |
| 05         | 2025WP post project | -          | -                 | X              | All generation in service                |

Note: \* All generators in the Study Area will be switched on for short-circuit analysis.

### 3.3. Connection Studies Carried Out

Load flow, voltage stability, and short circuit studies were performed for different study scenarios according to Table 3-1.

The following studies were performed for the pre-connection analysis:

- Power flow (Category A and Category B, from the Reliability Criteria)
- Short-Circuit analysis

The following studies were performed for the post-connection analysis:

- Power flow (Category A and Category B from the Reliability Criteria)
- Voltage stability (Category A and Category B from the Reliability Criteria)
- Short-Circuit analysis

### 3.4. Power Flow Analysis

Pre- and post-connection power flow studies were performed to assess system performance for Category A and Category B conditions. The system in the Study Area and its vicinity was monitored to identify any thermal violation, voltage range violation, and voltage deviation as per Reliability Criteria stated in Section 2.1.1.

The transmission elements that were monitored to record any violations of the Reliability Criteria include all the components at 69 kV and above in the Study Area and its vicinity.

PSS/E 33 contingency power flow analysis function was used as the study tool.

#### 3.4.1. Contingencies Studied

The study includes all Category B contingencies (69 kV and above) within the Study Area and the tie lines from the Study Area to surrounding areas. A list of selected special Category B contingencies was provided in Table 3-2. These transformer contingencies will lead to a bus outage due to the bus configuration.

**Table 3-2: List of Special Category B Contingencies**

| Contingencies | Elements Loss | From Substation    | To Substation    |
|---------------|---------------|--------------------|------------------|
| 163S T5       | 869L          | Amoco Empress 163S | Sandy Point 204S |
|               | 760L          | Empress 394S       | Oyen 767S        |
|               | 871L          | Amoco Empress 163S | Sand Hills 341S  |
|               | 669L          | Amoco Empress 163s | Cypress 562S     |

| Contingencies | Elements Loss       | From Substation    | To Substation         |
|---------------|---------------------|--------------------|-----------------------|
|               | 163S Transformer T5 | -                  | -                     |
| 394S T1       | 760L                | Empress 394S       | Amoco Empress 163S    |
|               | 668L                | Empress 394S       | Cypress 562S          |
|               | 394S Transformer T1 | -                  | -                     |
| 767S T1       | 767S Transformer T1 | -                  | -                     |
|               | 7L132               | Oyen 767S          | Lanfine 959S          |
|               | 7L760               | Oyen 767S          | 760L TAP              |
|               | 6L09                | Oyen 767S          | 6L21 TAP              |
| 648S T1       | 648S Transformer T1 | -                  | -                     |
|               | 703L                | Metiskow 648S      | 703AL TAP             |
|               | 749L                | Metiskow 648S      | 749AL TAP             |
|               | 885L                | Metiskow 648S      | Hansman Lake 650S     |
| 863S T2       | 863S Transformer T2 | -                  | -                     |
|               | 9L27                | Cordel 755S        | Paintearth Creek 863S |
|               | 9L948/948L          | Paintearth Creek   | Hansman Lake 650S     |
| 766S T1       | 766S Transformer T1 | -                  | -                     |
|               | 9L20                | Nevis 766S         | Cordel 755S           |
|               | 9L912/912L          | Nevis 766S         | Red Deer 63S          |
| 899S T3       | 899S Transformer T3 | -                  | -                     |
|               | 749L                | Edgerton 899S      | 7LB749 TAP            |
|               | 749L                | Edgerton 899S      | 749AL TAP             |
| 751S T1       | 751S Transformer T1 | -                  | -                     |
|               | 7L42                | Hill 751S          | Lloydminster 716S     |
|               | 7L14                | Hill 751S          | Kitscoty 705S         |
|               | 6L06                | Hill 751S          | Kitscoty 705S         |
|               | 751S Cap bank       | -                  | -                     |
|               | 751S Transformer T2 | -                  | -                     |
| 709S T1       | 709S Transformer T1 | -                  | -                     |
|               | 7L65                | Vegreville 709S    | Vermilion 710S        |
|               | 7L177               | Vegreville 709S    | North Holden 395S     |
|               | 7L92                | Vegreville 709S    | 7LA92 TAP             |
| 526S T1       | 526S Transformer T1 | -                  | -                     |
|               | 7L129               | Buffalo Creek 526S | 7LA129 TAP            |
|               | 7L50                | Buffalo Creek 526S | 704L TAP              |
|               | 562S Cap bank       |                    |                       |
| 252S T2       | 252S Transformer T2 | -                  | -                     |
|               | 704L                | Jarrow 252S        | 704AL TAP             |
|               | 704L                | Jarrow 252S        | 7L50 TAP              |

| Contingencies | Elements Loss       | From Substation | To Substation  |
|---------------|---------------------|-----------------|----------------|
|               | 408L                | Jarrow 252S     | Wainwright 51S |
|               | 61L                 | Jarrow 252S     | Cochin 968S    |
| 478S T1       | 478S Transformer T1 | -               | -              |
|               | 704L                | Tucuman 478S    | 704AL TAP      |
|               | 681L                | Tucuman 478S    | Hardisty 377S  |
|               | 679L                | Tucuman 478S    | Nilrem 574S    |
|               | 680L                | Tucuman 478S    | Nilrem 574S    |
|               | 478S Cap bank       | -               | -              |
| 377ST1        | 377S Transformer T1 | -               | -              |
|               | 377S Cap Bank       | -               | -              |
|               | 681L                | Hardisty 377S   | Tucuman 478S   |
|               | 702L                | Hardisty 377S   | 702L TAP       |
|               | 769L                | Hardisty 377S   | Rosyth 296S    |
|               | 703L                | Hardisty 377S   | 703BL TAP      |
| 574ST2        | 574S Transformer T2 | -               | -              |
|               | 574S Transformer T3 | -               | -              |
| 51ST3         | 51S Transformer T3  | -               | -              |
|               | 704L                | Wainwright 51S  | 704L TAP       |

### 3.5. Voltage Stability (PV) Analysis

The objective of the voltage stability analysis was to determine the ability of a power system to maintain sufficient reactive power margins at all the buses in the system under normal (Category A) and abnormal (Category B) steady-state operating conditions. In the study, PV (Power-Voltage) analysis was performed according to the Western Electricity Coordinating Council (WECC) Voltage Stability Assessment Methodology, as described in detail in the AESO Transmission Reliability Criteria.

PV curves were generated for Category A condition and a selected set of critical Category B contingencies in the Study Area. The maximum operating load limits are:

- 5% below the load at the collapse point on the PV curve for Category A
- 5% below the pre-contingency load corresponding to the collapse point on the PV curve for Category B contingencies

PSS/E 33 PV analysis function was used as the study tool.

#### 3.5.1. Contingencies Studied

The study includes, Category A and Category B contingencies. Also all Category B contingencies (69 kV and above) within the Study Area and the tie lines from the Study Area to the surrounding areas are included. Only a selected set of critical contingencies were chosen for the PV result plots.

### **3.6. Short-Circuit Analysis**

Short-circuit analysis was performed for three-phase and single-phase to ground current levels. All generators in and around the Study Area were switched on to evaluate the maximum fault current under three-phase-to-ground faults and single-line-to-ground faults. The scope of the analysis included 3-phase bolted faults and single-line to ground faults.

Short circuit analysis was performed to evaluate the three-phase and single-phase to ground current levels at selected buses in the Study Area in the pre- and post-connection systems.

PSS/E 33 automatic sequencing fault calculation function was used as the study tool.

## 4. Pre-Connection System Assessment

### 4.1. Pre-Connection Power Flow Analysis

The pre-connection system is defined as the system configuration without the Project. The steady-state performance of the pre-connection system was assessed under the 2017 SP and 2016 WP study scenarios. The power flow analyses were based on the Reliability Criteria described in Section 2.

#### 4.1.1. Scenario #1 – 2017 SP (Pre-connection)

The contingency of the Metiskow 648S 138/25kV transformer T1, which trips the Metiskow 648S 138kV bus and all three 138kV lines connected to the bus, will cause voltage collapse. This violation is an existing issue known to the AESO and is managed using real time operational practices.

No thermal or other voltage violations were observed under N-1 contingencies.

The results of the power flow analysis are summarized in Table 4-1 and shown in the power flow diagrams in Attachment A.

**Table 4-1: Summary of System Performance – 2017 SP Pre-connection**

| Contingency                                             | Voltage Performance |                   |               |
|---------------------------------------------------------|---------------------|-------------------|---------------|
|                                                         | Substation / Bus    | Voltage Violation | Deviation (%) |
| N-0: Normal Operation Condition                         | -                   | None              | Acceptable    |
| N-1: Metiskow 648S 138/25kV Transformer T1 <sup>3</sup> | Voltage Collapse    |                   |               |

#### 4.1.2. Scenario #2 – 2016 WP (Pre-connection)

As in the 2017 SP, the contingency of the Metiskow 648S 138/25kV transformer T1, which trips the Metiskow 648S 138kV bus and all three 138kV lines connected to the bus, will cause voltage collapse. This violation is an existing issue known to the AESO and is managed using real time operational practices.

A thermal loading violation was observed on the 138 kV transmission line 7L130 (Kitscoty 705S to Vermilion 710S) under N-1 contingency of the 138 kV transmission line 749L (Metiskow 648S to Edgerton 899S). The 749L contingency leaves 7L130 to radially feed the area load which causes thermal violation on this line. This violation is known to the AESO and is managed using real time operational practices.

No other voltage violations were observed under N-1 contingencies.

<sup>3</sup> While the loss of the 138/25 kV transformer at Metiskow 648S substation is considered a Category B (N-G-1) event, this event would in fact result in the simultaneous loss of the 138 kV bus and the 138 kV transmission lines 749L, 703L, and 885L, due to the Metiskow 138 kV bus configuration.

The results of the power flow analysis are summarized in Table 4-2, Table 4-3 and shown in the power flow diagrams in Attachment A.

**Table 4-2: Summary of System Performance – Thermal Loading, 2016 WP Pre-connection**

| Contingency                                | Thermal Loading                         |              |                        |            |       |
|--------------------------------------------|-----------------------------------------|--------------|------------------------|------------|-------|
|                                            | Element                                 | Rating (MVA) | Emergency rating (MVA) | Flow (MVA) | %I    |
| N-0: Normal Operation Condition            | none                                    | -            |                        |            | -     |
| N-1: 749L (Metiskow 648S to Edgerton 899S) | 7L130 (Kitscoty 705S to Vermilion 710S) | 86.2         | 86.2                   | 92.5       | 102.5 |

**Table 4-3: Summary of Voltage Violation and Deviation– 2016 WP Pre-connection**


| Contingency                                | Voltage Performance |                    |               |
|--------------------------------------------|---------------------|--------------------|---------------|
|                                            | Substation / Bus    | Voltage Violations | Deviation (%) |
| N-0: Normal Operation Condition            | -                   | None               | Acceptable    |
| N-1: Metiskow 648S 138/25kV Transformer T1 | Voltage Collapse    |                    |               |

## 5. Connection Alternatives

### 5.1. Overview

Currently, Hughenden 213S has one 138/24.5 kV 15/20/25 MVA Transformer and a 24.9 kV, 25 MVA Voltage Regulator. The substation is connected to the 138 kV transmission line 703L via T-tap configuration. Figure 2 shows the existing system configuration.

Figure 2: Provost Area (Existing)



As per FortisAlberta's Need for Development<sup>4</sup> document dated, load shifting was examined to address the need on 2.8 MW DTS increase. Load shifting would require extensive distribution facilities and would not resolve the reliability concerns for the distribution system supplied by the Hughenden 213S substation. Therefore, two transmission alternatives were examined to address the load increase at Hughenden 213S substation.

<sup>4</sup> Filed under a separate cover.


### Alternative 1: Addition of one (1) new 138/25kV 25/33/42MVA LTC transformer at Hughenden 213S with existing T-tap connection to 138 kV transmission line 703L

This alternative consisted of the addition of a 138/25 kV 25/33/42 MVA LTC Transformer to Hughenden 213S and maintain the T-tap connection to the 138 kV transmission line 703L.

### Alternative 2: Addition of one (1) new 138/25kV 25/33/42MVA LTC transformer at Hughenden 213S with In-and-Out connection to 138 kV transmission line 703L

Alternative 2 consisted of the addition of a 138/25 kV 25/33/42 MVA LTC Transformer to Hughenden 213S and transform the T-tap connection to the 138 kV transmission line 703L to an in-and-out configuration. Figure 3 shows the configuration of this alternative.

**Figure 3: Alternative 2 – 138/25 kV 25/33/42 MVA LTC Transformer addition with In-and-out connection to 138 kV transmissions line 703L**



## **5.2. Connection Alternatives Evaluated**

### **5.2.1. Connection Alternatives Selected for Further Studies**

**Alternative 2** was studied as it meets FortisAlberta's reliability criteria<sup>5</sup>.

### **5.2.2. Connection Alternatives Not Selected for Further Studies**

**Alternative 1** doesn't meet FortisAlberta's reliability criteria. Therefore, it was eliminated from further studies.

---

<sup>5 5</sup> As per Section 4.2.1 of Fortis's Distribution Deficiency Report dated October 7, 2015

## 6. Technical Analysis of the Connection Alternatives

Power flow and voltage stability analysis were performed for Alternative 2. The results of power flow and voltage stability analyses showed the following:

- Similar thermal criteria violations were observed in pre-connection scenarios and post-connection scenarios as shown in Table 6-1 to Table 6-3. These criteria violations will be managed using real time operational practices
- Similar to the pre-connection, the contingency of the Metiskow 648S 138/25kV transformer T1, which trips the Metiskow 648S 138kV bus and all three 138kV lines connected to the bus, will cause voltage collapse;
- Voltage stability margins in the Study Area would continue to meet the Reliability Criteria following the Project connection.

### 6.1. Alternative 2 – Addition of one (1) new 138/25kV 25/33/42MVA LTC transformer with In-and-out connection to 138 kV transmission line 703L

The power flow and voltage stability analyses results indicate that Alternative 2 would not adversely impact the performance of AIES. The detailed results are presented in the following subsections.

#### 6.1.1. Power Flow Analysis

The power flow analyses were based on the Criteria, System Data, and Study Assumptions as described in Section 2.

##### 6.1.1.1. Scenario #3 – 2017 SP (Post-connection)

As with the pre-connection, the contingency of the Metiskow 648S 138/25kV transformer T1, which trips the Metiskow 648S 138kV bus and all three 138kV lines connected to the bus, will cause voltage collapse in 2017 SP Post-connection.

No thermal or voltage violations were observed under Category B contingencies. The results are summarized in Table 6-1 and shown in the power flow diagrams in Attachment B.

**Table 6-1: Summary of System Performance – 2017 SP Post-connection**

| Contingency                                | Voltage Performance |                   |               |
|--------------------------------------------|---------------------|-------------------|---------------|
|                                            | Substation / Bus    | Voltage Violation | Deviation (%) |
| N-0: Normal Operation Condition            | -                   | None              | Acceptable    |
| N-1: Metiskow 648S 138/25kV Transformer T1 | Voltage Collapse    |                   |               |

### 6.1.1.2. Scenario #4 – 2016 WP (Post-connection)

A comparative result of the power flow analysis for 2016 WP Post-connection and 2016WP Pre-connection are summarized in Table 6-2, Table 6-3 and shown in the power flow diagrams in Attachment B.

Similar to the pre-connection, the contingency of the Metiskow 648S 138/25kV transformer T1, which trips the Metiskow 648S 138kV bus and all three 138kV lines connected to the bus, will cause voltage collapse in 2016 WP Post-connection as well.

Similar to the pre-connection, thermal overloading was observed on 138 kV transmission line 7L130 (Kitscoty 705S to Vermilion 750S) under N-1 contingency of 138 kV transmission line 749L (Metiskow 648S to Edgerton 899S). 749L contingency leaves 7L130 to radially feed the area load which causes thermal violation on this line. This violation is managed using real time operational practices.

The results of the power flow analysis are summarized in Table 6-2 and shown in the power flow diagrams in Attachment B.

**Table 6-2: Summary of System Performance – Thermal Loading 2016 WP Post-connection**

| Contingency                                | Overloaded Branch                       | Line Rating (MVA) |           | 2016 WP Pre-Connection | 2016 WP Post-Connection | %I Loading Difference |
|--------------------------------------------|-----------------------------------------|-------------------|-----------|------------------------|-------------------------|-----------------------|
|                                            |                                         | Normal            | Emergency | Loading (%I / MVA)     | Loading (%I / MVA)      | Post-Pre              |
| N-1: 749L (Metiskow 648S to Edgerton 899S) | 7L130 (Kitscoty 705S to Vermilion 710S) | 86.25             | 86.25     | 102.5% / 92.5          | 102.4% / 92.6           | -0.1                  |

**Table 6-3: Summary of Voltage Violation and Deviation 2016 WP Post-connection**

| Contingency                                | Voltage Performance |                    |               |
|--------------------------------------------|---------------------|--------------------|---------------|
|                                            | Substation / Bus    | Voltage Violations | Deviation (%) |
| N-0: Normal Operation Condition            | -                   | Acceptable         | Acceptable    |
| N-1: Metiskow 648S 138/25kV Transformer T1 | Voltage Collapse    |                    |               |

### 6.1.2. Voltage Stability Analysis (Alternative 2)

Voltage stability analysis was performed using Scenario #4 (2016 WP) to investigate the system active power margin after the proposed development under Category A and Category B contingency conditions.

The sink sub-system includes the loads in the Study Area. The source system was formed by the generation in the Wabamun area (AESO Planning area 40) and Fort McMurray area (AESO Planning area 25). The total load of 624.7 MW at the Study Area was considered as the starting point of the PV analysis.

#### 6.1.2.1. Scenario #4 – 2016 WP (Post-connection)

The voltage stability margins under Category A and the four most severe Category B contingencies are listed in Table 6-4. The voltages at Hughenden 213S, Metiskow 648S, Hardisty 377S, Sunken Lake 221S, and Rosyth 296S substations were monitored during the studies. The PV plots are presented in Attachment C.

**Table 6-4: Summary of Voltage Stability Analysis**

| System Condition                               | Incremental Area Load Increase before Collapse Point (MW) | Available Voltage Stability Margin (%) | Meets Voltage Stability Criteria? |
|------------------------------------------------|-----------------------------------------------------------|----------------------------------------|-----------------------------------|
| N-0: Normal Operation Condition                | 320.0                                                     | 51.2                                   | Yes                               |
| N-1: 7L130 (Vermillion 710S to Kitscoty 705S)  | 80                                                        | 12.8                                   | Yes                               |
| N-1: 749L (Edgerton 899S to Metiskow 648S)     | 110                                                       | 17.6                                   | Yes                               |
| N-1: 7L14 (Vermilion 710S to Hill 751S)        | 120                                                       | 19.2                                   | Yes                               |
| N-1: 899S T3 (Edgerton 899S Transformer fault) | 160                                                       | 25.6                                   | Yes                               |

## 6.2. Conclusions

Power flow and voltage stability analyses were performed on the connection Alternative 2 to evaluate the impacts of the Project connection on the AIES. There is one thermal loading violation and one voltage collapse observed for both pre-connection and post-connection of the Project. The identified constraints are addressed using real time operational practice.

The study results confirm that the proposed connection alternatives 2 will not adversely impact the performance of AIES.

## 7. Short-Circuit Analysis

Short circuit studies were performed to determine the changes of fault levels at the Hughenden 213S, and surrounding substations, including Metiskow 648S, Hardisty 377S, Sunken Lake 221S, Rosyth 296S and HRT Express 329S substations, prior to and post connection of the Project.

Short circuit studies shows that the Project will not adversely change the fault levels within the AIES.

### 7.1. Pre-Connection

Short circuit studies were performed using the 2016 WP scenario to determine the fault levels at Hughenden 213S and its surrounding substations prior to the Project. The single phase and three phase fault current results are presented in Table 7-1.

**Table 7-1: Summary of Short-Circuit Current Levels – Pre-Connection (2016 WP)**

| Substation Name and Number      | Base Voltage (kV) | Pre-Fault Voltage (kV) | 3- $\Phi$ Fault (kA) | Positive Sequence Thevenin Source Impedance ( $R1+jX1$ ) (pu) | 1- $\Phi$ Fault (kA) | Zero Sequence Thevenin Source Impedance ( $R0+jX0$ ) (pu) |
|---------------------------------|-------------------|------------------------|----------------------|---------------------------------------------------------------|----------------------|-----------------------------------------------------------|
| Hughenden 213S                  | 138               | 142.2                  | 4.87                 | 0.033521+ j0.082332                                           | 3.89                 | 0.039766+ j0.151048                                       |
| Hughenden 213S T1 Low side 25kV | 25                | 25.8                   | 4.10                 | 0.100400+ j0.573785                                           | 3.89                 | 0.060655+ j0.674804                                       |
| Metiskow 648S                   | 138               | 142.6                  | 7.26                 | 0.017979+ j0.056960                                           | 8.05                 | 0.004016+ j0.042194                                       |
|                                 | 240               | 254.4                  | 5.32                 | 0.013792+ j0.046066                                           | 6.49                 | 0.002545+ j0.021800                                       |
| Hardisty 377S                   | 138               | 143.2                  | 6.92                 | 0.021872+ j0.059069                                           | 7.98                 | 0.005944+ j0.037545                                       |
| Sunken Lake 221S                | 138               | 142.5                  | 7.15                 | 0.018312+ j0.057809                                           | 7.79                 | 0.005129+ j0.045632                                       |
| Rosyth 296S                     | 138               | 143.1                  | 6.64                 | 0.022990+ j0.061404                                           | 7.37                 | 0.008324+ j0.045555                                       |
| HRT Express 329S                | 138               | 143.2                  | 6.62                 | 0.023130+ j0.061576                                           | 7.23                 | 0.009092+ j0.048540                                       |

### 7.2. Post-Connection

Short circuit studies were performed using the 2016 WP scenario and 2025 WP scenario to determine the fault levels at the Hughenden 213S substation and its surrounding substations after the Project.

### 7.2.1. Alternative 2: Addition of one (1) new 138/25kV 25/33/42MVA LTC transformer with In-and-out connection to the 138 kV transmission line 703L

The single phase and three phase fault current results following Alternative 2 developments are presented in Table 7-2 and Table 7-3.

**Table 7-2: Summary of Short-Circuit Current Levels – Post-Connection (2016 WP)**

| Substation Name and Number      | Base Voltage (kV) | Pre-Fault Voltage (kV) | 3- $\Phi$ Fault (kA) | Positive Sequence Thevenin Source Impedance ( $R1+jX1$ ) (pu) | 1- $\Phi$ Fault (kA) | Zero Sequence Thevenin Source Impedance ( $R0+jX0$ ) (pu) |
|---------------------------------|-------------------|------------------------|----------------------|---------------------------------------------------------------|----------------------|-----------------------------------------------------------|
| Hughenden 213S                  | 138               | 142.7                  | 4.87                 | 0.033757+ j0.082396                                           | 3.90                 | 0.039798+ j0.151155                                       |
| Hughenden 213S T1 low side 25kV | 25                | 25.9                   | 4.14                 | 0.079565+ j0.574157                                           | 3.95                 | 0.059478+ j0.661449                                       |
| Hughenden 213S T2 Low side 25kV | 25                | 26.0                   | 4.99                 | 0.068196+ j0.477628                                           | 4.60                 | 0.065040+ j0.600933                                       |
| Metiskow 648S                   | 138               | 142.7                  | 7.27                 | 0.018012+ j0.056945                                           | 8.06                 | 0.004016+ j0.042210                                       |
|                                 | 240               | 254.4                  | 5.33                 | 0.013796+ j0.045973                                           | 6.49                 | 0.002546+ j0.021809                                       |
| Hardisty 377S                   | 138               | 144.5                  | 6.90                 | 0.022341+ j0.059671                                           | 7.96                 | 0.006047+ j0.037862                                       |
| Sunken Lake221S                 | 138               | 142.7                  | 7.16                 | 0.018347+ j0.057795                                           | 7.79                 | 0.005129+ j0.045648                                       |
| Rosyth 296S                     | 138               | 144.4                  | 6.62                 | 0.023458+ j0.062007                                           | 7.36                 | 0.008428+ j0.045872                                       |
| HRT Express 329S                | 138               | 144.4                  | 6.60                 | 0.023589+ j0.062159                                           | 7.22                 | 0.009193+ j0.048848                                       |

**Table 7-3: Summary of Short-Circuit Current Levels – Post-Connection (2025 WP)**

| Substation Name and Number      | Base Voltage (kV) | Pre-Fault Voltage (kV) | 3- $\Phi$ Fault (kA) | Positive Sequence Thevenin Source Impedance ( $R1+jX1$ ) (pu) | 1- $\Phi$ Fault (kA) | Zero Sequence Thevenin Source Impedance ( $R0+jX0$ ) (pu) |
|---------------------------------|-------------------|------------------------|----------------------|---------------------------------------------------------------|----------------------|-----------------------------------------------------------|
| Hughenden 213S                  | 138               | 142.2                  | 5.33                 | 0.029986+ j0.075151                                           | 4.17                 | 0.114098+ j0.351503                                       |
| Hughenden 213S T1 low side 25kV | 25                | 25.2                   | 4.27                 | 0.071625+ j0.539176                                           | 4.07                 | 0.055527+ j0.621358                                       |
| Hughenden 213S T2 Low side 25kV | 25                | 25.3                   | 5.15                 | 0.061094+ j0.449079                                           | 4.75                 | 0.061057+ j0.566058                                       |
| Metiskow 648S                   | 138               | 143.1                  | 8.46                 | 0.014738+ j0.049114                                           | 9.24                 | 0.007874+ j0.042058                                       |
| Hardisty 377S                   | 138               | 143.1                  | 7.98                 | 0.017834+ j0.051374                                           | 10.31                | 0.086572+ j0.186359                                       |
| Sunken Lake221S                 | 138               | 143.1                  | 8.31                 | 0.015066+ j0.049980                                           | 8.90                 | 0.102723+ j0.352128                                       |
| Rosyth 296S                     | 138               | 143.0                  | 7.61                 | 0.018943+ j0.053712                                           | 9.31                 | 0.005906+ j0.037397                                       |
| HRT Express 329S                | 138               | 143.0                  | 7.58                 | 0.019117+ j0.053931                                           | 9.04                 | 0.002545+ j0.021776                                       |

## 8. Project Interdependencies

There are no identified dependencies for the Project.

## 9. Summary and Recommendations

FortisAlberta Inc. (FortisAlberta), the market participant, has applied to the Alberta Electric System Operator (AESO) requesting a 2.8MW load increase at the existing Hughenden 213S substation. The Hughenden 213S substation is located in Provost area (AESO Planning area 37) at 04-03-41-07-W4M.

The requested in-service date (ISD) for the Project is December 1, 2016.

Two (2) connection alternatives were proposed for the Project:

- Alternative 1: Addition of one (1) new 138/25kV 25/33/42MVA LTC Transformer with the existing T-tap connection to 138 kV transmission line 703L;
- Alternative 2: Addition of one (1) new 138/25kV 25/33/42MVA LTC Transformer with in-and-out connection to 138 kV transmission line 703L.

FortisAlberta confirmed that of these two alternatives, only Alternative 2 meets their reliability criteria. Thus, this report presents the results of the detailed studies for Alternative 2.

Study results show that there are one existing thermal loading above transmission line emergency rating and one voltage collapse under loss of Metiskow 648S Transformer T1. AESO has previously identified these violations through other projects and specified the solutions with the regional long term plan. Alternative 2 does not adversely impact the AIES and does not significantly alter the short circuit levels in the area. Voltage stability analysis confirms that voltage stability margins continue to satisfy the voltage stability criteria.

The power flow study results indicate the following:

A- Pre-connection scenarios:

1- 2016 WP

- Category A (N-0)
  - No voltage violations or transmission thermal violations were observed.
- Category B (Single Element Outage (N-1))
  - The contingency of the Metiskow 648S 138/25kV transformer T1, which trips the Metiskow 648S 138kV bus and all three 138kV lines connected to the bus, will cause voltage collapse. This violation is known to the AESO and is managed using real time operational practices.
  - A thermal violation was observed on the 138 kV transmission line 7L130 (Kitscoty 705S to Vermilion 710S) following the N-1 contingency of the 138 kV transmission line 749L (Metiskow 648S to Edgerton 899S). 749L contingency leaves 7L130 to radially feed the area load which causes thermal violation on this line.. This violation is known to the AESO and is managed using real time operational practices.

2- 2017 SP

- Category A(N-0)
  - No voltage violations or transmission thermal violations were observed.
- Category B (Single Element Outage (N-1))
  - The contingency of the Metiskow 648S 138/25kV transformer T1, which trips the Metiskow 648S 138kV bus and all three 138kV lines connected to the bus, will cause voltage collapse. This violation is known to the AESO and is managed using real time operational practices.

B- Post-connection scenarios:

3- 2016 WP

- Category A(N-0)
  - No voltage violations or transmission thermal violations were observed.
- Category B (Single Element Outage (N-1))
  - Similar to the pre-connection scenario, the contingency of the Metiskow 648S 138/25kV transformer T1, which trips the Metiskow 648S 138kV bus and all three 138kV lines connected to the bus, will cause voltage collapse in 2016WP Post-connection as well.
  - Thermal overloading was observed on the 138 kV transmission line 7L130 (Kitscoty 705S to Vermilion 750S) under the N-1 contingency of the 138 kV transmission line 749L (Metiskow 648S to Edgerton 899S). The 749L contingency leaves 7L130 to radially feed the area load which causes thermal violation on this line. This violation is known to the AESO and is managed using real time operational practices.

4- 2017 SP


- Category A(N-0)
  - No voltage violations or transmission thermal violations were observed
- Category B ( Single Element Outage (N-1))
  - Similar to the pre-connection scenario, the contingency of the Metiskow 648S 138/25kV transformer T1, which trips the Metiskow 648S 138kV bus and all three 138kV lines connected to the bus, will cause voltage collapse in 2017 SP Post-connection. This violation is known to the AESO and is managed using real time operational practices.

## Recommendations

The connection assessment performed for upgrade of Hughenden 213S indicates that the proposed connection will not adversely impact the performance of the AIES. It is recommended to connect the Project through Alternative 2.

## **Attachment A**

### **Pre-Connection Power Flow Analysis Results (Scenarios 1 and 2)**



Fortis Hughenden Upgrade - P1642


SK Tie (Import): -0.1 MW BC and MATL (Import): 53.8 MW

FIGURE A1-1-N-0: NORMAL OPERATION  
2017 SUMMER PEAK (PRE-CONNECTION)  
PRINTED ON TUESDAY 10. NOVEMBER 2015

Bus - Voltage (kV)  
Branch - MW/Mvar  
Equipment - MW/Mvar  
100kV Bus  
115kV Bus  
138kV Bus  
145kV Bus  
155kV Bus  
165kV Bus  
175kV Bus  
185kV Bus  
195kV Bus








Fortis Hughenden Upgrade - P1642

SK Tie (Import): -0.1 MW BC and MATL (Import): 12.9 MW

FIGURE A1-4 N-1: 749L (EDGERTON 899S TO METISKOW 648S)  
2017 SUMMER PEAK (PRE-CONNECTION)  
PRINTED ON TUESDAY 10. NOVEMBER 2015

Bus - Voltage (kV)  
Branch - MW/Mvar  
Equipment - MW/Mvar  
1000 MVA  
KV: <25.000 <=58.000 <=138.000 <=240.000 <=500.000 >500.000






Fortis Hughenden Upgrade - P1642

SK Tie (Import): -0.1 MW BC and MATL (Import): 107.2 MW

FIGURE A2-1-N-0: NORMAL OPERATION  
2016 WINTER PEAK (PRE-CONNECTION)  
PRINTED ON TUESDAY 10. NOVEMBER 2015

Bus - Voltage (kV)  
Branch - MW/Mvar  
Equipment - MW/Mvar  
1000 MVA  
KV: <25.000 <=58.000 <=138.000 <=240.000 <=500.000 >500.000



Fortis Hughenden Upgrade - P1642


SK Tie (Import): -0.1 MW

BC and MATL (Import): 107.7 MW

FIGURE A2-2 N-1: METISKOW 648S 138/25 KV TRANSFORMER T1(BLOW UP)  
2016 WINTER PEAK (PRE-CONNECTION)  
PRINTED ON TUESDAY 10. NOVEMBER 2015

Bus - Voltage (kV) (blue)  
Branch - MV/LV (green)  
Equipment - MVA (red)  
1000V Bus (blue)  
25KV Bus (red)  
138KV Bus (blue)





# Fortis Hughenden Upgrade - P1642


SK Tie (Import): -0.1 MW BC and MATL (Import): 64.3 MW

FIGURE A2-4 N-1: 749L (EDGERTON 899S TO METISKOW 648S)

2016 WINTER PEAK (PRE-CONNECTION)


PRINTED ON TUESDAY 10. NOVEMBER 2015

Bus - Voltage (kV)  
Branch - MW/Mvar  
Equipment - MW/Mvar  
1000 MVA  
KV: <25.000 <=58.000 <=138.000 <=240.000 <=500.000 >500.000



## **Attachment B**

### **Post-Connection Power Flow Analysis Results (Scenarios 3 and 4) – Alternative 2**




Fortis Hughenden Upgrade - P1642

SK Tie (Import): -0.1 MW BC and MATL (Import): -52.4 MW

FIGURE B1-1-N-0: NORMAL OPERATION  
2017 SUMMER PEAK (POST-CONNECTION)  
PRINTED ON TUESDAY 10. NOVEMBER 2015

Bus - Voltage (kV)  
Branch - MW/MVA  
Equipment - MW/MVA  
1000 MVA  
KV: <25.000 <=58.000 <=138.000 <=240.000 <=500.000 >500.000




Fortis Hughenden Upgrade - P1642

SK Tie (Import): -0.1 MW BC and MATL (Import): 35.6 MW

FIGURE B1-2 N-1: METISKOW 648S 138/25 KV TRANSFORMER T1  
2017 SUMMER PEAK (POST-CONNECTION)  
PRINTED ON TUESDAY 10. NOVEMBER 2015

Bus - Voltage (kV)  
Branch - MW/Mvar  
Equipment - MW/Mvar  
1000 MVA  
KV: <25.000 <=58.000 <=138.000 <=240.000 <=500.000 >500.000



# Fortis Hughenden Upgrade - P1642

SK Tie (Import): -0.1 MW BC and MATL (Import): 54.7 MW


FIGURE B1-3 N-1: 7L130 (VERMILION 710S TO KITSCOTY 705S)

2017 SUMMER PEAK (POST-CONNECTION)

PRINTED ON TUESDAY 10. NOVEMBER 2015

Bus - Voltage (kV)  
Branch - MW/Mvar  
Equipment - MW/Mvar  
Load - MW/Mvar  
KV: <25.00 <=58.00 <=138.00 <=240.00 <=500.00 >500.00





Fortis Hughenden Upgrade - P1642


SK Tie (Import): -0.1 MW BC and MATL (Import): -49.6 MW

FIGURE B1-5 N-1: EDGERTON 899S TRANSFORMER T3

2017 SUMMER PEAK (POST-CONNECTION)

PRINTED ON TUESDAY 10. NOVEMBER 2015

Bus - Voltage (kV)pu  
Branch - MW/Mvar  
Equipment - MW/Mvar  
1000 MVA Base  
kV: <=25.000 <=59.000 <=138.000 <=240.000 <=500.000 >500.000



Fortis Hughenden Upgrade - P1642


SK Tie (Import): -0.1 MW BC and MATL (Import): 89.6 MW

FIGURE B2-1-N-0: NORMAL OPERATION  
2016 WINTER PEAK (POST-CONNECTION)  
PRINTED ON TUESDAY 10. NOVEMBER 2015

Bus - Voltage (kV)  
Branch - MW/Mvar  
Equipment - MW/Mvar  
1000 MVA  
KV: <25.000 <=58.000 <=138.000 <=240.000 <=500.000 >500.000







# Fortis Hughenden Upgrade - P1642


SK Tie (Import): -0.1 MW BC and MATL (Import): -46.8 MW

FIGURE B2-4 N-1: 749L (EDGERTON 899S TO METISKOW 648S)

2016 WINTER PEAK (POST-CONNECTION)

PRINTED ON TUESDAY 10. NOVEMBER 2015

Bus - Voltage (kV)  
Branch - MW/Mvar  
Equipment - MW/Mvar  
1000 MVA  
KV: <25.000 <=58.000 <=138.000 <=240.000 <=500.000 >500.000



Fortis Hughenden Upgrade - P1642

SK Tie (Import): -0.1 MW

BC and MATL (Import): 87.6 MW

FIGURE B2-5 N-1: EDGERTON 899S TRANSFORMER T3

2016 WINTER PEAK (POST-CONNECTION)


PRINTED ON TUESDAY 10. NOVEMBER 2015

Bus - Voltage (kV)  
Branch - MW/Mvar  
Equipment - MW/Mvar  
1000 MVA  
KV: <25.000 <=58.000 <=138.000 <=240.000 <=500.000 >500.000


## **Attachment C**

### **Post-Connection Voltage Stability Analysis Results (Scenarios 4) – Alternative 2**


# Hughenden 213S\_138kV Bus




Metiskow 648S\_138kV Bus



# Hardisty 377S\_138kV Bus



Sunken Lake 221S\_138kV Bus



Rosyth 296S\_138kV Bus

