

**APPENDIX E**

**AESO TRANSMISSION PLANNING CRITERIA –  
BASIS AND ASSUMPTIONS**

# Transmission Planning Criteria - Basis and Assumptions

---

Version 1.0

## 1. Introduction

This document presents the reliability standards, criteria, and assumptions to be used as the basis for planning the Alberta Transmission System. The criteria, standards and assumptions identified in this document supersede those previously established.

## 2. Transmission Reliability Standards and Criteria<sup>1</sup>

The AESO applies the following Alberta Reliability Standards to ensure that the transmission system is planned to meet applicable performance requirements under a defined set of system conditions and contingencies. A brief description of each of these standards is given below:

### 1. TPL-001-AB-0: System Performance Under Normal Conditions

Category A represents a normal system condition with all elements in service (N-0). All equipment must be within its applicable rating, voltages must be within their applicable ratings and the system must be stable with no cascading outages. Under Category A, electric supply to load cannot be interrupted and generating units cannot be removed from service.

### 2. TPL-002-AB-0: System Performance Following Loss of a Single BES Element

Category B events result in the loss of any single element (N-1) under specified fault conditions with normal clearing. The specified elements are a generating unit, a transmission circuit, a transformer or a single pole of a direct current transmission line. The acceptable impact on the system is the same as Category A with the exception that radial customers or some local network customers, including loads or generating units, are allowed to be disconnected from the system if they are connected through the faulted element. The loss of opportunity load or opportunity interchanges is allowed. No cascading can occur.

### 3. TPL-003-AB-0: System Performance Following Loss of Two or More BES Elements

Category C events result in the loss of two or more bulk electric system elements (sequential, N-1-1 or concurrent, N-2) under specified fault conditions and include both normal and delayed fault clearing. All of the system limits for Category A and B events apply with the exception that planned and controlled loss of firm load, firm transfers and/or generation is acceptable provided there is no cascading.

### 4. TPL-004-AB-0: System Performance Following Extreme BES Events

Category D represents a wide variety of extreme, rare and unpredictable events, which may result in the loss of load and generation in widespread areas. The system may not be able to reach a new stable steady state, which means a blackout is a possible outcome. The AESO needs to evaluate these events, at its discretion, for risks and consequences prior to creating mitigation plans.

### 5. FAC-014-AB-2: Establishing and Communicating System Operating Limits

The AESO is required to establish system operating limits where a contingency is not mitigated through construction of transmission facilities.

#### 2.1 Thermal Loading Criteria

The AESO Thermal Loading Criteria require that the continuous thermal rating of any transmission element is not exceeded under normal and post-contingency operating conditions. Thermal limits are

---

<sup>1</sup> A complete description of these standards are given in: AESO. *Alberta Reliability Standards*. Available from <http://www.aeso.ca/rulesprocedures/17004.html>

assumed to be 100% of the respective normal summer and winter ratings. Emergency limits are not considered in the planning evaluations.

## 2.2 Voltage Range and Voltage Stability Criteria

The normal minimum and maximum voltage limits as specified in the following table are used to identify Category A system voltage violations, while the extreme minimum and maximum limits are used to identify Category B and C system violations. Table 2-1 presents the acceptable steady state and contingency state voltage ranges for the AIES. Table 2-2 provides voltage stability criteria used to test the system performance.

**Table 2-1: Acceptable Range of Steady State Voltage (kV)**

Nominal Voltage	Extreme Minimum	Normal Minimum	Normal Maximum	Extreme Maximum
500	475	500	525	550
240	216	234	252	264
260 (Northeast & Northwest)*	234	247	266	275
144	130	137	151	155
138	124	135	145	152
72	65	68.5	75.5	79
69	62	65.5	72.5	76

**Table 2-2: Voltage Stability Criteria**

Performance Level	Disturbance (1)(2)(3)(4) Initiated by: Fault or No fault DC Disturbance	MW Margin (P-V method) (5)(6)(7)	MVAr Margin (V-Q method) (6)(7)
A	Any element such as: One Generator One Circuit One Transformer One Reactive Power Source One DC Monopole	$\geq 5\%$	Worst Case Scenario(8)
B	Bus Section	$\geq 5\%$	50% of Margin Requirement in Level A
C	Any combination of two elements such as: A Line and a Generator A Line and a Reactive Power Source Two Generators Two Circuits Two Transformers Two Reactive Power Sources DC Bipole	$\geq 2.5\%$	50% of Margin Requirement in Level A

Performance Level	Disturbance (1)(2)(3)(4) Initiated by: Fault or No fault DC Disturbance	MW Margin (P-V method) (5)(6)(7)	MVAr Margin (V-Q method) (6)(7)
D	Any combination of three or more elements. i.e.: Three or More Circuits on ROW Entire Substation Entire Plant Including Switchyard	> 0	> 0

### 2.3 Transient Stability Analysis Assumptions

Standard fault clearing times as shown in Table 2-3 are used for the new facilities or when the actual clearing times are not available for the existing facilities. Double line-to-ground faults are applied for the Category C5 events with normal clearing times. Single line-to-ground faults are applied for Category C6 to C9 events with delayed clearing times as depicted in Table 2-4 and Table 2-5.

**Table 2-3: Fault Clearing Times**

Nominal	Near End	Far End
kV	Cycles	Cycles
500	4	5
240	5	6
144/138	6	8
with telecommunications		
144/138	6	30
without telecommunications		

**Table 2-4: Stuck Breaker Clearing Times for Lines**

Fault Clearing Time			Fault Clearing Time			Fault Clearing Time		
138/144 kV			240 kV			500 kV		
Near End	Far End	2 <sup>nd</sup> Ckt (for C5 and C7 Only)	Near End	Far End	2 <sup>nd</sup> Ckt (for C5 and C7 Only)	Near End	Far End	2 <sup>nd</sup> Ckt (for C5 and C7 Only)
15	24	24	12	6	14	9	5	11

**Table 2-5: Stuck Breaker Clearing Times for Transformers**

Fault Clearing Time (Cycles)						Fault Clearing Time (Cycles)					
240/138 kV						500/240 kV					
Fault on 240 kV Side			Fault on 138 kV Side			Fault on 500 kV Side			Fault on 240 kV Side		
240 kV Side	138 kV Side	2 <sup>nd</sup> Ckt	138 kV Side	240 kV Side	2 <sup>nd</sup> Ckt	500 kV Side	240 kV Side	2 <sup>nd</sup> Ckt	240 kV Side	500 kV Side	2 <sup>nd</sup> Ckt
		(for Breaker Fail)			(for Breaker Fail)			(for Breaker Fail)			(for Breaker Fail)
12	6	14	15	5	24	9	5	11	12	4	14