

Terms and definitions to be added for use in the Alberta Reliability Standards:

balancing contingency event: means any single event described in subsections (a), (b), or (c) below, or any series of such otherwise single events with each separated from the next by one minute or less:

- (a) sudden loss of generation:
 - (i) due to:
 - (A) **generating unit** tripping;
 - (B) loss of **aggregating; generating facility** resulting in isolation from the **bulk electric system** or from the **interconnected electric system**; or
 - (C) sudden unplanned outage of a **transmission facility**; and
 - (ii) that causes an unexpected change to the **ISO's area control error**;
- (b) sudden loss of an import, due to forced outage of transmission equipment that causes an unexpected imbalance between generation and **demand** on the **Interconnection**; and
- (c) sudden restoration of a **demand** resource that causes an unexpected change to the **ISO's area control error**.