



Date of Request for Comment: <u>January 10, 2019</u> Period of Comment: <u>January 10, 2019</u> through <u>January 31, 2019</u> Comments From: <u>ENMAX Power Corporation (EPC)</u> Date [yyyy/mm/dd]: <u>2019/01/30</u>	Contact: <u>Robert Rothstein</u> Phone: <u>403-689-6507</u> Email: <u>rrothstein@enmax.com</u>
---	--

Listed below is the summary description of changes for the proposed amended PRC-023-AB-4. Please refer back to the Consultation Letter under the “Attachments” section to view materials related to the proposed amended PRC-023-AB-4. Please place your comments/reasons for position underneath (if any).

Alberta Reliability Standard	Market Participant Comments and/or Alternative Proposal
<p>Amended</p> <p>The AESO is seeking comments from market participants with regard to the following matters:</p> <ol style="list-style-type: none"> Are there any requirements contained in proposed amendments to PRC-023-AB-4 that are not clearly articulated? If yes, please indicate the specific section of proposed amendment to PRC-023-AB-4, describe the concern and suggest alternative language. Please provide any additional comments regarding proposed amendments to PRC-023-AB-4. 	<p><i>Comment # 1:</i></p> <p>R1 (b) appears to limit you to only mho function or load encroachment. Load encroachment may be required to be used with mho when load encroachment on the mho element is a concern. Suggestion is to edit sentence.</p>