

Market Participant Comment Matrix – March 23, 2017

Proposed New Alberta Reliability Standard FAC-008-AB-3, *Facility Ratings* (“new FAC-008-AB-3”)



Date of Request for Comment: <u>March 23, 2017</u>	Contact: <u>Dan Bamber</u>
Period of Comment: <u>March 23, 2017</u> through <u>April 20, 2017</u>	Phone: <u>780-509-9152</u>
Comments From: <u>ATCO Electric Ltd.</u>	Email: <u>Dan.bamber@atco.com</u>
Date: <u>April 18, 2017</u>	

Listed below is the summary description of changes for the proposed new FAC-008-AB-3. Please refer back to the Consultation Letter under the “Attachments” section to view materials related to the proposed New FAC-008-AB-3. Please place your comments/reasons for position underneath (if any).

Alberta Reliability Standard	Market Participant Comments and/or Alternative Proposal
New The AESO is seeking comments from market participants with regard to the following matters: 1. Are there any requirements contained in proposed new FAC-008-AB-3 that are not clearly articulated? If yes, please indicate the specific section of proposed new FAC-008-AB-3, describe the concern and suggest alternative language. 2. Please provide any additional comments regarding proposed new FAC-008-AB-3.	<i>ATCO Electric has the following Questions:</i> 1 <i>In the ‘Purpose’ section, the term ‘transmission system’ is used and in the ‘Applicability’ section (a)(i) the term ‘bulk electric system’ is used. Can the AESO please confirm that this ARS is only applicable to 100kV and above facilities, except for those identified by the ISO in the Applicability section (a)(ii).</i> 2 <i>Because part of the definition of Bulk Electric System in the AESO glossary states: “radial transmission facilities serving only load with one (1) transmission source are generally not included in this definition”, Can the AESO please confirm if radial transmission lines are included or excluded in this ARS. If they are either included or excluded, ATCO recommends having this documented in the ID to ensure clarity.</i>