

Date of Request for Comment: <u>February 15, 2018</u> Period of Comment: <u>February 15, 2018</u> through <u>March 15, 2018</u> Comments From: <u>ENMAX Energy Corporation</u> Date [yyyy/mm/dd]: <u>2018/03/15</u>	Contact: <u>Rose Ferrer</u> Phone: <u>403-514-3886</u> Email: <u>RFerrer@enmax.com</u>
--	---

Listed below is the summary description of changes for the proposed new PRC-005-AB-6 Please refer back to the Consultation Letter under the “Attachments” section to view materials related to the proposed new PRC-005-AB-6. Please place your comments/reasons for position underneath (if any).

Alberta Reliability Standard	Market Participant Comments and/or Alternative Proposal
New The AESO is seeking comments from market participants with regard to the following matters: <ol style="list-style-type: none"> Are there any requirements contained in proposed PRC-005-AB-6 that are not clearly articulated? If yes, please indicate the specific section of proposed PRC-005-AB-6, describe the concern and suggest alternative language. Please provide any additional comments regarding proposed PRC-005-AB-6. 	<p><u>Comment # 1:</u></p> <p><u>Table 1-4 (a), (b), and (c) – Maintenance Activities and Intervals for Protection Systems</u></p> <p>Under Maintenance Activities:</p> <p>Verify:</p> <p><input type="checkbox"/> Station dc supply voltage</p> <p><u>Comment:</u></p> <p>EEC would like clarity regarding the 4 month maximum maintenance interval activity for the station DC supply voltage.</p> <p>Q1: Is the battery charger system voltage adequate to meet the “Verify” component of the “Station DC supply voltage”?</p> <p>Q2: Is the AESO expecting participants to measure the cell/bank voltage?</p>