

**Proposed Amended Alberta Reliability Standard PRC-023-AB-4,
Transmission Relay Loadability (“PRC-023-AB-4”)**

Date of Request for Comment:	January 10, 2019	
Period of Consultation:	January 10, 2019	through January 31, 2019

Alberta Reliability Standard	Market Participant Comments and/or Alternative Proposal	AESO Replies
<p>Amended</p> <p>The AESO is seeking comments from market participants with regard to the following matters:</p> <ol style="list-style-type: none"> Are there any requirements contained in proposed amendment to PRC-023-AB-4 that are not clearly articulated? If yes, please indicate the specific section of proposed amendment to PRC-023-AB-4, describe the concern and suggest alternative language. Please provide any additional comments regarding proposed amendment to PRC-023-AB-4. 	<p><u>ENMAX Power Corporation (“EPC”)</u></p> <ol style="list-style-type: none"> R1 (b) appears to limit you to only mho function or load encroachment. Load encroachment may be required to be used with mho when load encroachment on the mho element is a concern. Suggestion is to edit sentence. 	<ol style="list-style-type: none"> The ISO has revised the wording in R1(b) to remove the reference to the mho function. This will allow the load encroachment function to be applied as needed. a load encroachment function within protection relays may be used to meet (a) and (b).