

Date of Request for Comment:	<u>September 18, 2018</u>
Period of Consultation:	<u>September 18, 2018</u> through <u>October 3, 2018</u>

Alberta Reliability Standard	Market Participant Comments and/or Alternative Proposal	AESO Replies
<p>Retirement</p> <p>The AESO is seeking comments from market participants with regard to the following matters:</p> <ol style="list-style-type: none"> 1. Are there any requirements contained in proposed retirement of existing PRC-018-AB-1 that are not clearly articulated? If yes, please indicate the specific section of retirement of existing PRC-018-AB-1, describe the concern and suggest alternative language. 2. Please provide any additional comments regarding retirement of existing PRC-018-AB-1. 	<p><u>TransAlta Corporation (“TransAlta”)</u></p> <ol style="list-style-type: none"> 1. TransAlta requests the AESO transfer the Disturbance Monitoring Equipment list published in accordance with R1 of PRC-018 to be associated with proposed new PRC-002-AB-2. 	<ol style="list-style-type: none"> 1. The equipment on the Disturbance Monitoring Equipment list published in accordance with R1 of PRC-018-AB-1 may not be the same as the equipment identified under requirement R5 of PRC-002-AB-2. Hence, the AESO will maintain the published list per PRC-018-AB-1 requirement R1 until the retirement of that reliability standard. <p>In accordance with PRC-002-AB-2 requirement R5, once the reliability standard is effective, the AESO will notify all legal owners of identified system elements on the bulk electric system, within 90 days of completion of requirement R5.1 that their respective system elements on the bulk electric system require dynamic disturbance recording data when requested. The AESO does not currently intend to publish a list of those identified system elements on the bulk electric system on the website.</p>