

Proposed new Alberta Reliability Standards PRC-010-AB-2, Under Voltage Load Shedding (“PRC-010-AB-2”)

Date of Request for Comment:	<u>February 27, 2020</u>	
Period of Consultation:	<u>February 27, 2020</u>	through <u>March 25, 2020</u>

Alberta reliability standard	Stakeholder Comments and/or Alternative Proposal	AESO Replies
<p>New</p> <p>The AESO is seeking comments from stakeholders with regard to the following matters:</p> <ol style="list-style-type: none"> 1. Are there any requirements contained in proposed new PRC-010-AB-2 to that are not clearly articulated? If yes, please indicate the specific section of proposed new PRC-010-AB-2, describe the concern and suggest alternative language. 2. Please provide any additional comments regarding proposed proposed new PRC-010-AB-2. 	<p><u>ATCO Electric Ltd.</u></p> <ol style="list-style-type: none"> 1. ATCO Electric would like to confirm our understanding that the proposed UVLS schemes that may be considered / developed under the PRC-010-AB-2 standard would be separate to any Remedial Action Schemes (RAS) that are or may be in place. This understanding is based on the current RAS definition as per AESO Glossary 	<ol style="list-style-type: none"> 1. The AESO confirms that the “under voltage load shed program” referenced in the proposed new PRC-010-AB-2 is separate from remedial action schemes. The AESO anticipates publishing a list on its website that contains each “under voltage load shed program”.