Part 200 Markets Division 205 Ancillary Services Section 205.6 Supplemental Reserve Technical Requirements and Performance Standards



Final Draft

Applicability

- 1 Section 205.6 applies to:
 - (a) a pool participant; and
 - (b) the ISO,

in relation to qualifying for, providing and utilizing supplemental reserve.

Requirements

General Application for Qualification to Provide Supplemental Reserve

- 2(1) A pool participant asset must be qualified by the ISO in order to provide that provides or anticipates providing supplemental reserve, must satisfy the technical requirements set out in this section 205.6 and must continue to satisfy such technical requirements while providing supplemental reserve.
- (2) A pool participant seeking to have a pool asset qualified by the ISO to provide supplemental reserve must provide the ISO with:
 - (a) a completed application form, available on the AESO website; and
 - (b) the data and records that the **ISO** specifies in the application form.

Minimum Pool Asset Requirements Eligibility to Provide Supplemental Reserve

- **3(1)** A **pool participant** seeking to have a **pool asset** qualified by the **ISO** to provide **supplemental reserve** must ensure that its **pool asset** has at least one (1) **supplemental reserve resource** that is at a minimum, is capable of providing:
 - (a) <u>5 MW</u> in the case of supplemental reserve sourced from within the balancing authority area of the ISO, a minimum of five (5) MW of supplemental reserve; and
 - (b) the amount of real power applied for under subsection 2(2) for a period of sixty

 (60) minutesin the case of supplemental reserve sourced from outside the balancing authority area of the ISO, a minimum of ten (10) MW of supplemental reserve.
- (2) A pool participant must ensure that its pool asset is capable of providing the amount of real power the ISO qualifies the pool asset to provide under subsection 4(1) for the period from ten (10) minutes after receiving a directive to provide supplemental reserve to sixty (60) minutes after receiving a directive to provide supplemental reserve.
- (3) A pool participant must ensure that the **pool asset** complies with subsections 3(1) and 3(2) by measuring the gross **real power** of the **pool asset**.

ISO QualifyingQualification of a Pool Asset to Provide Supplemental Reserve

- **4(1)** The ISO <u>may qualify a must, prior to any</u>**pool asset** <u>to provideing supplemental reserve if one (1) or more supplemental reserve resources of the pool asset meet the eligibility criteria set out in subsection 3, assess the eligibility of such pool asset and determine the real power in MW it is qualified to provide.</u>
- (2) The ISO must, <u>after qualifying a pool asset under subsection 4(1)</u>, in determineing the real power quantity in MW that each <u>supplemental reserve resource</u> of the pool asset is <u>capable of</u>

Part 200 Markets Division 205 Ancillary Services Section 205.6 Supplemental Reserve Technical Requirements and Performance Standards



providingqualified to provide, with consideration given to the following:

- (a) whether the <u>supplemental reserve resourcepool asset</u> participates in a <u>remedial action</u> scheme;
- (b) the total operating reserve that could be lost during a single contingency; and
- (c) the maximum **real power** capability and minimum **real power** capability <u>of each</u> <u>supplemental reserve resource</u> of the **pool asset**; <u>and</u>
- (d) any other factor that the **ISO** considers relevant.
- (3) The ISO must advise a pool participant whether itsof the eligibility of the pool asset is qualified to provide supplemental reserve within sixty (60) days of the ISO receiving an a completed application under subsection 2(2) for supplemental reserve.

Applying Performance Requirements when under Dispatch to Provide Supplemental Reserve

- 5(1) A pool participant must ensure that, following the receipt of a dispatch may apply to provide supplemental reserve by completing and providing to the ISO the documents the ISO specifies and posts on the AESO website., one (1) or more supplemental reserve resources of the pool asset are positioned to provide the real power set out in the dispatch, within a total tolerance of minus:
 - (a) 1 MW for a **dispatch** of less than or equal to 20 MW; or
 - (b) 5% of the **dispatch** quantity for a **dispatch** greater than 20 MW.
- (2) A pool participant must ensure that each supplemental reserve resource being used to provide supplemental reserve meets the requirements set out in subsection 5(1) beginning at:
 - (a) the time stated in the **dispatch**, for a **dispatch** with a time more than fifteen (15) minutes from the time the **pool participant** receives the **dispatch**; or
 - (b) the time stated in the **dispatch** or as soon as possible thereafter, but in any event, not more than fifteen (15) minutes after receiving the **dispatch**, for a **dispatch** with a time fifteen (15) minutes or less from the time the **pool participant** receives the **dispatch**.
- (3) A pool participant will not be paid for supplemental reserve unless the pool participant ensures that the supplemental reserve resources being used to provide supplemental reserve meet the requirements set out in subsections 5(1) and 5(2).

Performance Requirements when Responding to a Directive to Provide Supplemental Reserveto a Dispatch

- **6(1)** A **pool participant** must, within ten (10) minutes following receipt of a **directive** to provide **supplemental reserve**, ensure that its **pool asset** is providing a quantity of **real power** equal to the instantaneous amount of **real power** of the **pool asset** at the time of the **directive** and the amount of **real power** set out in the directive will not be paid for **supplemental reserve** unless the **pool participant** ensures that:
 - (a) upon receipt of a **dispatch** to provide **supplemental reserve**, if the time stated in the **dispatch** for the pool asset to be in position to provide the **real power** quantity indicated in the **dispatch** is:
 - (i) more than fifteen (15) minutes from the time the **pool participant** receives the **dispatch**, the **pool asset** is in position at the time stated in the **dispatch**; or
 - (ii) fifteen (15) minutes or less from the time the pool participant receives the dispatch, the

Part 200 Markets Division 205 Ancillary Services Section 205.6 Supplemental Reserve Technical Requirements and Performance Standards



pool asset is in position at the time stated in the **dispatch** or as soon as possible thereafter but in any event, not more than fifteen (15) minutes after receiving the **dispatch**; and

- (b) the **pool asset** maintains the ability to provide the **real power** quantity corresponding to the **dispatch** quantity, as measured in accordance with subsection 3(3):
 - (i) by the times set out in subsections 6(1)(a)(i) or (ii); and
 - (ii) within a tolerance of minus:
 - (A) one (1) MW for a dispatch of less than or equal to twenty (20) MW; or
 - (B) five percent (5%) for a dispatch greater than twenty (20) MW;

for as long as the dispatch is in effect.

- (2) A pool participant must ensure that, from the first time its pool asset achieves the response set out in subsection 6(1) to the time fifteen (15) minutes following receipt of the directive, the pool asset is providing an average response equal to or greater than the amount of real power set out in the directive.
- (3) A pool participant must ensure that, for each consecutive ten (10) minute interval beginning fifteen (15) minutes following the receipt of a directive, the average response from the pool asset equals the amount of real power set out in the directive, within a tolerance of plus or minus:
 - (a) 5 MW for a pool asset with a maximum capability of 200 MW or less; or
 - (b) 10 MW for a **pool asset** with a **maximum capability** of greater than 200 MW.
- (4) Where a **pool asset** does not have a **maximum capability**, the tolerances set out in subsection 6(3) will be measured against the maximum qualified facility capacity of the **pool asset** prescribed by the **ISO**.
- (5) A pool participant must ensure that its pool asset continues to meet the requirements set out in subsection 6(3) for as long as the directive to provide supplemental reserve is in effect.
- (6) A pool participant must ensure that its pool asset is in the position set out in subsection 5(1) as soon as possible or, in any event, not more than fifteen (15) minutes after receiving a cancellation of the directive for supplemental reserve.

Performance Requirements Measuring Response to a Directive

- **7(1)** A **pool participant** must, within ten (10) minutes after receiving a directive to provide supplemental reserve, ensure that <u>each</u> the **pool asset** complies with the requirements set out in subsection 6 as measured at:is providing a quantity of **real power** equal to the instantaneous amount of **real power** of the **pool asset** at the time of the **directive** plus the amount of **real power** set out in the **directive**, as measured in accordance with subsection 3(3).
 - (a) the stator winding terminals of the generating unit;
 - (b) the circuit breaker or disconnection device that is electrically closest to each load;
 - (c) the alternating current terminal closest to each inverter based technology;
 - (d) the collector bus for aggregated generating facilities; or
 - (e) a point designated by the **ISO**.
- (2) A pool participant must ensure that, from the first time the pool asset achieves the quantity of real power set out in subsection 7(1) to the time fifteen (15) minutes after the time of the directive, the

Part 200 Markets Division 205 Ancillary Services Section 205.6 Supplemental Reserve Technical Requirements and Performance Standards



average quantity of **real power** provided by the **pool asset** is equal to or more than the quantity set out in subsection 7(1), as measured in accordance with subsection 3(3).

- (3) A pool participant of a pool asset must ensure that, for each consecutive ten (10) minute interval starting fifteen (15) minutes following the receipt of a directive, the average real power from the pool asset equals the quantity set out in subsection 7(1), as measured in accordance with subsection 3(3), within a tolerance of:
 - (i) five (5) MW for a load **pool asset** or a generating **pool asset** with a **maximum capability** of two hundred (200) MW or less; or
 - (ii) ten (10) MW for a **pool asset** with a **maximum capability** of greater than two hundred (200) MW.
- (4) Notwithstanding subsection 3(2), a **pool participant** must ensure the **pool asset** continues to provide the average **real power** set out in subsection 7(3) for as long as the **directive** is in effect.
- (5) Notwithstanding subsections 7(1) through 7(4), a **pool participant** following the receipt of a **directive** for **supplemental reserve** to zero (0) must as soon as possible after receiving the **directive** to zero (0) MW, and, in any event, not more than fifteen (15) minutes after receiving the **directive** to zero (0) MW:
 - (a) ensure the generating pool asset is within the allowable dispatch variance of its current energy dispatch; or
 - (b) ensure the load **pool asset** is in position to provide the **real power** quantity indicated in its current **dispatch** for **supplemental reserve**.

Test Requirements

- The **ISO** may request that a pool participant to test a supplemental reserve resource its pool asset's responses to dispatches and directives:
 - (a) prior to allowing the <u>supplemental reserve resourcepool asset</u> to provide **supplemental reserve**; or
 - (b) if the **ISO** provides evidence that the **supplemental reserve** <u>resource</u> exhibits behaviour that is inconsistent with the requirements of this <u>sSection 205.6</u>; or
 - (c) if the ISO otherwise determines that such testing is necessary.

Maintaining Eligibility to Provide Supplemental Reserve

- **9(1)** The **ISO** may <u>issue a notice suspending the ability of, if</u> a **pool participant** <u>to provide</u> <u>supplemental reserve</u> if the <u>pool participant</u> does not <u>refuses to comply</u> with:
 - (a) refusing to comply with a testing request pursuant to subsection 8;
 - (b) any other provision of this Section 205.6; or
 - (c) other **ISO rules** that affect the provision of **supplemental reserve**;

provide notice to the **pool participant** that it cannot participate in the **supplemental reserve** market until the **pool participant** is compliant with this section 205.6 and all other **ISO rules** that affect the provision of **supplemental reserve**.

ISO Rules Part 200 Markets Division 205 Ancillary Services Section 205.6 Supplemental Reserve Technical Requirements and Performance Standards



(2) A pool participant that has received a <u>suspension</u> notice pursuant to subsection 9(1) <u>mustmay</u> not submit an **offer** for **supplemental reserve** until the **ISO** confirms the **pool participant** is compliant with this <u>sS</u>ection 205.6 and all other **ISO rules** that affect the provision of **supplemental reserve**.

Revision History

Effective Date	Description
2018-02-01	Revised requirements to be technology agnostic.
2014-12-23	Initial release