

ISO Rules

Part 300 System Reliability and Operations

Division 305 Contingency and Emergency

Section 305.1 Energy Emergency Alerts



External Consultation Draft

August 3, 2018

Applicability

- 1 Section 305.1 applies to:
- (a) an **electricity market participant**; and
 - (b) the **ISO**.

Requirements

Issuing Energy Emergency Alerts

- 2(1) The **ISO** must, during a supply shortfall event, declare an energy emergency alert.
- 2(2) The **ISO** must, when a supply shortfall event ends, cancel the energy emergency alert 0.

Communications

- 3(1) The **ISO** must communicate to **market participants** the declaration, modification or termination of an energy emergency alert.
- 3(2) An **electricity market participant** must communicate an energy emergency alert within their organizations as appropriate.
- 3(3) An **electricity market participant** must verbally notify the **ISO** of any work that increases the risk of tripping a **generating unit**, an **aggregated generating facility** or an **intertie**, or of constraining generation.

Revision History

Effective	Description
xxxx-xx-xx	Revision to clarify “ market participant ” as “ electricity market participant ” Subsections 2(a), (b) and (c) removed Administrative revisions.
2014-01-01	Amended to remove reference to the WECC Reliability Coordinator, clarify Energy Emergency Alert 0 declarations and incidental amendments.
2012-10-31	Initial release