

ISO Rules

Part 300 System Reliability and Operations

Division 306 Outages and Disturbances

Section 306.3 Load Planned Outage Reporting



External Consultation Draft
August 31, 2018

Applicability

- 1 ~~This section~~Section 306.3 applies to:
- (a) an electricity market participant with a load sink asset; and
 - (b) the ISO.

Requirements

Load Planned Outage Reporting

2(1) Subject to subsection 2(2), an electricity market participant who has a planned decrease in its capability to consume load at a facility of ~~forty (40)~~ MW or greater, must comply with the **planned outage** reporting requirements of this section 306.3.

~~(2) Subsection 2(1) does not apply if the market participant has documented the decrease in a restated **available capability** for the facility, in accordance with section 203.3 of the ISO rules, Restatements for Energy.~~

(32) The electricity market participant referred to in subsection 2(1) must submit to the ISO the following **planned outage** information, in a form the ISO approves and publishes on the AESO website:

- (a) the commencement date and time of the **planned outage**, but not where such date and time is historical;
- (b) the end date and time of the **planned outage**; and
- (c) the actual decrease, in MW, in the load capability.

(43) The electricity market participant must submit the information to the ISO as soon as reasonably practicable after the electricity market participant is aware of the **planned outage** information.

(54) Subsequent to the ISO receiving from electricity market participants the submissions referred to in subsection 2(~~32~~), on each **business day** the ISO must aggregate all **planned outage** records for loads as submitted, and determine the aggregate daily **planned outages** in MW which the ISO will calculate as:

the sum of MWh of all submitted **planned outages** by time period;

divided by

the number of hours in the time period.

(65) Once the ISO has determined the aggregate daily **planned outages** under subsection 2(~~54~~), the ISO also must prepare a daily **planned outage** report and publish it each **business day** on the AESO website, which report must include:

- (a) the time and date the report was prepared; and
- (b) the daily average **planned outage** amount in MW, rounded to the nearest MW, for each **business day** of the then current **month** and the next ~~three (3) successive~~3 successive months.

ISO Rules

Part 300 System Reliability and Operations

Division 306 Outages and Disturbances

Section 306.3 Load Planned Outage Reporting



(76) Subject to subsection 2(**87**), the **ISO** must keep confidential all **planned outage** information for loads submitted to it under this section 306.3, except as otherwise required to be made public under the provisions of section 103.1 of the **ISO rules**, *Confidentiality*.

(87) The **ISO** must publish on the AESO website the aggregate daily **planned outage** report in a manner that, in accordance with section 103.1 of the **ISO rules**, *Confidentiality*, seeks to preserve the confidential nature of any **planned outage** information as submitted by any one **electricity market participant**, and precludes the identification of any one **electricity market participant**, or other directly affected **pool participant**.

Revision History

Effective	Description
<u>XXXX-XX-XX</u>	<u>Revision to clarify “market participant” as “electricity market participant”.</u> <u>Removal of subsection 2(2)</u>
2014-07-02	Renumbered from section 208.1 of the ISO rules to section 306.3 of the ISO rules; unbolded all references to “load” and “loads”; and replaced references to “outage” with “planned outage”.
2013-01-08	Removed reference to section 3.5 <i>Offers and Bids</i> , and replaced with section 203.3 <i>Restatements for Energy</i> .
2011-09-30	Initial Release