

RENEWABLE ENERGY AND ENERGY STORAGE MARKET OPPORTUNITIES

05 November 2020

Presentation to Bulk and Regional Tariff Team

Introduction and Outline

2

- AESO held:
 - ▣ March 13, 2020
 - Bulk and Regional Tariff Design Stakeholder Engagement 1
 - ▣ Delay for 6 months
 - ▣ September 24, 2020
 - Bulk and Regional Tariff Design Stakeholder Engagement Session 2
 - ▣ October 14, 2020
 - Joint Stakeholder Engagement session on Energy Storage and Distributed Energy Resources (DER) This presentation focused on the aspect of renewable energy and energy storage
 - Bulk and Regional Tariff Design Technical Information Session

Paula McGarrigle


Solas Energy Consulting Inc.

www.solasenergyconsulting.com

2020-10-30



What is Storage?



Is it a Load, Generator, Transmission facility/Substation?

4

- Guiding documents
 - Section 1(1)(u) of *Electric Utilities Act* (EUA)
 - Section 1(1)(bbb) of EUA
 - Section 1(1)(k) of *Hydro and Electric Energy Act* (HEEA)
 - Section 1(1)(n) of HEEA
 - AUC's *Electric Transmission Facilities Process Guidelines*
- No references to Storage in any document
- **Energy storage fits best with the definition of the EUA “substation”**

2020-10-30

What is Storage? – Is it a generation facility under EUA? – It's not a generator

5

Reference	Definition	Energy Storage
EUA “generating unit”	<i>component of a power plant that produces, from any source, electric energy and ancillary services, and includes a share of the following associated facilities that are necessary for the safe, reliable and economic operation of the generating unit</i>	Energy storage does not produce electric energy, but rather stores electric energy. <u>Energy storage provides ancillary services</u> , but not through the production of electricity, but rather through the injection of electricity.
	<i>Fuel and Fuel handling equipment</i>	Energy storage does not have fuel
	<i>Cooling water facilities</i>	Not applicable
	<i>Switch yards</i>	Switches are included in the balance of system of the energy storage system, but not a switch yard
	<i>Other items</i>	Energy storage balance of system are included here.

2020-10-30

What is Storage? – Is it a Transmission Facility, under EUA? – It's not a transmission facility.

6

Reference	Definition	Energy Storage
EUA “Transmission facility”	<i>arrangement of conductors and transformation equipment that transmits electricity from the high voltage terminal of the generation transformer to the low voltage terminal of the step-down transformer operating phase to phase at a nominal low voltage level of more than 25 000 volts to a nominal low voltage level of 25 000 volts or less</i>	Not applicable. Voltages in the energy storage facility are lower than those identified in this definition.
	<ul style="list-style-type: none"> (i) <i>transmission lines energized in excess of 25 000 volts,</i> (ii) <i>insulating and supporting structures,</i> (iii) <i>substations, transformers and switchgear,</i> (iv) <i>operational, telecommunication and control devices</i> (v) <i>all property of any kind used for the purpose of, or in connection with, the operation of the transmission facility....</i> 	<ul style="list-style-type: none"> (i) Not applicable (ii) Not applicable (iii) Connects to the substation and includes transformers (iv) Includes telecommunication and control devices (v) The energy storage facility is not associated with the operation of the transmission facility.

What is Storage? Is it a Power Plant or a substation under HEEA?
– It's not a power plant. **BEST FIT IS SUBSTATION.**

7

Reference	Definition	Energy Storage
HEEA "Power Plant"	<i>facilities for the generation and gathering of electric energy from any source</i>	The energy storage facility does not generate electricity , but rather stores electricity. The energy storage facility <u>does potentially gather electric energy</u> but does not gather electricity like a conductor or collector system.
HEEA "substation"	<i>part of a transmission line that is not a transmission circuit and includes equipment for transforming, compensating, switching, rectifying or inverting of electric energy flowing to, over or from the transmission line</i>	The energy storage facility includes equipment for <u>transforming and inverting</u> of electric energy flowing to or from the transmission line. The energy storage facility does not include compensating equipment.

ES receives an asset ID to participate in the market (Energy and A/S)

2020-10-30



Maslow's Hammer – cognitive bias with a familiar tool

8

"I suppose it is tempting, if the only tool you have is a hammer, to treat everything as if it were a nail." –

▣ Abraham Maslow – 1966



2020-10-30

AESO Approach to Energy Storage

9

- Apply Demand Transmission Service to Energy Storage Charging
- Apply Supply Transmission Service to Energy Storage Discharging


2020-10-30



Seven (7) Components of DTS

10

- ▣ Bulk System Charge
 - Coincident metered demand - $\text{\$/MW/Month}$ for MW at coincident peak
 - Metered energy - $\text{\$/MWh}$ of metered demand
- ▣ Regional System Charge
 - Billing capacity - $\text{\$/MW/Month}$ of demand
 - Metered energy - $\text{\$/MWh}$ of metered demand
- ▣ Point of Delivery Charge
 - Substation fraction - $\text{\$/MW/Month}$ based on the share of DTS over the total of all DTS and STS in substation
- ▣ Operating Reserve Charge Estimate - $\text{\$/MWh}$ to cover AESO procurement of Operating Reserves
- ▣ Transmission Constraint Rebalancing Charge Estimate - $\text{\$/MWh}$ (minimal charge)
- ▣ Voltage Control Charge - $\text{\$/MWh}$ (minimal charge)
- ▣ Other System Support Services Charge - $\text{\$/MWh}$ (minimal charge)



These charges
form most of
the DTS bill

2020-10-30

Two (2) Components of STS

11

- Losses Charge

Metered Energy x Pool Price x Loss Factor

- Regulated Generating Unit Connection Cost

- Only for regulated units - \$/MW

2020-10-30

DOUBLE DOUBLE

12




Double Cream
Double Sugar

2020-10-30

DOUBLE, DOUBLE ISSUE – UNFAIR, UNECONOMIC, UNCOMPETITIVE.

Charging DTS and STS on Energy Storage doubles up the charges on this electricity.

13



Generators pay STS. These electrons have paid for STS [$e^- (STS)$]

Load receives electrons that have already been loaded with STS. [$e^- (STS)$]

Then load pays **DTS** so the final consumed electrons have had both STS and **DTS** payments [$e^- (STS/DTS)$]

Energy storage currently gets charged **DTS** to charge (treated as a load) and the same electricity delivered back to the grid is also charged **STS**.

Now we have $e^- (STS/DTS/STS)$

Load purchasing from the storage facility through the grid would now have to pay **DTS**, on top of electricity that has already now paid **DTS**, and **STS** twice. DOUBLE DOUBLE

Power used from energy storage has had twice the **DTS** and the **STS** applied.

This does not align with Fair, Efficient, and Openly Competitive

2020-10-30



Treatment of Electrons

14

Electrons from the AIES

e^- (STS/DTS)

FEOC = YES

Electrons that have been through
Storage

e^- (STS/DTS/STS/DTS)


FEOC = NO

2020-10-30

Session 1 – Option 1 identified for Storage

(as a market asset and not as a transmission asset)

15

AESO SUGGESTED OPTIONS	IMPACT ON ENERGY STORAGE	
1. Charge based flows DTS for inflows and STS for outflows (current tariff)	DOUBLE DOUBLE all the time.	


FEOC = NO

2020-10-30

Session 1 – Option 2 identified for Storage

(as a market asset and not as a transmission asset)

16

AESO SUGGESTED OPTIONS	IMPACT ON ENERGY STORAGE	
2. No DTS costs while providing “Market Services (FERC Order 841 treatment)”	DOUBLE DOUBLE sometimes, even if you are not profitable.	


FEOC = NO

2020-10-30

Session 1 – Option 3 identified for Storage

(as a market asset and not as a transmission asset)

17

AESO SUGGESTED OPTIONS	IMPACT ON ENERGY STORAGE	
<p>3. Interruptible service with lower rate, since storage can be off if transmission system is stressed.</p> <p>Direct physical control by AESO, asset can be tripped off without notice (AESO has certainty)</p> <p>Dispatch control based on bids and offers: Financial incentive to comply (not full certainty)</p> <p>May not qualify for Operating Reserves or FFRSi, - incompatible with current A/S requirements</p>	<p>Slightly cheaper</p> <p>DOUBLE DOUBLE,</p> <p>significant uncertainty, and less control of asset.</p>	
		<p>FEOC = NO</p>


Conclusion

18

- ❑ The application of DTS and STS to energy storage does not comply with FEOC
- ❑ Adding DTS/STS to energy storage creates a Double Double scenario for energy to customers of energy storage.
- ❑ Energy storage is most consistent with Substation definition under the current laws/regulations
- ❑ Energy storage is heavily disadvantaged under any of the proposed tariff schemes including DTS/STS
- ❑ Energy Storage Administration fee (rather than DTS/STS) is most appropriate.
- ❑ None of the options presented by the AESO are appropriate for Energy Storage

2020-10-30





Case Options

20

Generation	None	Wind	Solar			
Storage Location	At Generation	On Grid	At Customer			
Storage Timing	Standard	Perfect Forecast				
Substation Fraction	1.0	0.5	0.1			
Tariff Type	Current	FERC 841	Interruptible			
Region	NW	NE	Edmonton	Central	Calgary	South
Peak	12 CP	Regional 120 CP	System 120 - CP	System- Weekly CP		

2020-10-30



Case 1A: BESS ON GRID

21

Generation	None	Wind	Solar			
Storage Location	At Generation	On Grid	At Customer			
Storage Timing	Standard	Perfect Forecast	Charge during historical average low hours (HE 2,3,4,5) Discharge during historical average high hours (HE 15,16,17,18)			
Substation Fraction	1.0	0.5	0.1			
Tariff Type	Current	FERC 841	Interruptible			
Region	NW	NE	Edmonton	Central	Calgary	South
Peak	12 CP	Regional 120 CP	System 120 - CP	System- Weekly CP		


2020-10-30

CASE 1A

Use Case: Arbitrage, Tx/Dx connected, 4 hours storage

Tariff: Current Tariff

22



- Physical Meter
- Measurement Point
- Dispatch Point

Case Details


- 15 MW/60 MWh Storage
- 0 MW Generation
- Charge from Grid
- Discharge to Grid
- STS based on injecting near Blackspring Ridge
- DTS Substation Fraction POD equal to 1

Using 2016-2018 AESO data provided in the Tariff Bulk and Regional Impact Hourly Model

2020-10-30


Case 1a: Production Profile & Costs

23



Case 1a: Current Tariff is cost prohibitive for Standalone BESS

24



- DTS Regional System Charge and DTS Substation Fraction Charge are the largest components of annual expense
- Simple cash flow analysis shows negative cash flow. Does not cover system costs (Energy, DTS, STS, AESO Trading Charge)

Year	Average Cost (\$/MWh)	Average Revenue (\$/MWh)
2018	-102	+96
2019	-97	+76
2020	-104	+60

Case 1B: BESS ON GRID – Perfect Forecast

25


Generation	None	Wind	Solar			
Storage Location	At Generation	On Grid	At Customer			
Storage Timing	Standard	Perfect Forecast	Charge during the lowest hours, discharge during highest hours			
Substation Fraction	1.0	0.5	0.1			
Tariff Type	Current	FERC 841	Interruptible			
Region	NW	NE	Edmonton	Central	Calgary	South
Peak	12 CP	Regional 120 CP	System 120 - CP	System- Weekly CP		

THIS ONE CHANGED
FROM CASE 1A to 1B

2020-10-30


Case 1b: Production Profile & Costs

26



Case 1 B: Perfect foresight is insufficient to make BESS economic.

27



- 1/3 of years has negative simple cash flow. Cashflow is insufficient for covering capital costs.

Year	Average Cost (\$/MWh)	Average Revenue (\$/MWh)
2018	-110	+130
2019	-107	+128
2020	-118	+86

Case 1A: BESS ON GRID

28

Generation	None	Wind	Solar			
Storage Location	At Generation	On Grid	At Customer			
Storage Timing	Standard	Perfect Forecast	Charge during historical average low hours (HE 2,3,4,5) Discharge during historical average high hours (HE 15,16,17,18)			
Substation Fraction	1.0	0.5	0.1			
Tariff Type	Current	FERC 841	Interruptible			
Region	NW	NE	Edmonton	Central	Calgary	South
Peak	12 CP	Regional 120 CP	System 120 - CP	System- Weekly CP		

What's the impact of this?


2020-10-30



Massive DTS substation fraction costs push BESS locations to substations with other generators/loads (urban/industrial). But still uneconomic!


29

Current tariffs




Case Options – 5 options reviewed by AESO

30



Impact of AESO Tariff Cases




CASE 2A

Use Case: BESS + Wind, Arbitrage, Tx connected, 4 hours storage

Tariff: Current Tariff

32




Case Details:

- 15 MW/60 MWh Storage
- 300 MW Generation
- Transformer: 300 MW
- Charge from Wind Only
- Discharge to Grid

2020-10-30

Case 2a: BESS improves revenue, but not sufficient for positive economics. Hybrid BESS has better, but insufficient, economics than standalone BESS.



Year:	No BESS	With BESS
2019		
Total Revenue	\$30.7M	\$31.3M
Total STS	-\$1.2M	-\$1.2M
Charges	Does not include BESS operating costs, or BESS capital costs.	
Simple Cash Flow	\$29.5M	\$30.0M

No incremental DTS or STS


2020-10-30

CASE 3A

Use Case: BESS + Solar, Arbitrage, Tx connected, 4 hours storage

Tariff: Current Tariff

34



- Physical Meter
- Measurement Point
- Dispatch Point


Case Details:

- 15 MW/60 MWh Storage
- 300 MW Generation
- Transformer: 300 MW
- Charge from Solar Only
- Charges starting at sunrise
- Discharge to Grid starting at HE 13

2020-10-30

Case 3a: BESS improves revenue, but not sufficient for positive economics. Hybrid BESS has better, but insufficient, economics than standalone BESS.

35



Year:	No BESS	With BESS
2019		
Total Revenue	\$28.7M	\$28.9M
Total STS Charges	-\$1.1M	-1.1M
Simple Cash Flow	\$27.6M	\$27.8M

2020-10-30



Does not include BESS operating costs, or BESS capital costs.

No incremental DTS or STS