ISO Rules Part 500 Facilities

Division 503 Technical & Operating Requirements Section 503.18 Operation and Maintenance of Facilities



Applicability

- 1 Section 503.18 applies to:
 - (a) the legal owner and operator of a generating unit, aggregated facility, or energy storage resource that is directly connected to the transmission system or to transmission facilities within the City of Medicine Hat, including a generating unit, aggregated facility, or energy storage resource situated within an industrial complex that is directly connected to the transmission system;

and

(b) the ISO.

Requirements

Operation and Maintenance

- **2(1)** This subsection 2 does not apply to:
 - (a) excitation systems;
 - (b) automatic voltage regulators; or
 - (c) power system stabilizers.
- (2) The legal owner must operate and maintain the generating unit, aggregated facility, or energy storage resource to comply with the applicable technical design requirements of Division 503 of the ISO rules for so long as the generating unit, aggregated facility, or energy storage resource remains electrically connected.
- (3) The **operator** must, if it determines that any equipment required to meet the technical design requirements of an applicable **ISO rule** has become unavailable or is otherwise no longer meeting those requirements, notify the **ISO**, in writing, in accordance with subsection 2(4) no later than one **business day** after making such a determination.
- (4) The **operator** must include the following information in the notification to the **ISO** under subsection 2(2):
 - (a) a description of the cause of the equipment unavailability or the reason that the equipment no longer meets the technical design requirements;
 - (b) a plan to address the issue identified under subsection 2(3), including testing; and
 - (c) the expected date and time at which the issue identified under subsection 2(3) will be resolved.
- (5) The **operator** must, if the issue identified under subsection 2(3) is not resolved by the expected date and time provided in accordance with subsection 2(4), notify the **ISO** in writing, no later than one **business day** after the original expected date and time, of the reason why the issue was not resolved by the expected date and time, and provide the **ISO** with a revised date and time under subsection 2(4)(c).
- (6) The **operator** must notify the **ISO** no later than one **business day** after the issue identified under subsection 2(3) has been resolved.
- (7) The operator of:

ISO Rules Part 500 Facilities

Division 503 Technical & Operating Requirements Section 503.18 Operation and Maintenance of Facilities



- (a) multiple generating units or synchronous energy storage resources within a single complex; or
- (b) an aggregated facility containing an energy storage resource;

must, as soon as practicable, verbally notify the **ISO** when it determines that the auxiliary systems are configured such that multiple **generating units** or **energy storage resources** will trip or go off-line for a single **contingency** within the facility, such that it is being operated contrary to subsection 2 of Section 503.9 of the **ISO rules**, *Auxiliary Systems*.

- (8) The **legal owner** must, if the **ISO** provides written notice detailing evidence that the observed performance of the **generating unit**, **aggregated facility**, or **energy storage resource** is not consistent with any of the applicable requirements set out in Division 503 of the **ISO rules**, submit to the **ISO** a written report demonstrating that the **generating unit**, **aggregated facility**, or **energy storage resource** is capable of meeting those requirements.
- (9) The **legal owner** must submit a report no later than 60 **business days** after receipt of the written notice described in subsection 2(8).
- (10) The **legal owner** is not required, notwithstanding subsections 2(8) and 2(9), to provide the report if, between the date the **ISO** delivers the written notice and the deadline date for the submission of the report:
 - (a) the legal owner demonstrates to the satisfaction of the ISO that the failure to perform in accordance with the requirements set out in Division 503 of the ISO rules, was caused by equipment issues with the generating unit, aggregated facility, or energy storage resource that the legal owner corrected no later than 60 business days after receipt of the written notice described in subsection 2(8); and
 - (b) the **ISO** provides written notice to the **legal owner** that the report is not required.

Operating Data Requests from the ISO

- **3(1)** The **ISO** may request, by way of written notice, operating data from the **legal owner**, including the records described in Section 503.13 of the **ISO rules**, *Synchrophasor Measurement System* and Section 503.14 of the **ISO rules**, *Sequence of Events Monitoring*.
- (2) The legal owner must:
 - (a) submit the operating data requested by the **ISO**, if available, no later than 5 **business days** after receipt of the notice under subsection 3(1); or

ISO Rules Part 500 Facilities Division 503 Technical & Operating Requirements Section 503.18 Operation and Maintenance



Operator Availability

of Facilities

4 The **legal owner** must have designated personnel available 24 hours a **day** every **day** of the calendar year for contact and communication with the **ISO**, in accordance with all applicable **ISO rules** and **reliability standards**.

Revision History

Date	Description
2024-04-01	Initial release.