

Alberta Reliability Standard

Reliability Coordination - Staffing

PER-004-AB-2

1. Purpose

The **ISO** must have sufficient, competent staff to perform the functions of the **ISO**.

2. Applicability

This **reliability standard** applies to:

- (a) the **ISO**.

3. Requirements

R1 The **ISO** must be staffed with adequately trained operating personnel, each possessing a valid NERC Reliability Operator certificate, 24 hours per **day**, seven **days** per week.

R2 The **ISO** must ensure that **ISO** operating personnel have adequate information regarding **system operating limits**, **interconnection reliability operating limits** and **intertie** facility limits available.

4. Measures

The following measures correspond to the requirements identified in section 3 of this **reliability standard**. For example, MR1 is the measure for requirement R1.

MR1 Evidence may include, but is not limited to, NERC certificate / certification records, shift schedules or other equivalent evidence that will be used to confirm that the **ISO** is staffed with operating personnel possessing a valid NERC Reliability Operator certificate 24 hours per **day**, seven **days** per week.

MR2 Evidence may include but is not limited to, EMS screenshots, methodology documentation or other equivalent documentation that will be used to confirm that **ISO** operating personnel have adequate information regarding **system operating limits** and **interconnection reliability operating limits** and **intertie** facility limits.

Revision History

| Effective Date | Description |
|----------------|------------------|
| 2015-05-01 | Initial release. |