

**Preliminary 2005 Loss Factors Based on Proposed Loss Factor Methodology**

<b>GENERATION_PLANT_DESCR</b>	<b>MP_ID</b>	<b>Bus No</b>	<b>Loss Factor</b>
Air Liquide (Shell Scotsford - 0 - 62 MW))	SCTG	43	4.99%
Air Liquide (Shell Scotsford ISD - 63-82 M	SCTG	43	4.99%
Balzac IBOC (Turbo Balzac)	NX01	290	-1.73%
Barrier	BAR	216	-2.09%
Battle River (UNIT 3)	BR3	1491	5.01%
Battle River (UNIT 4)	BR4	1491	5.01%
Battle River (UNIT 5)	BR5	1469	4.07%
Bear Creek GT	BCRK	1142	1.32%
Bear Creek STG	BCR2	1142	1.32%
Bearspaw	BPW	184	-1.84%
Bighorn Hydro	BIG	103	1.70%
Brazeau Hydro	BRA	153	2.59%
CALPINE #1 (CTG)	CAL1	187	-0.09%
CALPINE #2 (STG)	CES2	187	-0.09%
Carseland IBOC (TransCanada)	TC01	252	-1.00%
Cascade	CAS	175	-2.42%
Castle River #1	CR1	234	-0.81%
Castle River #1	CR1	234	-0.81%
Cavalier IBOC (aka PanCanadian Nama	EC01	340	-1.37%
City of Medicine Hat	CMH1	682	-2.56%
Cloverbar #1	CG1	514	4.91%
Cloverbar #2	CG2	514	4.91%
Cloverbar #3	CG3	514	4.91%
Cloverbar #4	CG4	514	4.91%
Cowley Ridge Expansion #3	CRE3	264	0.44%
Cowley Ridge North Wind Plant	CRE1	264	0.44%
Diashowa	DAI1	1088	0.12%
Dow Generation	DOW1	61	5.11%
Dow GTG	DOWG	61	5.11%
Drywood	DRW1	233	-1.19%
Fort Nelson	FNG1	1016	-0.43%
Foster Creek	EC04	1301	6.14%
Genesee 1	GN1	524	6.45%
Genesee 2	GN2	524	6.45%
Ghost	GHO	180	-2.02%
Horseshoe	HSH	171	-2.10%
HR Milner	HRM	1147	3.98%
Interlakes	INT	329	-2.38%
Joffre	JOF1	383	1.97%
Kananaskis Hydro	KAN	193	-2.06%
Keephills 1	KH1	420	6.36%
Keephills 2	KH2	420	6.36%
Magrath (Taylor Hydro)	TAY1	694	-1.25%
MAHKESES (Cold Lake ISD)	IOR1	248	4.48%
McBRIDE LK. (0 - 36 MW)	AKE1	901	-0.64%
McBRIDE LK. (36 - 76 MW)	AKE1	901	-0.64%
MUSKEG River (Albian)	MKR1	1236	7.85%

OLD MAN Hydro	Project03	230	-0.60%
Pocaterra	POC	329	-2.38%
Poplar Hill	PH1	1118	-3.34%
Primrose	PR1	1302	5.49%
Procter & Gamble (Weyerhaeuser)	WEY1	1140	1.31%
Rainbow Lake 1	RB1	1028	-3.30%
Rainbow Lake 2	RB2	1028	-3.30%
Rainbow Lake 3	RB3	1028	-3.30%
Rainbow Lake 4	RL1	1028	-3.30%
Rainbow Lake 5 (CUPC)	RL2	1028	-3.30%
Rossdale 10	RG10	507	5.05%
Rossdale 8	RG8	507	5.05%
Rossdale 9	RG9	507	5.05%
Rundle	RUN	195	-2.15%
Sheerness 1	SH1	1484	2.47%
Sheerness 2	SH2	1484	2.47%
Spray	SPR	310	-2.09%
Sturgeon 1	ST1	1166	1.86%
Sturgeon 2	ST2	1166	1.86%
Suncor	SCR1	1208	7.65%
Sundance 1	SD1	135	7.10%
Sundance 2	SD2	135	7.10%
Sundance 3	SD3	135	7.10%
Sundance 4	SD4	135	7.10%
Sundance 5	SD5	135	7.10%
Sundance 6	SD6	135	7.10%
Sundance 6	SD6	135	7.10%
Syncrude	SCL1	1205	7.63%
Three Sisters	THS	195	-2.15%
ValleyView	VVW1	1172	2.31%
Wabamun 1	WB1	134	2.61%
Wabamun 2	WB2	134	2.61%
Wabamun 4	WB4	133	6.84%
Westlock	WST1	21	5.87%
On-Peak	SPC - Exp	1473	3.59%
Off-Peak		1473	3.59%
On-Peak	SPC - Imp	1473	-1.20%
Off-Peak		1473	-1.20%
On-Peak	BCH - Exp	90000	2.23%
Off-Peak		90000	2.23%
On-Peak	BCH - Imp	90000	-0.76%
Off-Peak		90000	-0.76%
Fortress Mountain			
Banff Mount Norquay			
Sil Industrial			
BP Canada Empress		262	3.27%
Dow By-Pass Fort Sask		61	-3.53%
Williams Energy Redwater			
Chevron West Pembina			
Wintergreen Ski Hill			
Garneau Inc.			
Camrose Pipe			

Shaw Pipe			
Agrium Joffre			
Chevron Ft Sask			
EPCOR/BP Canada			
Williams Energy Cochrane		191	3.78%
ATCO			
Slave Lake Pulp			
Syncrude		1200	-6.15%
Praxair Fort Sask			
Imperial Oil Strathcona			
Air Liquide			
EPCOR/Celanese			
Weyerhaeuser			
Keyspan Energy Canada			
Alpac	ALPC		
APF ATHABASCA ALPAC	APAL	308	3.64%
AQUILA-IRRICAN	AQIR		
CG&E COGEN G.PRAIRE	CGNE	1101	0.56%
Genesee 3	GN3	524	6.45%
GW POWER SODERGLLEN	GWS		
Benign Kettles Hill	BKH	224	-0.77%
McKAY RIVER	MKAY	1274	7.67%
NORTHSTONE ELMWORTH POWER	NELP	1134	-2.99%
Redwater Cogen (TCP)	RED	50	4.96%
Seven Persons (VQ)	SP		
Shell Purple Spring	SPS		
Summerview	SV		
Summerview Phase 2 (VQ)	SV	336	-0.40%
Suncor Magrath	SUNM		
Taylor Wind Plant (Canadian Hydro)	TAYW		
Waterton North (VQ)	WAT		

Greater Than 2 Times System Average Loss Factor

Less Than -1 Times System Average Loss Factor

**System Average Loss Factor**

**5.25%**