



2010 Generic Stacking Order Loss Factors

SEPTEMBER 02, 2009

| | Name | Signature | Date |
|--------------|----------------------------|-----------|--------------|
| Prepared by: | Ashikur Bhuiya, P.Eng. | | Sep 02, 2009 |
| Approved by: | Robert Baker, P.Eng. | | 2009 09 02 |
| Approved by: | Doyle Sullivan, P.Eng.. | | Sept 3/09. |

APEGGA Permit to Practice P-8200




TABLE OF CONTENTS

| | | |
|------------|---|----------|
| 1.0 | PURPOSE | 3 |
| 2.0 | INTRODUCTION | 3 |
| 3.0 | BACKGROUND | 4 |
| 4.0 | 2010 GSO KEY FEATURES | 5 |
| 5.0 | 2010 GENERIC STACKING ORDER..... | 8 |

1.0 Purpose

The purpose of this document is to describe the 2010 Generic Stacking Order as the order applies to the loss factor calculation.

2.0 Introduction

The Generic Stacking Order (GSO) is a key component in the loss factor calculation, operational forecasts, planning studies, and General Tariff Application process. Generators are dispatched to meet system demand in the base cases according to the order and generation amount specified in the GSO.

The loss factor GSO contains two key pieces of information –

1. Generation supply levels on a net-to-grid basis (NTG) for 12 seasonal cases¹ (four seasons and three load levels as defined below) for all generators, and

| Season | Timeframe | Scenario |
|--------|----------------------------------|----------|
| Winter | December, 2009 – February, 2010 | High |
| | | Medium |
| | | Low |
| Spring | March, 2010 – May, 2010 | High |
| | | Medium |
| | | Low |
| Summer | June, 2010 – August, 2010 | High |
| | | Medium |
| | | Low |
| Fall | September, 2010 – November, 2010 | High |
| | | Medium |
| | | Low |

2. Generation dispatch order.

The Rule governing the determination of the GSO generation supply levels can be located at www.aeso.ca > Rules & Procedures > ISO Rules > Current Rules. In summary, the generation supply levels are determined using

¹ Loss Factor base cases are relevant to NTG amount whereas operations and planning security base cases use more detailed modeling of the system including the behind the fence elements.

historical data for existing generators (in service for more than a year). For generators that have been in service for less than one year, the supply levels are estimated by the Incapability Factors or by a combination of actual data and the Incapability Factors. To determine dispatch order, a statistical analysis is used to determine a relationship between the generator output and the actual historical hourly pool price. The process is explained in 'Section 4.0. The AESO will request annually from generation owners confirmation that the previous year's historical data is appropriate to use. Additional blocks are used where necessary to reflect generators' multiple bidding strategies.

The TMR requirement (please refer to www.aeso.ca > Rules and Procedures > Current Operating Policies and Procedures > ISO Operating Policies and Procedures for details) supersedes all other operational criteria and hence TMR generators are dispatched first on the list when required to fulfill the reliability criteria.

3.0 Background

In 2006, the AESO began utilizing a new methodology, 50% Area Load Corrected R-Matrix, for the determination of generator and opportunity service loss factors. The methodology reflects the requirements Transmission Regulation. The regulation AR 86/2007 with amendments up to and including AR 255/2007 indicates loss factors must be calculated from the average impact of generators on the Alberta Interconnected Electric System (AIES). The regulation directed the AESO to implement a new methodology to meet these requirements. The AESO has consulted with stakeholders in the development of the loss factor methodology including the development of rules for the preparation of the GSO.

Prior to 2006, GSO's used generators STS contract levels as capacity amounts. Moving to a one year historical generation basis as was done in 2006 has several advantages, including;

- ◆ Amounts of actual generator energy market dispatch representative for

the previous year

- ◆ Addresses the issue of confidentiality of maintenance data by including actual maintenance and forced outages from the previous period
- ◆ Treats all facilities on the same basis
- ◆ Reduces necessity for the AESO to forecast generator / pool price relationships

4.0 2010 GSO Key Features

The highlights of the 2010 GSO preparation process are;

1. Average historical net-to-grid (NTG) output of a generator is considered for each of the twelve seasonal cases.
2. The determination of TMR and the energy component is done using SCADA data. The historical TMR instruction amount as dispatched by the system controller is used as the TMR amount. The difference between the total SCADA amount and the TMR instruction amount is used as the energy component. For example, if TMR instruction is 25 MW and the actual amount is 45 MW then the TMR amount will be 25 MW and the energy component will be 20 MW.
3. Generator owners are provided an opportunity to comment on and suggest revisions to the GSO capacities to correct calculation errors by the AESO on historical data or proposed operational characteristics on new generation.
4. The net of historical (or for Montana, estimated) levels of import and export (separately for BC, Montana, and Saskatchewan) is shown in the GSO only if the net is import. If the net is export the GSO shows zero for the scenario. The net import (if any) is added at the end of the 2nd block of Hydro. If the net is export then it will be reflected in the loss factor base cases. The DOS loads will be reflected in the loss factor base cases.

5. The numbers of hours (H values) used for averaging the historical generator output are taken from the AIES seasonal load duration curve analysis (Please see Appendix 6 of the AESO Rules).
6. No maintenance or outage data is used in the 2010 GSO as average historical net-to-grid output of a generator inherently contains this information.
7. 12 seasonal net-to-grid generations are assigned to each individual generator at the point of supply (POS).
8. The order except for units such as wind, import, and hydro generation is determined by the actual price responsiveness of the generators in each group.
9. New generators expected to be connected in the forecast year will be included in the GSO. These are generators with signed contracts to connect or who have made significant financial commitments to connect. Generators who have filed decommissioning plans with the AESO will be removed accordingly.

AESO typically relies on an operating profile submitted by the generator owner. In the event this information has not been provided the AESO will rely on the Canadian Electricity Association's (CEA) latest annual report on Generation Equipment Status utilizing The incapability factors (ICBF) to calculate the power available to the AIES. (1- ICBF) has been considered as equivalent to Available Capacity Factors (ACF)..

10. The 2010 GSO considers the NTG amount at the point of supply (POS). Since any given loss factor is primarily the function of net to grid amount of generation, the 2010 GSO represents an aggregate of generation at the point of supply. An equivalent generator is considered at the bus from which the NTG amount related to the Measurement Point Identification (MPID) is obtained. For example, Horseshoe has 4 generators with a single MPID which is HSH. The 4 generators are connected to Bus 172 (12 kV). They are represented as a single unit at Bus 171 (138 kV)

because the AESO billing database contains NTG data for all of these four units (related to MPID HSH) at Bus 171. The same approach is applied to the Industrial System Designations (ISD). All ISDs are represented by a single equivalent generator and load. The GSO contains a column with bus numbers for corresponding MPIDs.

11. An energy stacking order is created for all generation units based on 12 months of historical data. The generation energy market behavior analysis is updated with the latest historical data from the period June 1 2008 to May 31 2009. Each generator's hourly bidding prices and associated generation MW changes are combined and sorted as a multi-block stacking order for that generation unit for the 12 months period. The generation unit is then divided into two blocks. Two blocks are chosen to avoid additional complexity for limited modeling improvement. A statistical analysis is applied to define the first and second blocks from its multi-block stacking order. A low end price with the highest occurring percentage in the 12 months period is selected as the first block. Its block size is defined as the average size based on occurrence. Generation volumes above the first block size belong to the second block. This block price is defined by using weighted average of all the prices above the first block. The weighted factor is generation MW changes at each price and its percentage in history. The second block size is calculated by averaging of all blocks above the first block. However, not all generators have a 2nd block. The statistical analysis shows that some generators have an insignificant amount of generation in the 2nd block which indicates their price insensitivity. A weighted average of generator output of 12 seasonal outputs is calculated based on the H values or duration of the scenarios. A second block for a generator is considered, in general, if the weighted average is equal to or more than 5 MW. In some cases the second block is not assigned to a generator even though the weighted average is more than 5 MW such as for SPR&D or Wind generators.

The price response analysis used to construct the GSO is consistent with the losses forecast as filed with the AESO's General Tariff Application.

The 2009 GSO is similar to its predecessors in the following aspects:

1. The wind and hydro units are ranked according to their relative loss factors.
2. No bid price, specific TMR, maintenance schedules, or heat rate information is revealed.
3. Multiple blocks (two blocks) are used to represent the historical response of the generators to pool price.
4. The GSO is separated into two blocks (where necessary) and into similar generation technologies (i.e. wind, co-gen, coal, etc)

5.0 2010 Generic Stacking Order

The following describes the application of the GSO to the loss factor base cases:

- 1) **Transmission Must Run (TMR) generators** – the generators represent the expected TMR dispatch (of gas, combined cycle, or other units) beyond area generation energy market participation. The TMR units are listed in the AESO OPPs 501, 510 and 521. TMR is required in specific areas of the AIES to meet reliability criteria. The total net-to-grid (NTG) amount assigned to the TMR generators in the 2010 GSO is obtained from the following two sources:
 - a) The average historical TMR total (SCADA) is calculated for 12 seasonal cases in the past twelve months (June 1 2008 to May 31 2009). The AIES seasonal load duration curve analysis is used to obtain the average TMR total amount of each generator.
 - b) The average TMR instruction amount (as dispatched by the System Controller) is calculated for 12 seasonal cases in the past twelve months (June 1 2008 to May 31 2009). The AIES seasonal load

duration curve analysis is used to obtain the average TMR instruction amount for each generator.

According to the OPPs when the area criteria requirement is not met by the generation from local generators through energy market dispatches, TMR dispatches will be issued to TMR-contracted generators to make up the shortfall. TMR-contracted generators will be dispatched according to the TMR dispatch orders. The actual TMR dispatch order is confidential to the AESO.

- 2) **Data** – Most of the data used in 2010 GSO such as Alberta system load, hourly pool price and generation amount at each POS are historical and taken from the most recent 12 months' data found in the AESO's billing system. The data extraction period is June 1 2008 to May 31 2009.
- 3) **Dispatch Generator** – In general, the energy stacking order is formed to more closely reflect an actual operational perspective. The generators may bid multiple blocks but the typical block size beyond the 2nd block is very small.
- 4) **Wind Generation** – Wind generation does not have a relationship to pool price.
- 5) **Small Power Research & Development** – The relative order remains the same as the 2009 GSO. SPR&D generators are exempt by law from paying for losses.
- 6) **Distribution Connected Generation** – consists of distribution connected generators with STS contracts who occasionally supplies power to the AIES. Several prime movers may exist at a distribution generation location. The placement of the distribution generation in the stacking order is determined mainly by the predominant source of generation at the STS location and ranked by historical hourly pool price.
- 7) **Preliminary Generation** – consists of the generators with preliminary status and placed with the same fuel type group.

- 8) **Import levels** – as per the 2007 Transmission Regulation, inter-tie levels are included in the loss factor calculation power flows. Imports are added in the GSO following the second block of hydro generation. The location reflects the relative level of availability of import resources for Alberta. The GSO provides a list of generation or equivalent entity (imports or industrial system designation) along with their predicted seasonal output capacity. Exports are not added in the GSO as they are not supply component of the system.

2010 Generic Stacking Order Version 2 - September 02, 2009

| New GSO Number | Name | MP_ID | Gen with 2nd Block | Generation Type | Winter Peak Capacity, MW* | Winter Med Capacity, MW* | Winter Low Capacity, MW* | Spring Peak Capacity, MW* | Spring Med Capacity, MW* | Spring Low Capacity, MW* | Summer Peak Capacity, MW* | Summer Med Capacity, MW* | Summer Low Capacity, MW* | Fall Peak Capacity, MW* | Fall Med Capacity, MW* | Fall Low Capacity, MW* |
|----------------|----------------------------------|------------------|--------------------|-----------------|---------------------------|--------------------------|--------------------------|---------------------------|--------------------------|--------------------------|---------------------------|--------------------------|--------------------------|-------------------------|------------------------|------------------------|
| 1 | RAINBOW 4 | RL1 | 1 | Co-gen | 31.5 | 32.7 | 33.9 | 38.7 | 32.3 | 27.5 | 19.3 | 30.8 | 28.8 | 28.5 | 27.2 | 28.0 |
| 2 | RAINBOW 5 | RB5 | 1 | Gas | 24.0 | 21.0 | 16.1 | 20.3 | 21.3 | 22.2 | 25.8 | 13.7 | 8.1 | 32.3 | 25.8 | 21.2 |
| 3 | POPLAR HILL | PH1 | 1 | Gas | 3.7 | 5.2 | 1.3 | 6.6 | 5.1 | 2.1 | 3.7 | 1.8 | 2.2 | 8.5 | 4.4 | 0.4 |
| 4 | VALLEYVIEW | VVW1 | 1 | Gas | 0.2 | 0.4 | 0.0 | 0.0 | 0.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 5 | FORT NELSON | FNG1 | 1 | Gas | 25.6 | 36.8 | 39.3 | 35.9 | 29.7 | 25.9 | 24.6 | 35.9 | 40.1 | 34.5 | 31.2 | 36.5 |
| 6 | BEAR CREEK G1 | BCRK | 1 | Co-Cycle | 5.0 | 6.8 | 4.6 | 12.0 | 2.7 | 0.0 | 14.3 | 10.5 | 11.7 | 2.7 | 2.0 | 0.1 |
| 7 | RAINBOW 2 | RB2 | 1 | Gas | 2.3 | 4.2 | 3.0 | 0.0 | 2.6 | 4.1 | 3.4 | 2.5 | 3.9 | 2.1 | 3.9 | 2.9 |
| 8 | RAINBOW 1 | RB1 | 1 | Gas | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 9 | BEAR CREEK G2 | BCR2 | 1 | Co-Cycle | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 10 | NORTHSTONE ELMWORTH | NPC1 | 1 | Co-gen | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 11 | RAINBOW 3 | RB3 | 1 | Gas | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 12 | GRANDE PRAIRIE ECOPOWER CENTRE | GPEC | 1 | Co-gen | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 13 | TABER WIND | TAB1 | | Wind | 26.4 | 26.0 | 28.5 | 22.2 | 29.3 | 33.6 | 15.9 | 19.2 | 16.8 | 37.6 | 23.4 | 29.5 |
| 14 | SUNCOR HILLRIDGE WIND FARM | SCR3 | | Wind | 12.9 | 12.4 | 13.4 | 10.8 | 14.0 | 14.5 | 7.0 | 9.1 | 6.3 | 18.2 | 11.1 | 13.6 |
| 15 | GLENWOOD | 0000022911 | | Wind, DG | 0.0 | 0.0 | 0.1 | 0.0 | 0.1 | 0.2 | 0.0 | 0.2 | 0.6 | 0.0 | 0.2 | 0.4 |
| 16 | SUNCOR MAGRATH | SCR2 | | Wind | 10.1 | 11.9 | 13.7 | 9.3 | 12.4 | 11.6 | 4.7 | 8.7 | 7.1 | 16.0 | 11.7 | 10.9 |
| 17 | FT MACLEOD | 0000001511 | | Wind, DG | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 18 | McBRIDE | AKE1 | | Wind | 22.9 | 30.8 | 33.1 | 23.7 | 29.1 | 22.7 | 9.7 | 19.6 | 10.8 | 41.4 | 30.9 | 25.6 |
| 19 | CASTLE RIVER | CR1 | | Wind | 10.6 | 15.4 | 16.5 | 13.6 | 13.4 | 8.2 | 3.8 | 9.0 | 4.1 | 20.7 | 15.1 | 12.0 |
| 20 | SODERGLEN | GWW1 | | Wind | 22.7 | 31.9 | 33.7 | 26.5 | 29.1 | 25.9 | 11.7 | 20.8 | 13.1 | 38.4 | 31.1 | 26.3 |
| 21 | PINCHER CREEK | 0000039611 | | Wind, DG | 0.2 | 0.5 | 1.2 | 0.3 | 0.8 | 0.9 | 0.3 | 1.0 | 0.6 | 1.4 | 1.4 | 1.5 |
| 22 | KETTLES HILL WIND ENERGY PHASE 2 | KHW1 | | Wind | 18.8 | 27.4 | 29.0 | 23.7 | 25.4 | 19.1 | 10.4 | 16.8 | 9.4 | 37.5 | 26.2 | 20.6 |
| 23 | TAYLOR WIND PLANT | TAY2 | | Wind | 0.6 | 0.9 | 1.0 | 0.4 | 0.8 | 0.6 | 0.3 | 0.5 | 0.4 | 0.8 | 0.7 | 0.5 |
| 24 | SUMMERVIEW 1 | IEW1 | | Wind | 16.0 | 25.6 | 27.5 | 17.2 | 23.8 | 18.8 | 9.9 | 12.1 | 6.3 | 35.7 | 18.8 | 15.0 |
| 25 | COWLEY EXPANSION 1 | CRE1 | | Wind | 0.1 | 0.3 | 0.3 | 0.3 | 0.3 | 0.2 | 0.1 | 0.2 | 0.1 | 0.4 | 0.3 | 0.2 |
| 26 | COWLEY EXPANSION 2 | CRE2 | | Wind | 0.3 | 0.4 | 0.4 | 0.4 | 0.4 | 0.2 | 0.2 | 0.3 | 0.1 | 0.6 | 0.4 | 0.3 |
| 27 | COWLEY NORTH | CRE3 | | Wind | 4.9 | 7.3 | 7.4 | 7.1 | 6.2 | 3.9 | 3.6 | 4.2 | 1.6 | 9.8 | 7.1 | 5.7 |
| 28 | COWLEY RIDGE WIND POWER PHASE1 | PKNE | | Wind | 2.0 | 3.8 | 3.9 | 3.7 | 3.8 | 2.4 | 2.1 | 2.5 | 1.0 | 5.5 | 4.0 | 3.1 |
| 29 | COWLEY RIDGE WIND POWER PHASE2 | CRWD | | Wind | 1.9 | 3.3 | 3.5 | 3.3 | 3.3 | 2.0 | 1.6 | 2.0 | 0.7 | 4.8 | 3.4 | 2.6 |
| 30 | BLUE TRAIL WIND FARM | BTR1 | | Wind | 29.7 | 29.7 | 29.7 | 22.7 | 22.7 | 22.7 | 16.9 | 16.9 | 16.9 | 25.1 | 25.1 | 25.1 |
| 31 | SUMMERVIEW 2 | Project_393_2 | | Wind | 28.4 | 28.4 | 28.4 | 21.7 | 21.7 | 21.7 | 16.1 | 16.1 | 16.1 | 24.0 | 24.0 | 24.0 |
| 32 | PEACE BUTTE WIND FARM | Project513_1_SUP | | Wind | 0.0 | 0.0 | 0.0 | 39.9 | 39.9 | 39.9 | 29.7 | 29.7 | 29.7 | 44.2 | 44.2 | 44.2 |
| 33 | GREENGATE HALKIRK WIND PROJECT | Project723_1_SUP | | Wind | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 57.2 | 57.2 | 57.2 |
| 34 | OLD MAN RIVER WIND FARM | Project519_1_SUP | | Wind | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 17.8 | 17.8 | 17.8 |
| 35 | WESGEN | WST1 | | Bio-mass | 9.2 | 9.9 | 9.7 | 10.8 | 12.7 | 12.2 | 9.6 | 10.8 | 9.0 | 14.6 | 13.3 | 12.4 |
| 36 | WHITE COURT | EAGL | | Bio-mass | 21.1 | 20.6 | 21.1 | 23.7 | 23.1 | 23.7 | 23.5 | 24.1 | 24.3 | 13.8 | 19.2 | 20.0 |
| 37 | BRIDGE CREEK | GOC1 | | Gas-decomp | 3.1 | 3.3 | 3.4 | 3.6 | 3.2 | 3.4 | 2.0 | 1.9 | 1.3 | 3.6 | 2.9 | 3.0 |
| 38 | DRAYTON VALLEY PL IPP | DV1 | | Bio-mass | 5.7 | 5.9 | 6.1 | 8.4 | 8.1 | 8.8 | 8.7 | 8.9 | 9.7 | 8.5 | 8.3 | 8.2 |
| 39 | BELLY RIVER IPP | BLYR | | Hydro | 0.0 | 0.0 | 0.0 | 0.0 | 0.7 | 1.2 | 2.7 | 2.7 | 2.1 | 0.0 | 1.1 | 1.4 |
| 40 | CHIN CHUTE | CHIN | | Hydro | 0.0 | 0.0 | 0.0 | 0.0 | 1.9 | 3.3 | 9.1 | 10.0 | 11.0 | 0.0 | 2.7 | 3.6 |
| 41 | DICKSON DAM 1 | DKSN | | Hydro | 5.1 | 5.0 | 5.0 | 4.6 | 5.8 | 6.5 | 10.2 | 12.4 | 12.6 | 5.2 | 7.5 | 8.1 |
| 42 | WATER IPP | WTRN | | Hydro | 0.7 | 0.7 | 0.7 | 0.7 | 0.9 | 1.1 | 2.3 | 2.4 | 2.6 | 0.7 | 0.8 | 0.9 |
| 43 | ST MARY IPP | STMY | | Hydro | 1.8 | 1.7 | 1.8 | 1.7 | 1.8 | 1.8 | 2.3 | 2.3 | 2.2 | 1.8 | 2.1 | 2.1 |
| 44 | RAYMOND RESERVOIR | RYMD | | Hydro | 0.0 | 0.0 | 0.0 | 0.0 | 2.5 | 4.0 | 17.3 | 17.0 | 15.5 | 0.0 | 2.8 | 3.3 |
| 45 | P&G WEYERHAUSER | WEY1 | | Co-gen | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 46 | DIASHOWA | DAI1 | | Co-gen | 3.4 | 2.7 | 2.6 | 3.9 | 2.8 | 1.9 | 4.1 | 1.9 | 2.0 | 2.8 | 2.7 | 2.3 |

| New GSO Number | Name | MP_ID | Gen with 2nd Block | Generation Type | Winter Peak Capacity, MW* | Winter Med Capacity, MW* | Winter Low Capacity, MW* | Spring Peak Capacity, MW* | Spring Med Capacity, MW* | Spring Low Capacity, MW* | Summer Peak Capacity, MW* | Summer Med Capacity, MW* | Summer Low Capacity, MW* | Fall Peak Capacity, MW* | Fall Med Capacity, MW* | Fall Low Capacity, MW* |
|----------------|---------------------|---------------|--------------------|-----------------|---------------------------|--------------------------|--------------------------|---------------------------|--------------------------|--------------------------|---------------------------|--------------------------|--------------------------|-------------------------|------------------------|------------------------|
| 94 | SUNDANCE #2 | SD2 | 1 | Coal | 210.7 | 188.6 | 178.7 | 165.2 | 170.1 | 149.0 | 110.2 | 38.9 | 8.6 | 199.3 | 174.2 | 169.3 |
| 95 | SUNDANCE #3 | SD3 | 1 | Coal | 248.8 | 228.4 | 225.0 | 249.5 | 151.6 | 162.8 | 243.9 | 218.2 | 166.3 | 259.5 | 205.6 | 184.7 |
| 96 | SUNDANCE #4 | SD4 | 1 | Coal | 203.4 | 188.9 | 181.4 | 150.1 | 348.2 | 345.1 | 335.3 | 333.6 | 329.7 | 343.2 | 326.6 | 307.0 |
| 97 | SUNDANCE #6 | SD6 | 1 | Coal | 160.7 | 202.4 | 211.3 | 270.7 | 265.0 | 274.9 | 232.4 | 229.9 | 214.9 | 4.3 | 155.3 | 162.3 |
| 98 | HR MILNER | HRM | 1 | Coal | 103.2 | 92.7 | 82.7 | 71.7 | 61.2 | 47.8 | 95.4 | 69.1 | 73.7 | 79.5 | 94.3 | 81.4 |
| 99 | SUNDANCE #5 | SD5 | 1 | Coal | 240.3 | 228.0 | 211.8 | 263.1 | 241.2 | 220.8 | 217.3 | 173.6 | 180.1 | 269.8 | 249.3 | 230.1 |
| 100 | SUNDANCE #1 | SD1 | 1 | Coal | 209.4 | 179.4 | 182.6 | 221.9 | 217.0 | 197.7 | 228.1 | 223.7 | 239.5 | 238.0 | 196.2 | 183.9 |
| 101 | BATTLE RIVER #3 | BR3 | 1 | Coal | 71.3 | 68.9 | 62.8 | 57.7 | 47.6 | 32.4 | 74.9 | 62.2 | 34.6 | 72.6 | 66.5 | 59.8 |
| 102 | BATTLE RIVER #5 | BR5 | 1 | Coal | 185.8 | 181.4 | 162.6 | 193.6 | 174.6 | 139.9 | 197.6 | 167.3 | 84.4 | 181.2 | 172.1 | 148.5 |
| 103 | BATTLE RIVER #4 | BR4 | 1 | Coal | 83.9 | 80.6 | 70.4 | 88.2 | 71.1 | 54.8 | 78.8 | 75.5 | 51.9 | 86.9 | 83.1 | 69.3 |
| 104 | GENESEE 3 | GN3 | 2 | Coal | 229.3 | 233.4 | 230.8 | 239.3 | 230.8 | 209.9 | 236.2 | 200.3 | 111.9 | 128.0 | 128.7 | 139.5 |
| 105 | SUNDANCE #6 | SD6 | 2 | Coal | 35.4 | 44.6 | 46.5 | 59.6 | 58.3 | 60.5 | 51.1 | 50.6 | 47.3 | 0.9 | 34.2 | 35.7 |
| 106 | SUNDANCE #5 | SD5 | 2 | Coal | 66.6 | 63.2 | 58.7 | 72.9 | 66.8 | 61.2 | 60.2 | 48.1 | 49.9 | 74.8 | 69.1 | 63.8 |
| 107 | SUNDANCE #4 | SD4 | 2 | Coal | 9.0 | 8.3 | 8.0 | 6.6 | 15.4 | 15.2 | 14.8 | 14.7 | 14.5 | 15.1 | 14.4 | 13.5 |
| 108 | HR MILNER | HRM | 2 | Coal | 18.4 | 16.5 | 14.8 | 12.8 | 10.9 | 8.5 | 17.0 | 12.3 | 13.1 | 14.2 | 16.8 | 14.5 |
| 109 | SHEERNESS #2 | SH2 | 2 | Coal | 154.9 | 104.1 | 92.5 | 147.5 | 130.9 | 104.3 | 173.1 | 149.0 | 115.4 | 173.0 | 148.6 | 136.6 |
| 110 | SUNDANCE #2 | SD2 | 2 | Coal | 67.0 | 60.0 | 56.8 | 52.5 | 54.1 | 47.4 | 35.0 | 12.4 | 2.7 | 63.4 | 55.4 | 53.8 |
| 111 | SHEERNESS #1 | SH1 | 2 | Coal | 130.8 | 122.2 | 121.7 | 110.4 | 108.6 | 99.4 | 130.7 | 88.6 | 41.4 | 136.4 | 130.4 | 125.2 |
| 112 | SUNDANCE #3 | SD3 | 2 | Coal | 73.4 | 67.4 | 66.4 | 73.6 | 44.7 | 48.0 | 72.0 | 64.4 | 49.1 | 76.6 | 60.6 | 54.5 |
| 113 | SUNDANCE #1 | SD1 | 2 | Coal | 25.2 | 21.6 | 22.0 | 26.7 | 26.1 | 23.8 | 27.4 | 26.9 | 28.8 | 28.6 | 23.6 | 22.1 |
| 114 | GENESEE 2 | GN2 | 2 | Coal | 185.4 | 183.2 | 183.0 | 185.0 | 182.3 | 178.9 | 185.6 | 182.7 | 165.1 | 182.9 | 161.8 | 161.0 |
| 115 | GENESEE 1 | GN1 | 2 | Coal | 179.1 | 177.0 | 177.7 | 182.6 | 176.5 | 176.4 | 183.5 | 182.9 | 170.8 | 184.8 | 180.1 | 176.8 |
| 116 | BATTLE RIVER #5 | BR5 | 2 | Coal | 173.8 | 169.8 | 152.1 | 181.2 | 163.3 | 130.9 | 184.9 | 156.5 | 79.0 | 169.5 | 161.1 | 139.0 |
| 117 | KEEPHILLS #2 | KH2 | 2 | Coal | 50.7 | 42.5 | 42.0 | 0.0 | 29.7 | 41.3 | 51.5 | 47.3 | 40.3 | 49.0 | 41.6 | 39.1 |
| 118 | KEEPHILLS #1 | KH1 | 2 | Coal | 46.4 | 54.3 | 53.6 | 60.7 | 28.8 | 10.2 | 38.6 | 43.4 | 41.1 | 60.4 | 55.8 | 52.5 |
| 119 | BATTLE RIVER #4 | BR4 | 2 | Coal | 63.1 | 60.6 | 53.0 | 66.3 | 53.5 | 41.2 | 59.3 | 56.8 | 39.1 | 65.4 | 62.5 | 52.1 |
| 120 | BATTLE RIVER #3 | BR3 | 2 | Coal | 71.8 | 69.4 | 63.2 | 58.1 | 47.9 | 32.6 | 75.4 | 62.6 | 34.8 | 73.1 | 66.9 | 60.2 |
| 121 | WABAMUN #4 | WB4 | 2 | Coal | 4.0 | 3.6 | 3.6 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 122 | SUNDANCE 5 UPGRADE | SD5 | | Coal | 47.7 | 47.7 | 47.7 | 47.7 | 47.7 | 47.7 | 47.7 | 47.7 | 47.7 | 47.7 | 47.7 | 47.7 |
| 123 | KEEPHILLS #3 | Project_500_1 | | Coal | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 154.7 | 154.7 | 154.7 |
| 124 | CASCADE | CAS | 2 | Hydro | 5.4 | 3.4 | 0.2 | 3.8 | 1.7 | 0.0 | 4.1 | 1.6 | 0.0 | 5.1 | 2.6 | 0.1 |
| 125 | RUNDLE | RUN | 2 | Hydro | 2.3 | 1.9 | 0.3 | 2.2 | 1.5 | 0.3 | 2.1 | 1.4 | 0.1 | 2.6 | 1.9 | 0.3 |
| 126 | SPRAY | SPR | 2 | Hydro | 12.4 | 9.2 | 1.4 | 11.6 | 6.3 | 1.2 | 9.3 | 6.2 | 0.6 | 11.1 | 8.0 | 1.1 |
| 127 | GHOST | GHO | 2 | Hydro | 10.8 | 5.9 | 1.2 | 7.4 | 4.7 | 1.1 | 13.9 | 13.1 | 15.3 | 10.2 | 8.6 | 2.4 |
| 128 | HORSESHOE | HSH | 2 | Hydro | 1.5 | 1.2 | 1.1 | 1.2 | 1.0 | 0.9 | 1.7 | 1.8 | 1.9 | 1.4 | 1.4 | 1.3 |
| 129 | BEARSPAW | BPW | 2 | Hydro | 1.3 | 1.3 | 1.4 | 1.3 | 1.4 | 1.5 | 2.4 | 2.7 | 2.9 | 0.8 | 1.2 | 1.4 |
| 130 | KANANASKIS | KAN | 2 | Hydro | 1.7 | 1.4 | 1.3 | 1.5 | 1.3 | 1.1 | 2.5 | 2.7 | 2.9 | 1.7 | 1.3 | 1.1 |
| 131 | BRAZEAU | BRA | 2 | Hydro | 72.4 | 31.9 | 1.8 | 44.0 | 30.0 | 4.2 | 109.4 | 94.9 | 132.2 | 59.1 | 24.6 | 4.1 |
| 132 | BIGHORN | BIG | 2 | Hydro | 16.0 | 12.8 | 10.0 | 12.1 | 10.6 | 8.3 | 26.0 | 15.4 | 7.4 | 18.5 | 16.4 | 11.2 |
| 133 | BC IMPORT | BCHIMP | | Import | 459.9 | 290.1 | 0.0 | 402.8 | 173.7 | 0.0 | 408.5 | 147.6 | 185.3 | 359.0 | 267.3 | 0.0 |
| 134 | SASKATCHEWAN IMPORT | SPCIMP | | Import | 62.9 | 70.6 | 62.6 | 70.6 | 52.7 | 71.2 | 112.1 | 90.9 | 91.2 | 72.6 | 67.0 | 50.7 |
| 135 | MATL IMPORT | MATLIMP | | Import | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 25.0 | 25.0 | 0.0 | 25.0 | 25.0 | 0.0 |
| 136 | SUNCOR MILLENIUM | SCR1 | 2 | Co-gen | 55.9 | 54.9 | 46.7 | 54.5 | 40.3 | 32.4 | 43.3 | 39.0 | 37.8 | 52.1 | 38.1 | 33.9 |
| 137 | CAVAILIER | EC01 | 2 | Co-Cycle | 77.0 | 41.6 | 28.0 | 61.8 | 34.8 | 18.0 | 56.0 | 22.9 | 3.4 | 52.6 | 40.2 | 20.3 |
| 138 | REDWATER | TC02 | 2 | Co-gen | 5.7 | 4.7 | 4.6 | 4.9 | 4.1 | 4.0 | 3.7 | 4.4 | 4.9 | 4.4 | 4.2 | 4.2 |
| 139 | CARSELAND | TC01 | 2 | Co-gen | 20.5 | 21.0 | 20.8 | 18.9 | 20.9 | 21.3 | 21.3 | 18.4 | 10.7 | 21.9 | 21.7 | 21.2 |
| 140 | MUSKEG | MKR1 | 2 | Co-gen | 29.5 | 24.2 | 19.6 | 31.9 | 21.8 | 17.1 | 20.1 | 17.5 | 15.9 | 26.7 | 11.7 | 9.0 |

| New GSO Number | Name | MP_ID | Gen with 2nd Block | Generation Type | Winter Peak Capacity, MW* | Winter Med Capacity, MW* | Winter Low Capacity, MW* | Spring Peak Capacity, MW* | Spring Med Capacity, MW* | Spring Low Capacity, MW* | Summer Peak Capacity, MW* | Summer Med Capacity, MW* | Summer Low Capacity, MW* | Fall Peak Capacity, MW* | Fall Med Capacity, MW* | Fall Low Capacity, MW* |
|----------------|---------------------------------|------------------|--------------------|-----------------|---------------------------|--------------------------|--------------------------|---------------------------|--------------------------|--------------------------|---------------------------|--------------------------|--------------------------|-------------------------|------------------------|------------------------|
| 141 | NORTHERN PRAIRIE POWER PROJECT | NPP1 | | Gas | 13.2 | 5.7 | 0.0 | 3.1 | 2.1 | 1.2 | 11.3 | 11.3 | 11.3 | 6.9 | 6.9 | 6.9 |
| 142 | CLOVER BAR 1 | ENC1 | | Gas | 30.5 | 5.3 | 0.3 | 2.7 | 1.7 | 0.0 | 4.3 | 2.2 | 0.0 | 3.4 | 7.0 | 1.4 |
| 143 | McKAY RIVER | MKRC | 2 | Co-gen | 2.6 | 2.6 | 2.6 | 2.7 | 2.4 | 2.4 | 2.0 | 2.3 | 2.3 | 2.5 | 2.2 | 2.3 |
| 144 | NOVA JOFFRE | NOVAGEN15M | 2 | Co-gen | 57.8 | 48.2 | 40.2 | 48.7 | 30.7 | 14.4 | 36.6 | 16.2 | 2.5 | 45.0 | 30.2 | 22.0 |
| 145 | ATCO VALLEY VIEW 2 | VVW2 | | Gas | 2.5 | 0.6 | 0.0 | 0.7 | 0.5 | 0.0 | 6.4 | 6.4 | 6.4 | 1.0 | 1.5 | 0.3 |
| 146 | PRIMROSE | PR1 | 2 | Co-gen | 1.4 | 1.6 | 1.5 | 2.5 | 1.9 | 1.8 | 1.2 | 1.6 | 1.8 | 0.0 | 0.5 | 0.7 |
| 147 | ENMAX CALGARY ENERGY CENTRE CTG | CES1 | 2 | Co-Cycle | 92.4 | 43.1 | 20.6 | 105.6 | 46.4 | 7.0 | 77.1 | 22.3 | 21.5 | 66.0 | 55.2 | 24.3 |
| 148 | ENMAX CALGARY ENERGY CENTRE STG | CES2 | 2 | Co-Cycle | 22.8 | 10.4 | 5.2 | 25.3 | 11.6 | 1.3 | 20.8 | 5.8 | 5.8 | 17.3 | 14.7 | 6.2 |
| 149 | BALZAC | NX01 | 2 | Co-Cycle | 29.2 | 22.0 | 15.2 | 30.9 | 16.4 | 8.9 | 21.5 | 10.2 | 4.0 | 22.3 | 20.1 | 16.4 |
| 150 | CITY OF MEDICINE HAT | CMH1 | 2 | Gas | 6.0 | 6.1 | 1.0 | 6.2 | 4.0 | 0.7 | 2.2 | 2.1 | 0.0 | 6.4 | 5.6 | 0.8 |
| 151 | FOSTER CREEK G1 | EC04 | 2 | Co-gen | 5.3 | 5.1 | 5.0 | 4.7 | 2.6 | 2.7 | 3.3 | 3.8 | 4.4 | 4.6 | 4.5 | 4.6 |
| 152 | DOW GTG | DOWGEN15M | 2 | Co-gen | 69.6 | 44.0 | 22.4 | 54.0 | 33.9 | 21.5 | 38.2 | 22.2 | 10.4 | 53.6 | 33.9 | 18.1 |
| 153 | RAINBOW 4 | RL1 | 2 | Gas | 4.9 | 0.3 | 0.2 | 0.2 | 0.4 | 0.6 | 2.5 | 1.8 | 5.9 | 1.4 | 2.3 | 0.8 |
| 154 | RAINBOW 5 | RB5 | 2 | Gas | 4.4 | 0.4 | 0.3 | 0.7 | 0.3 | 0.3 | 3.2 | 0.9 | 0.2 | 1.3 | 2.8 | 0.5 |
| 155 | POPLAR HILL | PH1 | 2 | Gas | 2.5 | 0.4 | 0.0 | 0.1 | 0.7 | 0.1 | 0.7 | 0.5 | 0.1 | 1.1 | 1.4 | 0.2 |
| 156 | VALLEYVIEW | VVW1 | 2 | Gas | 1.2 | 0.2 | 0.0 | 0.8 | 0.2 | 0.0 | 0.0 | 0.1 | 0.0 | 0.1 | 1.0 | 0.2 |
| 157 | FORT NELSON | FNG1 | 2 | Gas | 14.7 | 3.7 | 0.6 | 4.9 | 1.6 | 0.5 | 15.9 | 4.3 | 0.4 | 7.8 | 7.7 | 2.7 |
| 158 | BEAR CREEK G1 | BCRK | 2 | Co-Cycle | 24.8 | 9.2 | 1.9 | 7.4 | 1.9 | 0.3 | 17.4 | 3.3 | 0.5 | 10.5 | 15.8 | 6.8 |
| 159 | RAINBOW 2 | RB2 | 2 | Gas | 0.9 | 0.3 | 0.2 | 0.0 | 0.2 | 0.4 | 1.4 | 0.4 | 0.2 | 1.2 | 1.1 | 0.3 |
| 160 | RAINBOW 1 | RB1 | 2 | Gas | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 161 | BEAR CREEK G2 | BCR2 | 2 | Co-Cycle | 16.3 | 14.2 | 12.1 | 16.4 | 11.7 | 9.8 | 22.8 | 16.2 | 15.9 | 13.9 | 17.5 | 14.8 |
| 162 | NORTHSTONE ELMWORTH | NPC1 | 2 | Co-gen | 2.1 | 0.4 | 0.1 | 0.1 | 0.1 | 0.0 | 0.9 | 0.1 | 0.0 | 0.5 | 0.7 | 0.1 |
| 163 | RAINBOW 3 | RB3 | 2 | Gas | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 164 | GRANDE PRAIRIE ECOPOWER CENTRE | GPEC | 2 | Co-gen | 15.4 | 13.8 | 13.6 | 19.3 | 18.6 | 18.4 | 16.3 | 16.9 | 13.1 | 16.6 | 16.2 | 17.3 |
| 165 | SHELL CAROLINE | SHCG | | Co-gen | 0.1 | 0.9 | 1.1 | 0.6 | 1.4 | 1.8 | 0.0 | 1.2 | 2.4 | 4.1 | 2.3 | 2.2 |
| 166 | STURGEON 1 | ST1 | | Gas | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 167 | STURGEON 2 | ST2 | | Gas | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 168 | DRYWOOD 1 | DRW1 | | Gas | 1.0 | 0.3 | 0.0 | 0.8 | 0.2 | 0.0 | 0.8 | 0.2 | 0.0 | 0.3 | 0.2 | 0.0 |
| 169 | CLOVER BAR 2 | ENC2 | | Gas | 18.2 | 18.2 | 18.2 | 18.2 | 18.2 | 18.2 | 18.2 | 18.2 | 18.2 | 18.2 | 18.2 | 18.2 |
| 170 | DOW UPGRADE PHASE 1 | DOWGEN15M | | Co-gen | 4.9 | 2.1 | 0.0 | 2.9 | 3.0 | 0.9 | 5.9 | 3.4 | 1.0 | 6.0 | 3.0 | 0.2 |
| 171 | CLOVER BAR 3 | Project593_3_SUP | | Gas | 70.7 | 70.7 | 70.7 | 70.7 | 70.7 | 70.7 | 70.7 | 70.7 | 70.7 | 70.7 | 70.7 | 70.7 |
| 172 | MEG ENERGY | MEG1 | | Co-gen | 65.6 | 65.6 | 65.6 | 65.6 | 65.6 | 65.6 | 65.6 | 65.6 | 65.6 | 65.6 | 65.6 | 65.6 |
| 173 | SUMMIT CROSSFIELD ENERGY CENTRE | CRS1, CRS2, CRS3 | | Gas | 120.0 | 120.0 | 20.8 | 120.0 | 120.0 | 25.8 | 118.0 | 118.0 | 36.4 | 120.0 | 120.0 | 29.0 |
| 174 | DAPP POWER WESTLOCK EXPANSION | Project692_1_SUP | | Gas | 0 | 0 | 0 | 6.25 | 6.25 | 6.25 | 6.25 | 6.25 | 6.25 | 6.25 | 6.25 | 6.25 |

* Capacity is determined as per AESO rules for the periods defined.