

2012 Loss Factors Generic Stacking Order

SEPTEMBER 16, 2011



	Name	Signature	Date
Prepared by:	Ryan Fehr, EIT.	<i>Ryan Fehr</i>	Sept 16 2011
Reviewed by:	Ashikur Bhuiya, P.Eng.	<i>Ashikur Bhuiya</i>	Sep 16/2011
Approved by:	Fred Ritter, P.Eng	<i>Fred Ritter</i>	Sept. 16, 2011

APEGGA Permit to Practice P-8200

Table of Contents

1 Purpose	1
2 Introduction	1
3 Background	2
4 2012 GSO Key Features	2
4.1 2011 Important Generator Retirements.....	3
5 2012 Generic Stacking Order	4
Appendix 1: 2012 Generic Stacking Order	5

1 Purpose

The purpose of this document is to describe the 2012 Generic Stacking Order as the order applies to the loss factor calculation.

2 Introduction

The Generic Stacking Order (GSO) is a key component in the loss factor calculation. Generators are dispatched to meet system demand in the base cases according to the order and generation amount specified in the GSO.

The loss factor GSO contains two key pieces of information –

1. Generation supply levels on a net-to-grid basis (NTG) for 12 seasonal cases¹ (four seasons and three load levels as defined below) for all generators, and

Season	Timeframe	Scenario
Winter	December, 2011 – February, 2012	High
		Medium
		Low
Spring	March, 2012 – May, 2012	High
		Medium
		Low
Summer	June, 2012 – August, 2012	High
		Medium
		Low
Fall	September, 2012 – November, 2012	High
		Medium
		Low

2. Generation dispatch order.

The Rule governing the determination of the GSO generation supply levels can be located at www.aeso.ca > Rules & Standards > ISO Rules > Current Rules. In summary, the generation supply levels are determined using historical data for existing generators (in service for more than a year). For generators that have been in service for less than one year, data is provided by the owner or the supply levels are estimated by the Incapability Factors or by a combination of actual data and the Incapability Factors. To determine the dispatch order, a statistical analysis is used to determine a relationship between the generator output and the actual historical hourly pool price. The process is explained in Section 4.0. The AESO will request annually from generation owners confirmation that the previous year’s historical data is appropriate to use. Additional blocks are used where necessary to reflect a generator’s multiple bidding strategy.

The TMR requirement (please refer to www.aeso.ca > Rules and Standards >Current Operating Policies and Procedures > “Complete Set of OPPs”) supersedes all other operational criteria and hence TMR generators are dispatched first on the list when required to fulfill the reliability criteria.

¹ Loss Factor base cases are relevant to NTG amount whereas operations and planning cases use more detailed modeling of the system including the behind the fence elements.

3 Background

In 2006, the AESO began utilizing a new methodology, 50% Area Load Corrected R-Matrix, for the determination of generator and opportunity service loss factors. The methodology reflects the requirements of the Transmission Regulation. More information on the methodology can be found in the Current ISO Rules (www.aeso.ca > Rules and Standards >Current ISO Rules> "[Appendix 6 - Transmission loss Factor Methodology & Assumptions](#)").

4 2012 GSO Key Features

The highlights of the 2012 GSO preparation process are;

1. Average historical net-to-grid (NTG) output of a generator is considered for each of the twelve seasonal cases.
2. The determination of TMR and the energy component is done using SCADA data. The historical TMR instruction amount as dispatched by the system controller is used as the TMR amount. The difference between the total SCADA amount and the TMR instruction amount is used as the energy component. For example, if TMR instruction is 25 MW and the actual amount is 45 MW then the TMR amount will be 25 MW and the energy component will be 20 MW.
3. Generator owners were provided an opportunity to comment on and suggest revisions to the GSO capacities² to correct calculation errors by the AESO on historical data or proposed operational characteristics on new generation.
4. The net of import and export (separately for BC, and Saskatchewan) is shown in the GSO only if the net is import. If the net is export the GSO shows zero for the scenario. The net import (if any) is added at the end of the 2nd block of Hydro. If the net is export then it will be reflected in the loss factor base cases. The DOS loads will be reflected in the loss factor base cases.
5. The numbers of hours (H values) used for averaging the historical generator output are taken from the AIES seasonal load duration curve analysis (Please see Appendix 6 of the AESO Rules).
6. No maintenance or outage data is used in the 2012 GSO as average historical net-to-grid output of a generator inherently contains this information.
7. 12 seasonal net-to-grid generations are assigned to each individual generator at the point of supply (POS).
8. The generator order, except for units such as wind, import, and hydro generation, is determined by the actual price responsiveness of the generators in each group.
9. Future generators expected to be connected in the forecast year that have Alberta Utilities Commission (AUC) approval will be included in the GSO.
10. Generators that have filed decommissioning plans with the AESO will be removed accordingly.
11. The AESO typically relies on an operating profile submitted by the generator owner of a new generator. In the event this information has not been provided, the AESO will rely on the Canadian Electricity Association's (CEA) latest annual report on Generation Equipment Status

² www.aeso.ca/downloads/Transmission_Loss_Factor_GSO_Data_Confirmation_Request.pdf

utilizing the incapability factors (ICBF) to calculate the power available to the AIES. (1- ICBF) has been considered as equivalent to Available Capacity Factors (ACF).

12. The 2012 GSO considers the NTG amount at the point of supply (POS). Since any given loss factor is primarily the function of the NTG amount of generation, the 2012 GSO represents an aggregate of generation at the point of supply. An equivalent generator is considered at the bus from which the NTG amount related to the Measurement Point Identification (MPID) is obtained. For example, Horseshoe has 4 generators with a single MPID which is HSH. The 4 generators are connected to Bus 172 (12 kV). They are represented as a single unit at Bus 171 (138 kV) because the AESO billing database contains NTG data for all of these four units (related to MPID HSH) at Bus 171. The same approach is applied to the Industrial System Designations (ISD). All ISDs are represented by a single equivalent generator and load. The GSO contains a column with bus numbers for corresponding MPIDs.
13. An energy stacking order is created for all generation units based on lowest operating cost for units predominantly of the same fuel type. If multiple units have the same operating costs the unit's previous year's loss factors are used to determine dispatch order. Each generator's hourly bidding prices and associated generation MW changes are combined and sorted as a multi-block stacking order for that generation unit for the 12 month period (January 1st 2010 - December 31st 2010). The generation unit is then divided into two blocks. Two blocks are chosen to avoid additional complexity for limited modeling improvement. A first block price is determined by calculating the average bid price per MW dispatched as a first block in the 12 month period. The first block size is defined as the percentage of first block MW dispatched divided by total MW dispatched multiplied by the GSO value for that seasonal scenario. Generation volumes above the first block size belong to the second block. The second block price is determined by calculating the average bid price per MW dispatched for every block above the first block for the same 12 month period. The second block size is calculated as the percentage of MW dispatched outside of the first block divided by the total MW dispatched then multiplied by the GSO value for that seasonal scenario. However, not all generators have a 2nd block. The statistical analysis shows that some generators have an insignificant amount of generation in the 2nd block which indicates their price insensitivity. A weighted average of generator output of 12 seasonal outputs is calculated based on the H values or duration of the scenarios. A second block for a generator is considered, in general, if the annual weighted average is 5 MW or greater. In some cases a second block is not assigned to a generator even though the weighted average is more than 5 MW such as for small power research and development (SPR&D) and Wind generators.

The 2012 GSO is similar to its predecessors in the following aspects:

1. Units with similar generation technology in cases where operating costs are identical are ranked according to their previous year's loss factors.
2. No bid price, specific TMR, maintenance schedules, or heat rate information is revealed.
3. Multiple blocks (two blocks) are used to represent the historical response of the generators to pool price.
4. The GSO is separated into two blocks (where necessary) and into similar generation technologies (i.e. wind, co-gen, coal, etc)

4.1 2011 Important Generator Retirements

1. Sundance Units 1 and 2 have been out of service since December of 2010

5 2012 Generic Stacking Order

The following describes the application of the GSO to the loss factor base cases:

1. **Transmission Must Run (TMR) generators** – the generators represent the expected TMR dispatch (of gas, combined cycle, or other units) beyond area generation energy market participation. The TMR units are listed in the AESO OPP 501. TMR is required in specific areas of the AIES to meet reliability criteria. The total NTG amount assigned to the TMR generators in the 2012 GSO is obtained from the following two sources:
 - a) The average historical TMR total (SCADA) is calculated for 12 seasonal cases in the past twelve months (June 1 2010 to May 31 2011). The AIES seasonal load duration curve analysis is used to obtain the average TMR total amount of each generator.
 - b) The average TMR instruction amount (as dispatched by the System Controller) is calculated for 12 seasonal cases in the past twelve months (June 1 2010 to May 31 2011). The AIES seasonal load duration curve analysis is used to obtain the average TMR instruction amount for each generator.

According to the OPPs when the area criteria requirement is not met by the generation from local generators through energy market dispatches, TMR dispatches will be issued to TMR-contracted generators to make up the shortfall. TMR-contracted generators will be dispatched according to the TMR dispatch orders. The actual TMR dispatch order is confidential to the AESO.

2. **Data** – Most of the data used in the 2012 GSO such as Alberta system load, and generation amount at each POS are historical and taken from the most recent 12 months' data in the AESO's billing system. The data extraction period is June 1, 2010 to May 31, 2011.
3. **Dispatch Generator** – In general, the energy stacking order is formed to more closely reflect an actual operational perspective. The generators may bid multiple blocks but the typical block size beyond the 2nd block is very small.
4. **Wind Generation** – Wind generation does not have a relationship to pool price.
5. **Small Power Research & Development** – The relative order remains the same as the 2011 GSO. SPR&D generators are exempt by law from paying for losses.
6. **Distribution Connected Generation** – consists of distribution connected generators with STS contracts that occasionally results in supply of power to the AIES. Several prime movers may exist at a distribution generation location. The placement of the distribution generation in the stacking order is determined mainly by the predominant source of generation at the STS location.
7. **Future Generation** – generators expected to be connected in the forecast year that have AUC approval will be included in the GSO and placed with the same fuel type group.
8. **Import levels** – as per the 2007 Transmission Regulation, inter-tie levels are included in the loss factor calculation power flows. Imports are added in the GSO following the second block of hydro generation. The location reflects the relative level of availability of import resources for Alberta. The GSO provides a list of generation or equivalent entity (imports or industrial system designation) along with their predicted seasonal output capacity. Exports are not added in the GSO as they are not a supply component of the system.

Appendix 1: 2012 Generic Stacking Order

New CSO Number	Name	MP_ID	Gen with 2nd Block	Generation Type	Winter Peak Capacity, MW	Winter Med Capacity, MW	Winter Low Capacity, MW	Spring Peak Capacity, MW	Spring Med Capacity, MW	Spring Low Capacity, MW	Summer Peak Capacity, MW	Summer Med Capacity, MW	Summer Low Capacity, MW	Fall Peak Capacity, MW	Fall Med Capacity, MW	Fall Low Capacity, MW	
1	RAINBOW 4	RL1	1	Co-gen	41.5	40.7	42.2	31.8	29.4	24.9	30.7	27.9	26.6	42.1	35.9	32.7	
2	RAINBOW 5	RBS	1	Gas	27.9	17.4	11.2	23.0	17.4	12.2	14.0	10.6	8.9	17.5	16.4	13.1	
3	POPLAR HILL	PH1	1	Gas	0.9	0.6	0.2	1.2	2.2	0.0	0.0	0.3	0.0	0.7	0.5	0.0	
4	VALLEYVIEW	VWV1	1	Gas	0.1	0.0	0.0	0.0	2.0	0.0	0.0	0.3	0.0	0.0	0.0	0.0	
5	FORT NELSON	FN1	1	Gas	12.4	28.6	36.0	31.1	34.2	35.9	20.7	34.0	36.0	27.8	32.1	32.1	
6	BEAR CREEK G1	BCR1	1	Co-Cycle	6.4	7.9	4.3	12.8	16.2	0.2	0.1	3.8	1.4	13.6	6.8	4.4	
7	RAINBOW 2	RB2	1	Gas	0.0	0.7	0.0	0.6	1.5	1.3	0.0	0.0	0.0	0.0	0.0	0.0	
8	TABER WIND	TAB1	1	Wind	23.4	32.0	50.2	20.7	24.9	27.8	9.7	17.1	37.1	20.0	20.7	26.7	
9	SUNCOR HILLRIDGE WIND FARM	SCR3	1	Wind	7.8	13.4	19.7	7.5	11.3	13.6	4.2	7.3	15.6	9.7	9.5	12.3	
10	GLENWOOD	0000022911	1	Wind, DG	0.0	0.0	0.0	0.0	0.0	0.0	2.9	3.1	4.0	0.0	1.0	1.4	
11	FT MACLEOD	0000019151	1	Wind, DG	0.0	0.0	0.0	0.0	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.0	
12	CASTLE RIVER	CR1	1	Wind	11.4	13.8	21.2	8.0	10.9	7.3	7.5	7.2	10.4	13.9	11.5	9.6	
13	SUNCOR MAGRATH	SCR2	1	Wind	6.7	12.3	19.5	8.4	10.7	11.0	4.6	8.0	14.0	10.3	9.8	9.5	
14	PINCHER CREEK	0000039611	1	Wind, DG	0.6	1.2	3.0	0.5	1.4	1.4	0.4	0.9	2.3	1.1	1.7	1.9	
15	MCKENZIE	AKR1	1	Wind	17.6	27.9	45.2	15.0	21.3	21.1	10.2	16.5	31.5	22.1	20.8	20.1	
16	KETTLES HILL WIND ENERGY PHASE 2	KRW1	1	Wind	16.7	22.9	37.1	10.7	21.2	19.5	8.8	15.2	27.2	22.2	21.9	20.2	
17	TAYLOR WIND PLANT	TAY2	1	Wind	0.5	0.9	1.4	0.7	0.8	0.7	0.4	0.4	0.7	0.6	0.6	0.4	
18	BLUE TRAIL WIND FARM	BTR1	1	Wind	11.9	21.6	34.3	11.8	19.2	19.3	8.7	14.0	27.7	15.0	19.2	19.7	
19	SUMMERVIEW 1	JEV1	1	Wind	19.2	22.9	35.5	12.3	21.1	18.1	10.5	14.2	32.0	18.2	20.8	19.3	
20	SUMMERVIEW 2	JEV2	1	Wind	14.0	19.7	29.8	10.5	19.3	15.1	6.2	8.1	10.3	14.2	18.7	15.5	
21	SOBERGLEN	GWV1	1	Wind	27.0	42.0	42.9	16.1	24.6	26.6	11.4	19.7	35.7	29.4	23.5	23.8	
22	TRANSALTA ARDENVILLE WIND FARM	ARD1	1	Wind	14.8	20.1	29.8	14.2	20.3	23.6	16.9	16.9	16.9	25.1	25.1	25.1	
23	COWLEY EXPANSION 1	CRE1	1	Wind	0.2	0.2	0.3	0.2	0.2	0.1	0.2	0.1	0.2	0.2	0.2	0.2	
24	COWLEY EXPANSION 2	CRE2	1	Wind	0.3	0.4	0.5	0.2	0.3	0.2	0.2	0.2	0.2	0.3	0.3	0.3	
25	COWLEY NORTH	CNR1	1	Wind	6.2	8.4	9.4	5.2	5.3	4.1	3.7	3.5	4.8	5.4	4.9	4.9	
26	COWLEY RIDGE WIND POWER PHASE1	PKNE	1	Wind	3.0	3.3	4.7	2.7	3.1	2.2	2.4	2.0	2.5	2.7	2.8	2.6	
27	COWLEY RIDGE WIND POWER PHASE2	CRWD	1	Wind	2.6	3.0	4.2	2.6	2.8	1.8	2.0	1.8	2.1	2.6	2.4	2.2	
28	GHOST PINE WIND FARM	NEP1	1	Wind	1.9	11.9	17.6	18.5	20.6	32.7	19.2	19.2	19.2	28.6	28.6	28.6	
29	SUNCOR WINTERING HILLS WIND ENERGY PROJECT	SCR4	1	Wind	39.6	39.6	39.6	30.3	30.3	30.3	22.5	22.5	22.5	33.5	33.5	33.5	
30	ALBERTA WIND ENERGY OLD MAN RIVER WIND FARM	OWE19_1_GEN	1	Wind	0.0	0.0	0.0	16.2	16.2	16.2	12.0	12.0	12.0	17.9	17.9	17.9	
31	CAPITAL POWER HALKIRK WIND PROJECT	Project723_1_SUP	1	Wind	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	57.2	57.2	57.2	
32	WESGEN	WS1	1	Bio-mass	15.3	14.7	14.9	12.0	13.1	13.8	11.6	12.1	13.3	13.7	13.4	13.7	
33	WHITE COURT	EAGL	1	Bio-mass	23.9	23.8	24.0	23.9	21.2	18.2	23.2	23.2	24.8	22.3	20.7	21.3	
34	BRIDGE CREEK	GOC1	1	Gas-decomp	4.0	3.7	3.6	4.0	3.5	3.4	1.4	1.9	2.8	3.2	1.8	2.1	
35	DRAYTON VALLEY PL IPP	DV1	1	Bio-mass	7.0	6.8	6.8	6.7	7.3	8.0	8.1	8.1	8.9	7.5	9.3	9.5	
36	CHIN CHUTE	CH1	1	Hydro	0.0	0.0	0.0	0.0	0.0	2.3	4.2	4.9	3.7	0.0	2.4	3.1	
37	DICKSON DAM 1	DKS1	1	Hydro	4.9	4.8	4.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
38	WATER IPP	WTRN	1	Hydro	1.6	1.3	1.3	0.8	2.0	2.5	2.5	2.6	2.7	0.0	0.0	0.0	
39	ST MARY IPP	STM1	1	Hydro	2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.3	0.0	0.0	0.0	
40	RAYMOND RESERVOIR	RMD	1	Hydro	0.0	0.0	0.0	0.0	0.7	2.2	7.2	6.7	1.8	0.0	3.5	4.6	
41	NORTHSTONE ELMWOLF	NPC1	1	Co-gen	3.9	1.1	0.0	0.3	0.4	0.0	1.6	0.3	0.0	1.1	0.2	0.0	
42	FORTSALBERTA AL-PAC PULP MILL	AFG1TX	1	Gas	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	
43	GRANDE PRAIRIE ECOPOWER CENTRE	GPEC	1	Co-gen	10.6	10.9	11.0	6.0	10.8	9.5	8.8	11.5	15.4	11.6	9.7	10.7	
44	WAUJUROO	0000040511	1	Co-gen, DG	4.9	4.8	4.8	5.3	3.5	1.5	4.8	5.3	5.5	6.5	6.1	6.6	
45	P&G WEYERHAEUSER	WEY1	1	Co-gen	0.0	0.0	0.0	0.0	0.2	0.3	0.0	0.0	0.0	0.0	0.0	0.0	
46	BEAR CREEK G2	BCR2	1	Co-Cycle	16.5	15.1	12.6	15.6	10.6	9.1	22.1	14.6	11.4	13.4	11.8	11.9	
47	HARMATTAN GAS PLANT DG	0000025611	1	Gas	5.1	7.2	7.6	5.6	8.4	9.5	1.5	1.5	1.5	1.5	1.5	1.5	
48	SHELL CAROLINE	SHCG	1	Co-gen	0.2	0.5	0.4	3.5	5.7	5.5	0.0	0.3	0.8	0.0	0.8	1.2	
49	DASHOWA	DA1	1	Co-gen	2.9	2.9	2.6	2.5	2.1	1.4	3.5	1.6	0.9	2.7	1.7	1.2	
50	ALTAGAS PARKLAND	0000034911	1	Gas, DG	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
51	BALZAC	NX01	1	Co-Cycle	51.9	44.8	25.1	55.6	26.7	7.9	69.2	42.9	17.0	57.6	46.8	24.8	
52	CARSELAND	TC01	1	Co-gen	65.9	64.8	61.7	60.1	59.2	60.8	60.0	60.3	61.7	62.4	53.5	52.8	
53	CITY OF MEDICINE HAT	CMH1	1	Gas	32.3	19.2	2.1	22.9	8.1	1.5	36.4	17.0	8.1	12.2	10.8	4.3	
54	CAVALIER	CA1	1	Co-Cycle	23.3	15.4	7.3	23.9	1.6	24.8	14.6	4.1	19.9	15.7	17.9	17.9	
55	NOVA JOFFRE	NOVAGEN15M	1	Co-gen	111.1	92.2	67.0	97.1	67.2	13.2	131.1	67.5	30.0	97.0	72.6	46.8	
56	BUCK LAKE	0000045411	1	Co-gen, DG	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
57	SHELL SCOTTFORD	SC1G	1	Co-gen	0.9	0.1	0.0	0.1	2.3	0.5	0.0	0.0	0.0	0.0	0.2	0.2	
58	REDWATER	TD02	1	Co-gen	25.6	24.7	23.7	24.0	23.2	23.3	18.9	18.4	16.6	22.0	23.7	23.6	
59	DOWN GTG	DOWNGEN15M	1	Co-gen	54.9	34.9	21.5	36.5	37.5	26.3	52.8	39.1	16.2	53.7	48.5	26.0	
60	PRIMROSE	PR1	1	Co-gen	5.7	7.5	5.3	0.0	3.5	5.8	1.9	5.6	5.3	3.1	6.8	8.1	
61	CNRL HORIZON	CNR5	1	Co-gen	9.8	12.9	14.1	0.0	0.0	11.9	8.8	1.7	2.3	5.8	6.3	6.3	
62	FOSTER CREEK G1	EC04	1	Co-gen	44.4	41.8	37.0	42.3	34.0	29.2	30.3	30.8	36.8	4.9	32.0	35.2	
63	MCKAY RIVER	MMRC	1	Co-gen	161.4	157.1	154.0	161.9	149.0	133.4	140.2	144.5	148.3	161.9	128.8	128.0	
64	SYNCRUDE	SCL1	1	Co-gen	39.8	34.1	30.3	32.3	26.7	20.9	19.7	16.6	24.7	17.4	40.6	41.7	44.8
65	MEG ENERGY	MEG1	1	Co-gen	78.7	77.3	76.0	80.9	71.4	69.7	60.7	65.9	69.7	81.3	53.6	49.9	
66	MUSKEG	MKR1	1	Co-gen	59.9	39.1	22.2	53.8	33.4	16.8	62.3	47.7	36.3	61.8	45.6	32.1	
67	SUNCOR MILLENNium	SCR1	1	Co-gen	123.6	116.3	106.7	155.3	132.1	129.8	104.3	84.1	71.8	118.9	125.8	117.6	
68	NEXEN OPTI	NX02	1	Co-gen	46.7	46.7	46.3	46.3	46.3	46.3	46.3	46.3	46.3	46.3	46.3	46.3	46.3
69	MANKESES COLD LAKE	ICR1	1	Co-gen	46.9	44.2	39.4	41.5	35.6	41.1	37.0	41.6	47.6	50.0	47.9	49.1	
70	ENMAX CALGARY ENERGY CENTRE CTG	CES1	1	Co-Cycle	13.9	8.7	2.7	14.1	7.0	0.8	7.4	2.9	0.5	11.9	7.2	3.0	
71	ENMAX CALGARY ENERGY CENTRE STG	CES2	1	Co-Cycle	8.6	5.3	1.7	8.2	4.3	0.5	4.3	1.8	0.2	6.8	4.4	1.8	
72	CASCADE	CAS	1	Hydro	20.7	10.7	0.1	20.1	8.4	0.3	17.0	0.0	15.3	6.5	0.2	0.2	
73	GHOST	GH0	1	Hydro	15.2	15.1	3.1	15.7	18.1	12.1	12.6	25.9	18.0	20.1	20.8	8.6	
74	SPRAY	SPR	1	Hydro	38.0	33.2	10.9	37.6	25.7	2.0	23.0	13.2	0.8	50.0	26.2	3.8	
75	THREE SISTERS	THS	1	Hydro	0.8	0.8	0.4	0.4	0.0	0.0	0.7	0.2	0.0	1.5	0.9	0.2	
76	HORSESHOE	HSH	1	Hydro	10.7	8.4	7.9	9.5	7.9	7.7	13.0	12.3	11.7	9.0	8.5	8.3	
77	RUNDLE	RUN	1	Hydro	13.5	11.3	3.6	12.2	8.7	0.6	7.7	4.4	0.3	15.1	8.7	1.3	
78	BARBER	BAR	1	Hydro	5.4	5.4	0.0	8.8	4.6	3.1	9.8	3.8	4.8	4.8	4.8	4.8	
79	KANANASKIS	KAN	1	Hydro	7.9	8.5	7.9	9.9	9.4	10.0	14.9	14.1	12.8	6.6	8.3	8.2	
80	SPRING COULEE	0000038511	1	Hydro, DG	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
81	BEARSPAW	BPW	1	Hydro	6.4	6.4	6.6	6.3	7.8	9.8	11.3	11.3	11.9	5.8	5.8	5.7	
82	POCATERRA	PCC	1	Hydro	10.6	5.2	0.3	9.0	2.9	0.0	1.3	0.2	0.0	7.8	2.2	0.1	
83	INTERLAKES	INT	1	Hydro	3.8	2.0	2.6	0.5	0.5	0.5	0.1	0.0	3.2	0.0	2.6	0.0	
84	STIRLING	000000711	1	Hydro, DG	0.0												

NER GSO Number	Name	MP_ID	Gen with 2nd Block	Generation Type	Winter Peak Capacity, MW*	Winter Med Capacity, MW*	Winter Low Capacity, MW*	Spring Peak Capacity, MW*	Spring Med Capacity, MW*	Spring Low Capacity, MW*	Summer Peak Capacity, MW*	Summer Med Capacity, MW*	Summer Low Capacity, MW*	Fall Peak Capacity, MW*	Fall Med Capacity, MW*	Fall Low Capacity, MW*
127	KANANASKIS	KAN	2	Hydro	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
128	BEARSPAW	BPW	2	Hydro	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
129	DICKSON DAM 1	DKSN		Hydro	0.0	0.0	0.0	4.4	6.8	11.1	10.9	11.1	10.4	4.9	7.2	7.9
130	WATER IPP	WTRN		Hydro	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.3	2.4	2.5
131	ST MARY IPP	STMY		Hydro	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.3	2.3	2.3
132	BC IMPORT	BCHIMP		Import	523.0	383.5	108.7	517.6	419.2	320.9	414.8	250.8	240.9	402.1	149.3	0.0
133	SASKATCHEWAN IMPORT	SPOIMP		Import	90.8	61.8	41.2	98.3	77.3	78.3	24.4	60.3	63.6	50.1	29.0	27.2
134	STURGEON 1	ST1		Gas	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
135	STURGEON 2	ST2		Gas	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
136	ATCO VALLEY VIEW 2	VVW2		Gas	0.8	0.3	0.0	0.0	0.2	0.0	0.5	0.0	0.0	0.0	0.0	0.0
137	RAINBOW 1	RB1		Gas	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
138	RAINBOW 3	RB3		Gas	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
139	CLOVER BAR 3	ENC3	1	Gas	33.5	11.9	2.4	0.0	0.0	0.0	21.1	5.3	0.0	22.6	10.5	3.1
140	CLOVER BAR 1	ENC1	1	Gas	11.3	7.6	0.9	7.9	1.4	0.0	2.0	0.8	0.0	4.8	1.0	0.3
141	CLOVER BAR 2	ENC2	1	Gas	14.6	9.6	1.5	12.3	2.3	0.0	0.0	0.0	0.0	8.0	2.1	0.3
142	ENMAX CROSSFIELD ENERGY CENTER	CRS3	1	Gas	2.0	0.6	0.1	2.2	0.6	0.0	2.3	0.7	0.0	1.9	0.4	0.1
143	ENMAX CROSSFIELD ENERGY CENTER	CRS1	1	Gas	1.4	0.6	0.0	2.1	0.7	0.0	2.3	0.6	0.0	1.7	0.3	0.1
144	ENMAX CROSSFIELD ENERGY CENTER	CRS2	1	Gas	1.8	0.6	0.1	2.4	0.7	0.0	2.6	0.8	0.0	1.6	0.4	0.1
145	NORTHERN PRAIRIE POWER PROJECT	NPP1	1	Gas	43.6	17.0	0.9	13.9	9.8	0.0	33.6	7.0	0.0	19.9	4.5	0.3
146	ENMAX CALGARY ENERGY CENTRE CTG	CES1	2	Co-Cycle	137.7	85.8	26.7	139.3	69.0	8.3	73.8	28.8	4.8	117.8	71.3	29.9
147	ENMAX CALGARY ENERGY CENTRE STG	CES2	2	Co-Cycle	65.0	52.4	16.5	61.5	42.3	4.8	42.4	17.5	2.3	67.4	43.5	17.9
148	SUNCOR MILLENIUM	SCR1	2	Co-gen	8.3	7.8	7.2	10.4	8.9	8.7	7.0	5.6	4.8	8.0	8.4	7.9
149	CAVALIER	EC01	2	Co-Cycle	66.6	46.9	20.8	65.3	28.0	4.5	70.8	41.6	11.8	56.9	44.8	24.4
150	CITY OF MEDICINE HAT	CMH1	2	Gas	11.9	7.1	0.8	8.4	3.0	0.6	13.4	6.3	3.0	4.5	4.0	1.6
151	BALZAC	NX01	2	Co-Cycle	20.9	18.1	10.1	22.4	10.8	3.2	27.9	17.3	6.9	23.2	18.9	10.0
152	DOW GTG	DOWGEN15M	2	Co-gen	15.2	9.7	6.0	10.1	10.5	7.3	14.6	10.8	4.5	14.9	13.4	7.2
153	MUSKEG	MRK1	2	Co-gen	7.5	4.9	2.8	6.7	4.2	2.1	7.8	6.0	4.5	7.7	5.7	4.0
154	NOVA JOFFRE	NOVAGEN15M	2	Co-gen	19.8	16.5	12.0	17.3	12.0	2.4	23.4	12.1	5.3	17.3	13.0	8.3
155	REDWATER	TC02	2	Co-gen	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
156	CARLELAND	TC01	2	Co-gen	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8
157	CLOVER BAR 2	ENC2	2	Gas	82.1	53.7	8.4	89.0	12.8	0.0	0.0	0.0	0.0	45.0	11.5	1.5
158	CLOVER BAR 1	ENC1	2	Gas	28.7	19.2	2.4	19.9	3.5	0.0	5.0	2.0	0.0	12.0	2.6	0.6
159	CLOVER BAR 3	ENC3	2	Gas	41.1	14.6	2.9	0.0	0.0	0.0	25.8	6.5	0.0	27.7	12.9	3.8
160	ENMAX CROSSFIELD ENERGY CENTER	CRS2	2	Gas	23.3	8.4	0.7	31.7	9.0	0.0	34.4	10.0	0.0	21.0	5.1	1.0
161	ENMAX CROSSFIELD ENERGY CENTER	CRS3	2	Gas	28.8	9.0	0.7	31.7	8.6	0.1	33.5	9.6	0.4	27.1	5.8	0.8
162	ENMAX CROSSFIELD ENERGY CENTER	CRS1	2	Gas	20.6	8.5	0.7	30.8	9.6	0.1	33.1	9.4	0.0	24.7	4.7	1.4
163	NORTHERN PRAIRIE POWER PROJECT	NPP1	2	Gas	23.5	9.2	0.5	7.5	5.3	0.0	18.1	3.8	0.0	10.7	2.4	0.1
164	FORT NELSON	FNG1	2	Gas	29.8	10.4	4.2	7.1	5.5	2.0	19.3	5.4	1.9	12.1	3.1	2.4
165	RAINBOW 4	RL1	2	Gas	2.9	1.2	1.4	0.5	1.9	4.0	3.3	3.2	2.4	0.7	0.7	0.9
166	BEAR CREEK G1	BCRK	2	Co-Cycle	25.3	18.6	9.0	11.3	1.1	0.0	29.9	8.0	1.7	14.2	1.6	0.1
167	POPLAR HILL	PH1	2	Gas	3.6	0.7	0.0	0.5	0.6	0.0	5.4	1.6	0.0	0.1	1.0	0.0
168	RAINBOW 5	RB5	2	Gas	1.6	0.5	0.4	0.3	0.7	0.2	0.3	0.7	0.2	0.4	0.7	0.4
169	VALLEYVIEW	VVW1	2	Gas	1.2	0.4	0.2	0.1	0.2	0.1	0.4	0.2	0.0	0.0	0.1	0.1
170	RAINBOW 2	RB2	2	Gas	1.2	0.5	0.0	1.1	0.2	0.6	0.0	0.0	0.0	0.0	0.0	0.0
171	DRYWOOD 1	DRW1	1	Gas	3.5	0.7	0.0	0.5	0.3	0.0	2.5	0.3	0.0	0.6	0.2	0.0
172	BC HYDRO FORT NELSON GENERATING STATION UPGRADES	FNG1	2	Gas	28.2	28.2	28.2	28.2	28.2	28.2	28.2	28.2	28.2	28.2	28.2	28.2

* Capacity determined as per AESO Rules for the defined period