

ISO Rules

Part 200 Markets

Division 205 Ancillary Services

Section 205.5 Spinning Reserve Technical Requirements and Performance Standards



Applicability

- 1 Section 205.5 applies to:
 - (a) a **pool participant**; and
 - (b) the **ISO**,

in relation to qualifying for, providing and utilizing **spinning reserve**.

Requirements

General

- 2 A **pool participant** that provides or anticipates providing **spinning reserve** must satisfy the technical requirements set out in this section 205.5 and must continue to satisfy such technical requirements while providing **spinning reserve**.

Minimum Requirements

- 3(1) A **pool participant** must ensure that each **generating unit** or load is capable of providing a minimum of ten (10) MW of **spinning reserve**.

- 3(2) A **pool participant** must ensure that each **generating unit** or load is capable of providing the amount of **real power** the **ISO** qualifies the **generating unit** or load to provide under subsection 4(1) for the period from ten (10) minutes after receiving a **directive** to provide **spinning reserve** to sixty (60) minutes after receiving a **directive** to provide **spinning reserve**.

- 3(3) A **pool participant** must ensure that each **generating unit** or load is equipped with a **governor system** that:

- (a) is responsive to both over frequency and under frequency events;
- (b) has a total deadband of equal to or less than zero point zero three six (0.036) Hertz;
- (c) has a droop setting equal to or greater than three percent (3%) but less than or equal to five percent (5%) based on:
 - (i) the maximum operating range of each **generating unit** providing **spinning reserve**; or
 - (ii) the total **real power** capacity of each load providing **spinning reserve**;
- (d) has no intentional time delays added to the control system;
- (e) has a sample rate of at least thirty (30) samples per second;
- (f) has a resolution of at least zero point zero zero four (0.004) Hertz; and
- (g) while the **pool asset** is under a **dispatch** or **directive** to provide **spinning reserve** is:
 - (i) in service at all times; and
 - (ii) without load limiters or other control systems that override or interfere with the **governor system**; and
 - (iii) for **pool assets** providing both **spinning reserve** and **regulating reserve**, the **automatic generator control** signal must not override the frequency response of the **governor system**.

- 3(4) A **pool participant** must ensure that any **pool asset** providing **spinning reserve** complies with subsections 3(1), (2) and (3) as measured at the:

ISO Rules

Part 200 Markets

Division 205 Ancillary Services

Section 205.5 Spinning Reserve Technical Requirements and Performance Standards



- (a) stator winding terminals of each qualified **generating unit**; or
- (b) the circuit breaker or disconnection device that is electrically closest to each qualified load.

(5) The requirements set out in subsections 3(3)(e) and (f) do not apply to a **pool participant** that provides **spinning reserve** with a **generating unit** that is equipped with an analog **governor system**, as of the effective date of this section 205.5, until such time as the **governor system** is replaced.

(6) A **pool participant** must ensure that, for the applicable minimum time period set out in Appendix 1, each **generating unit** or load providing **spinning reserve** will not trip as a result of under-frequency or over-frequency deviations when its **pool asset** is under a **dispatch** or a **directive** to provide **spinning reserve**.

Qualification of a Generating Unit or a Load

4(1) The **ISO** must, prior to any **generating unit** or load providing **spinning reserve**, assess the eligibility of each **generating unit** or load and determine the **real power** in MW it is qualified to provide.

(2) The **ISO** must, in determining the **real power** quantity each **generating unit** or load is qualified to provide, consider the following:

- (a) whether the **generating unit** or load participates in a **remedial action scheme**;
- (b) the total **operating reserve** that could be lost during a single **contingency**; and
- (c) the maximum **real power** capability and minimum **real power** capability of each **generating unit** or load.

(3) The **ISO** must advise a **pool participant** of the eligibility of each **generating unit** or load within sixty (60) **days** of the **ISO** receiving an application for **spinning reserve**.

Application to Provide Spinning Reserve

5 A **pool participant** may apply to provide **spinning reserve** by completing and providing to the **ISO** the documents the **ISO** specifies and posts on the AESO website.

Performance Requirements to a Dispatch

6(1) A pool participant will not be paid for spinning reserve unless the **pool participant** ensures that:

- (a) upon receipt of a **dispatch** to provide **spinning reserve**, if the time stated in the **dispatch** for the **pool asset** to be in a position to provide the **real power** quantity indicated in the **dispatch** is:
 - (i) more than fifteen (15) minutes from the time the **pool participant** receives the **dispatch**, the **pool asset** is in position at the time stated in the **dispatch**; or
 - (ii) fifteen (15) minutes or less from the time the **pool participant** receives the **dispatch**, the **pool asset** is in position at the time stated in the **dispatch** or as soon as possible thereafter but in any event, not more than fifteen (15) minutes after receiving the **dispatch**; and
- (b) the **pool asset** maintains the ability to provide the **real power** quantity corresponding to the **dispatch** quantity, as measured in accordance with subsection 3(4):
 - (i) by the times set out in subsections 6(1)(a)(i) and (ii); and
 - (ii) within a tolerance of minus:

ISO Rules

Part 200 Markets

Division 205 Ancillary Services

Section 205.5 Spinning Reserve Technical Requirements and Performance Standards



- (A) one (1) MW for a **dispatch** of less than or equal to twenty (20) MW; or
- (B) five percent (5%) for a **dispatch** greater than twenty (20) MW;

for as long as the **dispatch** is in effect.

(2) A **pool participant** must ensure that the **pool asset** remains connected to the **interconnected electric system** and be frequency responsive, as described in subsection 3(3), while under a **dispatch** to provide **spinning reserve**.

Performance Requirements to a Directive

7(1) A **pool participant** must, within ten (10) minutes after receiving a **directive** to provide **spinning reserve**, ensure that the **pool asset** is providing a quantity of **real power** equal to the instantaneous amount of **real power** of the **pool asset** at the time of the **directive** plus the amount of **real power** set out in the **directive**, as measured in accordance with subsection 3(4).

(2) A **pool participant** must ensure that, from the first time the **pool asset** achieves the quantity of **real power** set out in subsection 7(1) to fifteen (15) minutes after the time of the **directive**, the average quantity of **real power** provided by the **pool asset** is equal to or more than the quantity set out in subsection 7(1), as measured in accordance with subsection 3(4).

(3) A **pool participant** must ensure that, for each consecutive ten (10) minute interval starting fifteen (15) minutes following the receipt of a **directive**, the average **real power** from the **pool asset** equals the quantity set out in subsection 7(1), as measured in accordance with subsection 3(4), within a tolerance of:

- (a) five (5) MW for a load **pool asset** or a generating **pool asset** with a **maximum capability** of two hundred (200) MW or less; or
- (b) ten (10) MW for a load **pool asset** or a generating **pool asset** with a **maximum capability** of greater than two hundred (200) MW.

(4) Notwithstanding subsection 3(2), a **pool participant** must ensure the **pool asset** continues to provide the average **real power** set out in subsection 7(3) for as long as the **directive** is in effect.

(5) A **pool participant** must ensure that the **pool asset** remains connected to the **interconnected electric system** and remains frequency responsive, as described in subsection 3(3), while under a **directive** to provide **spinning reserve**.

(6) Notwithstanding subsections 7(1) through 7(4), a **pool participant** following the receipt of a **directive** for **spinning reserve** to zero (0) MW must as soon as possible, and, in any event, not more than fifteen (15) minutes after receiving the **directive** to zero (0) MW:

- (a) ensure the generating **pool asset** is within the **allowable dispatch variance** of its current energy **dispatch**; or
- (b) ensure the load **pool asset** is in position to provide the **real power** quantity indicated in its current **dispatch** for **spinning reserve**.

Test Requirements

8 The **ISO** may request that a **pool participant** test its **pool asset**'s responses to **dispatches** and **directives**:

- (a) prior to allowing the **pool asset** to provide **spinning reserve**; or
- (b) if the **ISO** provides evidence that the **spinning reserve** exhibits behaviour that is inconsistent with the requirements of this section 205.5.

ISO Rules

Part 200 Markets

Division 205 Ancillary Services

Section 205.5 Spinning Reserve Technical Requirements and Performance Standards



Maintaining Eligibility

9(1) The **ISO** may, if a **pool participant** refuses to comply with:

- (a) a testing request pursuant to subsection 8;
- (b) any other provision of this section 205.5; or
- (c) any other section of the **ISO rules** that affects the provision of **spinning reserve**;

provide notice to the **pool participant** that it cannot participate in the **spinning reserve** market until the **pool participant** is compliant with this section 205.5 and all other **ISO rules** that affect the provision of **spinning reserve**.

(2) A **pool participant** that has received a notice pursuant to subsection 9(1) must not submit an **offer** for **spinning reserve** until the **ISO** confirms that the **pool participant** is compliant with this section 205.5 and all other **ISO rules** that affect the provision of **spinning reserve**.

Appendices

Appendix 1 – *Frequency Ranges*

Revision History

Effective	Description
2014-12-23	Initial release

ISO Rules

Part 200 Markets

Division 205 Ancillary Services

Section 205.5 Spinning Reserve Technical Requirements and Performance Standards



Appendix 1

Frequency Ranges

High Frequency Duration		Low Frequency Duration	
Frequency (Hz)	Time (Sec)	Frequency (Hz)	Time (sec)
≥61.7	Instantaneous trip	≤57.0	Instantaneous trip
≥61.6	30	≤57.3	0.75
≥60.6	180	≤57.8	7.5
<60.6	Continuous operation	≤58.4	30